

Flauta Riga 3 NEW





Are you a professional and your project needs consulting and support?


BOOK AN APPOINTMENT

Main specifications

Mounting	Wall
Environments	Outdoor wet location
Light Source Type	LED
LED type	Power LED
Lamp category	LED
Number of heads	1
Power (W)	12
System power (W)	12
System flux (Im)	2x347

Physical

Color	Anthracite
Orientation	Fixed
Net weight (lb)	5.73
IP internal	65



Download

Dominoud	
Family spec sheet	₹ ZIP
Mounting instructions	<u>↓</u> ZIP

Photometric Files

LDT / IES













Ecodesign and Energy Labelling

This product contains a light source of energy efficiency class **E**



Replaceable (LED only) light source by a professional




Replaceable control gear by a professional

https://professional.flos.com/en-US/us/product/flauta-riga-3-f019a23du33/

F019A23DU33

Schematic light drawing



Beam	Angle DIR:	32°
h(m)	E(lx)	D(m)
1	1244	0.57
2	311	1.15
3	138	1.72
4	78	2.29
5	50	2.86

1244, cd		± 1	45°
Luminou 694 lm	ıs flux	(l umi	naire

Photometric

Lighting type	Indirect, Direct
Light distribution	Symmetric
CCT (K)	2700
CRI>	80
Beam angle C0-180 (°)	16
Beam angle C90-270 (°)	16
Beam angle indirect C0-180 (°)	16
Beam angle indirect	16

Electrical

Insulation class	II
Frequency (Hz)	50-60
Main voltage (Vac)	100-127
Driver	Integrated
Dimmable	Yes
Dimming type	Dimmable DALI 1
Dimming range (%)	10-100
Dimming interface	Dimmer Integrated
Emergency type	No

Notes

We recommend using a connection system with a degree of protection greater than or equal to the degree of protection of the luminaire.

During the installation and the maintenance of the fixtures it is important to be careful and avoid damages on the paint coating.

Damages on the coating exposed to outdoor conditions or water, could cause

Chemical substances affect the anticorrosion covering protection.

For LED fixtures, there is evidence that most of the damages are connected to electrical effects related to the insulations, which cause destructive electrical discharges

These effects are frequently caused by:

- over Voltage coming from the Mains' network where fixture is connected.
- electrostatic discharge (ESD) coming from the environment.

The use of a protective device against the overvoltage on the electrical installation is warmly suggest this helps to reduce the intensity of some of these phenomenon and prevent irreversible damages.

The selection of the type of device to be used must be adjust on the electrical plant. 110V version available by request.

https://professional.flos.com/en-US/us/product/flauta-riga-3-f019a23du33/

F019A23DU33