

# **BRICK PENDANT**






#### **Features:**

- Efficacy Of Up To 106lm/W\*
- High Output "DOB" LED Modules
- Decorative / Architectural Suspended Area Lighting
- Minimum Lumen Maintenance: 50 000h (L80B10)



Power Supply:	220 - 240V AC   50 - 60Hz				
Operating Temperature Range: (Ta - Ambient)	- 20°C to 35°C				
Colour Rendering Index:	CRI 80+				
Colour Consistency:	3-Step MacAdam				
Colour Temperature: (Kelvin / CCT)	<b>0</b> 4000K				
Installation Type:	Suspension				
Ingress Protection:	IP40				
IK Rating:	IK04				
Luminaire Colour:	Black				
Material:	Housing - Fitting frame construction CNC laser cut and co <sup>2</sup> welded mild steel finished in a durable outdoor epoxy powder coating Diffuser - Vacuum Formed PETG				
	Dimensions	Wattage (System)	CRI	Kelvin	Luminous Flux (Effective)
	151mm x 98mm x 98mm	15W	80+	4000K	1600Lm*

#### **Dimensions:**



\*E & O.E (Errors And Omissions Excepted)

\*Due to the rapid development in LED technology the performance values, power consumption and lumen output levels stated above are subject to change without prior notice.

\*All lumen outputs stated above are based a nominal output that included a 10% light loss, this can vary depending on the optic used.

# Contact

#### **Cape Town**

1B Hansen Close, Richmond Park, Cape Town T. +27 21 555 0570

### Durban

Unit L, Nandi Park, 34 Brickworks Way Briardene T. +27 31 001 2964

## Namibia – Windhoek

Unit 2, Tesoro Building, 31 TV More Street Windhoek T. +264 61 40 0339

#### **Johann esburg**

17 Galaxy Road, Unit 5A Galaxy Park, Linbro Park T. +27 11 262 5179

## Port Elizabeth

216 Main Road, Walmer Port Elizabeth T. +27 41 451 4359

> enning to be a loss provide service Property of the above of the Constant of the above of the State of the constitution of the State of the constitution of the State of the constitution of the