Specifications Release Date: October 2021

Geography: North American | Series C



JADE2.0 **Technical Specifications**

General Description

Manufacturer: Surgically Clean Air Inc. Model

Name: JADE2.0

Model Number: SCA5100C

Colours Available: Powder coated metal

Housing: White or Matte Black

Dimensions: D 31.6cm x H 89.5cm D 12.4 inches x H 35.2 inches

Weight: 14.5kg (31.9 pounds)

Features

- Airflow up to 448 CFM
- Handsfree touchless control
- Lockable control panel to prevent setting changes
- Energy-optimized for operation through special design for high efficiency and with favourable acoustic behaviour
- Single point power connection
- Ready for operation with minimal setup
- Wall mountable accessory available

Electrical Data

Rated voltage: 1~120V, 60Hz, 1A

Power Cord: SJT 3X16AWG, 105°C, VW-1, Length 2.5m

Power Consumption @120V Input			
Speed	Current (Amp)	Wattage (W)	
Low	0.16	19.2	
Medium	0.2	24.0	
High	0.33	39.6	
Turbo	0.53	63.6	

Warranty

Surgically Clean Air will either repair or replace any defective or malfunctioning unit at no cost to the client for a 1-year period.

Filtration & Containment Testing

Minimum Inert Material Capture (Fractional Collection

EN1822 Standard Minimum 98.69% Efficiency at 0.052µm @300cfm



- Ultrafine Aerosol Particulate Filter: HEPA-RX
- Activated Carbon: Broad spectrum adsorption Coconut Shell **Activated Carbon Filter**
- Germicidal UV-C+: Non-Ozone Producing 254 nm Doped Quartz Glass Germicidal UV-C
- Hydroxyl Radical Reactivity Chamber: Photocatalytic TiO2 (Titanium Dioxide) mixed phase anatase and rutile
- Revitalizing Negative ION Chamber: 3,000,000 ions/cm³ Negative Ion Generator

Performance Data

Airflow Cubic Feet Per Minute (CFM)		
Low	135	
Medium	223	
High	330	
Turbo	448	

Airflow Cubic Feet Per Hour (CFH)		
Low	8,100	
Medium	13,380	
High	19,800	
Turbo	26,880	

Sound Level		
Low	<37.3 dB(A)	
Medium	45 dB(A)	
High	52 dB(A)	
Turbo	58 dB(A)	



Product Safety Data

UL/CSA Recognized ETL Product Safety Tested & Certified Federal ARB Ozone Emissions Tested & Certified: Maximum 0.02 ppm ozone as per UL 867 - ozone chamber testing and peak ozone test for electronic devices.

Minimum Biological Capture Testing Requirements (Fractional Collection Efficiency)

- (Virus) MS-2 phage (ATCC 15597-B1) ->99.9% efficiency @300 cfm
- (Bacteria) Staph Aureus (ATCC 6538) >99.9% efficiency @300cfm
- (Fungus) Aspergillus Niger (ATCC 1004) >99.9% efficiency @300cfm

















