

SECTION: _____

 PART: _____



PRODUCT SUBMITTAL DATA

RollMark™ V FP Fire Protection Self-Stick Rollform Pipe Marker



DESCRIPTION: Self-adhesive rolls of pre-printed stock and custom pipe markers. With acrylic pressure sensitive adhesive backing sturdy 4 mil vinyl.

USE: Use to identify piping systems. Designed for all Fire Sprinkler pipe marking jobs.

COMPLIANCE: Complies with ASME (ANSI) A13.1-2020 Scheme for the Identification of Piping Systems for color, color field width & letter size.

Craftmark's RollMark™ V FP is ideal for all pipe marking jobs. Easy to use RollMark™ V FP comes with pre-slit arrows so they can be used to indicate flow in either direction. RollMark™ V comes with 50 legends and 50 arrows per roll. Available in 3 sizes to fit most pipe jobs up to 6" diameter.

FEATURES

- Meets ASME(ANSI) A13.1-2020 Standard.
- Ultra-durable self-stick vinyl for indoor/outdoor use.
- Available in 3 sizes.
- Full 50 legends / 50 arrows per roll.
- Custom available.
- Meets ASME (ANSI) A13.1-2020

•STANDARD COLORS

Red Background with White Text

•ROLLMARK V Application Guide

Style RMSM

Small 1" x 8" - 3/4" Letters



Style RMLG

Large 2" x 12" - 1 1/4" Letters



Style RMXLG

X Large 4" x 24" - 3" Letters



DATE: ___ / ___ / ___

JOB: _____

CONTRACTOR: _____

RollMark™ V FP SELF-STICK ROLLFORM PIPE MARKER (Continued)

ADHESIVE: Permanent, aggressive acrylic pressure sensitive adhesive. Sticks to most pipe and pipe covering materials.

SURFACE PREPARATION: Surface should be dry, oil free, dirt free and above the minimum application temperature.

SERVICE TEMPERATURE: -40°F to 200°F (-40°C to 93°C)

APPLICATION TEMPERATURE: Minimum application temperature of 50°F (10°C)

AVERAGE OUTDOOR DURABILITY: 5 years outdoor - mid continental U.S.

CHEMICAL RESISTANCE: VERY GOOD

MOISTURE RESISTANCE: EXCELLENT MOISTURE RESISTANCE

ABRASION RESISTANCE: VERY GOOD ABRASION RESISTANCE

GLOSS: 40 Gardner units (20° test)

STORAGE STABILITY: 2 years typical at 70°F (21°C) at 50% relative humidity.

DATE: ___ / ___ / ___

JOB: _____

CONTRACTOR: _____