
SPLIT-CORE CURRENT TRANSFORMER JS36S-XXX-333mV series











APPLICATIONS

- Energy sub meter
- Power meters
- Power quality monitoring
- HVAC&Pumps, etc
- Distributed measurement system

BENEFITS

- · Small-size, light-weight
- Simple Installation
- Over-Voltage protection circuit is installed.

JS36S-600/333mV 600A : 333mV Lot no:150310 IEC60044-1 class0.5S, 0.033VA F=50/60Hz Umax=720V Ui=3kV **S2** CE A CAN'US B JEDHISH QUALIT

FEATURES

- PC spring, output-terminal, secure locking hinge, one-touch structure make easy to install to the existent equipments such as a power distribution boards.
- Isolated plastic case recognized according to UL94-V0
- UL / EN 61010 1 certified


NOTICE


- Core contact surface is waterproofed, however if it gets rusty, you could reuse after removing rusts with spraying WD-40 or CRC5-56 on the rusted side.
- Do not use any other chemicals except WD-40 or CRC5-56 on housing or any other parts.
- Customizing output lead wire


HOW TO USE 1













SPECIFICATION

(F=50/60Hz)

Accuracy	Class 0.5S / 1.0		
Output Terminals	2 X M3-Screw, with Terminals cover		
System Voltage	720V(0.72kV)		
Overload withstand	1.2 times rated current continuously		
Compliant with	IEC/EN61869-2 & IEC61010-1		
Operating Temperature Range	-20°C to 55°C		
Relative Humidity	0-85% non-condensing		
Test Voltage	3kV for 1minute		
Frequency Range	50/60Hz		
Protection Level	3.0V0-P		
Insulation Category	CAT II or CAT III 600VAC		



CURRENT TRANSFORMER RATIOS


eg JS36S-000/333mV Model JS36S Primary Current Select code from ratio table Secondary Voltage 333mV 3 3 3 mV


Current Transformer Ratios


Primary Current (A)	Metering Burden(VA)			
	cl. 0.2S	cl. 0.5S	cl. 1	Code
	cl. 0.3	cl. 0.6	cl. 1.2	
300		0.05		300
400		0.05		400
500		0.05		500
600		0.05		600
333mV Secondary				

Accuracy conforms to IEC61869-2 & IEEE/ANSI C57.13 meets the measuring range from 1 to 120 % of In

DIMENSIONS







🔼 CAUTION: DANGER 🗘

HAZARD OF ELECTRIC SHOCK, EXPLOSION, OR ARC FLASH

• In order to guarantee safe operation of the transformer, please read and understand the instructions thoroughly.

For your reference, see NFPA 70E in the USA, or applicable local codes.

- This equipment must only be installed and put into operation by qualified electrical personnel or appropriately trained individual.
- Before servicing the CTs, turn off all sources of power and
- use a properly rated voltage sensing device to check if the power is off.
- Current transformer secondary must be shorted or connected to a burden all times.
- The transformer (split core type) must not be operated when it is not fully closed or the installation is not completed.
- Rearrange all covers and protective devices before powering the equipment.

NOTICE

- This product is not intentionally made for safety applications.
- Make sure not to install this transformer in hazardous or classified areas.
- The installer is responsible for conformance to all applicable codes.
 Ignoring the warnings can lead to serious injury and/or cause damages.
- A qualifined person is the one who is skilled and has knowledge about the construction and operation of this electrical equipment, and has received safety training to recognize and avoid the hazards involved. (NEC2011 Article 100)
- If this product is used in a way not specified by the manufacturer, the protection offered by the product may be impaired. No responsibility is taken by J&D Electronics for any consequences arising by not following this material properly

