

VOC Content Test Certificate

Friday October 19th, 2007

Supplier: Nexus Adhesives Pty Ltd

42 Healey Road

Dandenong Victoria 3175

Sample Description: Nexus 840 Pressure Sensitive Adhesive

Date Tested: October 2007

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design IEQ-13 Green Star Office Interiors IEQ-11	Nexus 840
Carpet Adhesive 50 grams per Litre	10 grams per Litre



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0710-09