

# VOC Content Test Certificate

Friday April 30<sup>th</sup>, 2010

Manufacturer: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road Seven Hills NSW 2147)

Sample Description: Ardex A46 rapid hardening and rapid drying internal slump free mortar for external repairs

Date Tested: April 2010

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>	<b>Ardex A46</b>
<b>Green Building Council of Australia</b> <b>Green Star Office Design V2 IEQ-13</b> <b>Green Star Office Interiors V1.1 IEQ-11</b>	
Architectural Sealant 250 grams per Litre as VOC content material	<b>5 grams per Litre as VOC content per coating</b>
<b>Specification</b>	<b>Ardex A46</b>
<b>Green Building Council of Australia</b> <b>Green Star Office Design V3 IEQ-13</b>	
Architectural Sealant 250 grams per Litre as VOC content material	<b>5 grams per Litre as VOC content per coating</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

F1004-34