

# VOC Content Test Certificate

Thursday October 6<sup>th</sup>, 2011

Manufacturer: Ardex Australia (Unit 7, 20 Powers Rd, Seven Hills NSW 2147)

Sample Description: ARDEX K 301

Date Tested: October 2011 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

|   |  |
|---|--|
| <b>Specification</b><br><br><b>Green Building Council of Australia</b><br><b>Green Star Office Design V3 IEQ-13</b> | <b>ARDEX K 301</b>                                   |
| One and two pack performance coatings for floors<br><br>140 grams per Liter as VOC content per material             | <b>6 grams per Liter as VOC content per material</b> |



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Anne Saletti  
BNanotech/BSc(Hons)  
Consultant

CV111002