

VOC Content Test Certificate

Thursday, 13th November 2014

Supplier: Ardex Australia (7/20 Powers Road, Seven Hills, NSW 2147)

Sample Description: Ardex RA 56

Date Tested: November 2014 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

Specification	
Green Building Council of Australia Green Star Office Design V3 IEQ-13	Ardex RA 56
Multipurpose construction adhesive* 70 grams per Litre as VOC content per material	17 grams per Litre as VOC content per material

*Sealants used to enhance the fire and water-proofing properties are included



Dr. Vyt Garnys
PhD, BSc(Hons) AImm, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV141116