

VOC Content Test Certificate

Thursday October 23rd, 2008

Manufacturer: Ardex Australia Pty Ltd
 Unit 7, 20 Powers Road
 Seven Hills NSW 2147

Sample Description: Ardex ArditeX NA (sub floor leveling and smoothing compound)

Date Tested: October 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Ardex ArditeX NA
Architectural sealant 250 grams per Litre as VOC content coating	64 grams per Litre as VOC content per coating
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Ardex ArditeX NA
Architectural sealant 250 grams per Litre as VOC content coating	64 grams per Litre as VOC content per coating



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

F0810-19