

TEST CERTIFICATE

Issued to: EAE Elektrik Asansör Endustrisi
Insaat San. ve Tic. A.S.
Makine ihtisas Organiza Sanayi Bolgesi 6. Cad. No:6
41455 Dilovasi / Kocaeli
Turkey

For the product: Low-voltage busbar trunking system

Trade name: EAE

Type/Model: KDA 250 A

Ratings: I_{nc} 250 A, U_e 1000 V, U_i 1000 V, U_{imp} 12 kV, I_{cw} 10 kA – 1 s
For more details see annex

Manufactured by: EAE Elektrik Asansör Endustrisi
Insaat San. ve Tic. A.S.
Makine ihtisas Organiza Sanayi Bolgesi 6. Cad. No:6
41455 Dilovasi / Kocaeli
Turkey

Subject: Design verification

Requirements: IEC 61439-6: 2012
Clauses: 10.2, 10.3, 10.4, 10.5, 10.9, 10.10, 10.11 and Annex BB, CC, and DD

Remarks: -

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in report no. 2234430.01-INC, dated 4 November 2019.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 4 November 2019

Number: 2234430.100

DEKRA Certification B.V.



F.S. Strikwerda
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed