



BOĞAZIÇI UNIVERSITY

KANDILLI OBSERVATORY AND
EARTHQUAKE RESEARCH INSTITUTE



EARTHQUAKE ENGINEERING DEPARTMENT

SEISMIC TEST CERTIFICATE

No : 4

Issued to :EAE ELEKTRİK ASANSÖR END. INSAAT
ve TİC. A.S.
Akçaburgaz Mahallesi, 119. Sokak, No:8
34510 Esenyurt – İstanbul
Turkey

Trade Name :EAE

Type/Model :KO - Cu 6x75

Manufactured by :EAE ELEKTRİK ASANSÖR END. INSAAT
ve TİC. A.S.
Akçaburgaz Mahallesi, 119. Sokak, No:8
34510 Esenyurt – İstanbul
Turkey

Position :Horizontal

Modules : Feeder, Standard, Top Off Box

Hangers : UT

Axis : x and y

Subject : Seismic Qualification Test For Busbar

Requirements :Sine-bite Test Based on the IEC 60068-3-3 according to Worst Case Zone 4
Seismic Compliance Based on the IEEE-693 and IBC 2006

Final Test Voltage :3500 V

Date of Approval : October, 2009
Name : Prof.Dr. Erdal Safak