

# Envisivent Air Flow Data



## Cold Air Returns

				Core Velocity [FPM]	300	400	500	600	700	800	1000	1200	1400
Product Identifier	Opening Width [in]	Opening Height [in]	Core Area [ft <sup>2</sup> ]	Core Velocity Pressure [“wc]	0.006	0.010	0.016	0.022	0.030	0.040	0.062	0.090	0.122
REM Air Return 14 x 8	12	8.75	0.729	Flow [CFM]	153	204	255	306	357	408	510	612	714
				Static Pressure [“wc]	0.027	0.048	0.076	0.109	0.148	0.194	0.303	0.436	0.594

tested by:  Airflow Sciences Corporation

### Notes:

1. The test procedures are based on ASHRAE 70.
2. Core Velocity – The average airstream velocity at the face of the grille, measured in feet per minute.
3. Core Velocity Pressure – The dynamic pressure of the airstream at the grille face. This pressure is relative to the core velocity and reported in inches of water (“wc)
4. Flow Rate – The volumetric rate of airflow through the grille, measured in cubic feet per minute (CFM)
5. Static Pressure – The air pressure difference across the grille at a given flow rate or velocity, measured in inches of water (“wc).
6. Throw – The distance away from a supply grille (i.e. perpendicular to the grille face) where the airstream velocity has slowed to a particular envelope velocity.
7. PER = PERMANENT/REM = REMOVABLE.