Report Template - Revision 1. April 2014 - Authorised by K. Ali Page 1 of 1



Boral Construction Materials Materials Technical Services

Unit 4, 3-5 Gibbon Road Baulkham Hills NSW 2153 Australia PO Box 400, Winston Hills NSW 2153

T: +61 (02) 9624 9900 F: +61 (02) 9624 9999

www.boral.com.au

FILE No: 482/15

REQUEST No: 62478

TEST REPORT

CLIENT: PERMA PRODUCTS

PROJECT: Quality Control

SAMPLE DESCRIPTION: Croc Grip Commercial High Grit Anti Slip Tape

DATE RECEIVED: 28.5.15

DATE OF TEST: 30.5.15

ENVIRONMENTAL CONDITIONS: Air Condition Room

TYPE OF RUBBER USED: 4S

TYPE OF CLEANING: Water only

NAME OF TESTING OFFICER: W. Komsta

TEST CONDUCTED: In Laboratory

TYPE OF TEST: Unfixed Surface

AIR TEMPERATURE AT TIME OF TEST: 23°C

TEST PROCEDURE: AS/ 4586:2013 Appendix A – Wet Pendulum Test Method For New Pedestrian Surface Materials

Laboratory Sample No:

166495

| Laboratory Campio 110. | | 100-100 | | |
|---|----------------------------------|---------|----|--|
| AS/ 4586, App. A | Test Wet Pendulum Test | RESULT | | |
| | | | | |
| | The Mean British Pendulum Number | | | |
| | For Each Test Specimen: | 1. | 72 | |
| | • | 2. | 72 | |
| | | 3. | 71 | |
| | | 2. | 72 | |
| | | 2. | 72 | |
| | The Mean British Pendulum Number | | | |
| | For the Sample: | | 72 | |
| Classification achieved in accordance with AS/ 4586, Table 2. | | | P5 | |
| | | | | |

Sample submitted by client.

L. Back, File

Date



Approved Signatory_____

2.6.15

Phr.

W. KOMSTA

Serial No.

136943

NATA Accredited Laboratory

Accredited for compliance with ISO/IEC 17025

Number: 547