



**Boral Construction Materials  
Materials Technical Services**

Unit 4, 3-5 Gibbon Road  
Baulkham Hills NSW 2153 Australia  
PO Box 400, Winston Hills NSW 2153

T: +61 (02) 9624 9900  
F: +61 (02) 9624 9999

www.boral.com.au

**TEST REPORT**

CLIENT: PERMA PRODUCTS

PROJECT: Testing of CrocGrip Commercial High Grit Anti Slip Tape for Wet Slip Resistance.

SAMPLE DESCRIPTION: CrocGrip Commercial High Grit Anti Slip Tape

FILE No: 912/20

CLIENT SAMPLE NO: PET 36 Grit, 8805-36B(296)

REQUEST No: 91665

DATE RECEIVED: 9.10.20

DATE OF TEST: 12.10.20

ENVIRONMENTAL CONDITIONS: STD Lab Conditions / Air Conditioned Room

TYPE OF RUBBER USED: TRL (55)

TYPE OF CLEANING: Water only

NAME OF TESTING OFFICER: A.Liu

TEST CONDUCTED: In Laboratory

TYPE OF TEST: Unfixed Surface

AIR TEMPERATURE AT TIME OF TEST: 23°C


**TEST PROCEDURE: AS/ 4586:2013 Appendix A – Wet Pendulum Test Method  
For New Pedestrian Surface Materials**

Laboratory Sample No: 245554

TEST METHOD	TEST	RESULT
AS/ 4586, App. A	Wet Pendulum Test	
	The Mean British Pendulum Number For Each Test Location:	1. 91 2. 91 3. 88 4. 89 5. 91
	The Mean British Pendulum Number For the Sample:	90
Classification achieved in accordance with AS/ 4586, Table 2.	Class	P5

Sample submitted by client  
E. Offord, File

Alex Liu

Approved Signatory   
Date 12.10.20 Serial No. AGG91665.AL.1

