




CHEMICAL SEGREGATION CHART

CLASS	2	3	4		5	6	8			
										
	Green	Grey	Red	Red	Red	Red	Red	Yellow	Grey	Grey
	Grey	Green	Grey	Blue	Red	Blue	Blue	Red	Blue	Grey
	Red	Grey	Green	Grey	Red	Red	Red	Yellow	Grey	Grey
	Red	Blue	Grey	Green	Grey	Red	Red	Red	Grey	Blue
	Red	Red	Red	Grey	Green	Grey	Red	Yellow	Grey	Grey
	Red	Blue	Red	Red	Grey	Green	Grey	Red	Blue	Blue
	Red	Blue	Red	Red	Red	Grey	Blue	Red	Grey	Grey
	Yellow	Red	Yellow	Red	Yellow	Red	Red	Green	Grey	Grey
	Grey	Blue	Grey	Grey	Grey	Blue	Grey	Grey	Green	Blue
	Grey	Grey	Grey	Blue	Grey	Blue	Grey	Grey	Blue	Blue



Chemicals in the same DG class are usually compatible. However chemicals may have more than one hazard and you should still check the SDS.



REFER TO SDS: Separation of these chemicals may be necessary. Consult the SDS for further guidance.



These chemicals may react dangerously if stored together therefore dedicated stores or cabinets are recommended. Adequate separation from other buildings and boundaries is required.



Storing these classes together will significantly increase the likelihood or severity of an incident. They should be kept at least five metres apart and in separate storage areas. Refer to SDS for further guidance.



These chemicals may react dangerously if stored together and should be kept at least three metres apart. Refer to SDS or supplier.

NOTES:

- The SDS or supplier of goods should be consulted in all cases.
- Combustible liquids shall be segregated in the same manner as Class 3 flammable liquids.
- Class 9 dangerous goods shall be segregated in accordance with the SDS.
- If dangerous goods have a sub-risk of another Class, the segregation requirements of the sub-risk need to be considered and the most stringent requirements applied.