# Technical Data Sheet

## Aerosol can storage cage: 132 to 180 can capacity*

### APPLICATION

For the safe and secure storage of aerosol cans.

### FEATURES

- Heavy duty zinc anneal steel construction
- Durable UV-stabilised powder-coated yellow finish
- High open-area perforated side panels for natural ventilation in accordance with Australian Standards
- Solid steel roof and base
- Three fixed shelves (including base)
- Pre-drilled mounting feet (bolt down plates)
- Lockable door fitted with magnetic latch and padlock lug (padlock not included)
- Manufactured in Australia to comply with Australian Standards
- Safety and warning signage in accordance with Australian Standards

*Lower capacity based on loose storage of 65mm ø x 245mm high aerosol cans.
 Maximum shelf capacity: up to 60 cans per shelf.

### SPECIFICATIONS

| | |
|---|---|
| Product name | Aerosol can storage cabinet |
| Code | SCAR132 |
| Maximum storage capacity | 180 aerosol cans (65mm ø x 245mm high) |
| Construction material | Zinc anneal steel |
| Surface finish | UV-stabilised polyester powder |
| Paint colour | Yellow |
| Doors | 1 |
| Shelves (including base) | 3 |
| Bolt down plates | 4x pre-drilled holes - 8mm ø |
| Shipping weight | 38kg |

### DIMENSIONS (W x D x H)

| | |
|---|---|
| External dimensions | 665mm x 465mm x 1050mm |
| Internal dimensions | 585mm x 400mm x 1020mm |

### MANUFACTURED TO MEET THE REQUIREMENTS OF

| | |
|---|---|
| AS/NZS3833-2007 | The storage and handling of mixed classes of dangerous goods, in packages and intermediate bulk containers |
| AS1319-1994 | Safety signs for the occupational environment |
| ADG CODE 7.5 | Australian Dangerous Goods Code 2017 Edition 7.5 |
| AS4506-2005 | Metal finishing - Thermoset powder coatings |

### Class 2: Flammable Gas

Flammable gases are gases which at 20°C and a standard pressure of 101.3 kPa:
(i) are ignitable when in a mixture of 13 per cent or less by volume with air; or
(ii) have a flammable range with air of at least 12 percentage points regardless of the lower flammable limit. Flammability should be determined by tests or by calculation in accordance with methods adopted by ISO (see ISO 10156:2010).

Referenced from the Australian Dangerous Goods Code, 2017, Edition 7.5