

# Flammable liquids safety cabinet - 30L storage capacity

### APPLICATION

For the safe and secure indoor storage of Class 3 flammable liquids and combustible liquids.

#### FEATURES

- Double wall construction with 40mm thermal barrier
- Vent ports with integral flash arrestors fitted on each side
- Single self-closing door with stainless steel, three point bullet self-latching system
- Adjustable hydraulic door closure
- Flush mount handle and key lock
- Continuous piano hinge on door delivers smooth closure
- One adjustable shelf plus fixed base shelf
- Internal spill containment bund with suspended perforated floor
- Durable UV stabilised thermosetting polyester powder coat finish
- Grounding connector enables earthing if required
- Adjustable screw-in feet for optional elevation
- Safety and warning signage applied in accordance with Australian Standards.

### **SPECIFICATIONS**

Product name	Flammable liquids safety cabinet
Code	SCIRF30
Maximum storage capacity	30 litres
Construction material	Steel
External surface finish	UV-stabilised polyester powder
Paint colour	Yellow
Doors	1
Shelves (including base)	2
Shelf positions	3
Shipping weight	55kg

### MANUFACTURED TO MEET THE REQUIREMENTS OF

AS1940-2017	The storage and handling of flammable and combustible liquids	
AS1319-1994	Safety signs for the occupational environment	
ADG CODE 7.5	Australian Dangerous Goods Code 2017 Edition 7.5	
AS4506-2005	Metal finishing - Thermoset powder coatings	

DANGER	
NO SMOKING	ð
NO IGNITION SOURCES WITHIN 3M	
MAXIMUM CAPACITY 30 LITRES	

DIMENSIONS (W x D x H)		
External dimensions	600mm x 475mm x 800mm	
Internal dimensions	500mm x 375mm x 550mm	
Shelf dimensions	998mm x 360mm x 27mm	



## **Class 3: Flammable Liquids**

Flammable liquids are liquids, or mixtures of liquids, or liquids containing solids in solution or suspension (for example, paints, varnishes, lacquers, etc., but not including substances otherwise classified on account of their dangerous characteristics) which give off a flammable vapour at temperatures of not more than 60 °C, closed-cup test, or not more than 65.6 °C, open-cup test, normally referred to as the flash point.

Referenced from the Australian Dangerous Goods Code, 2017, Edition 7.5