

TEST REPORT FOR:
Availcare 'Glance' Grab rail
(Tested to 1100 N, 112 kgf)

TEST DOCUMENTS:
AS 1428.1:2009 Design for access and mobility
Clause 17 - Grab-rails

LABORATORY REFERENCE
492617

15th August 2016



TEST REPORT

This report may NOT be reproduced in part without written laboratory authorisation. The NovitaTech Test Laboratory has no control over the selection of test samples. Any extension of the findings of this report to cover production items must be based on the production being truly represented by the sample(s).

Job no: 492617

PRODUCT

Name & Model No.

Availcare 'Glance' Grab rail

Serial no of test sample

Not marked

Safe Working Load

Tested to 1100 N / 112 kgf

Documents used in testing

AS 1428.1:2009, Clause 17 Grab-rails

SUPPLIER

Name

Availcare Pty Ltd

Address

161 Hamiltons Road, Warragul South, Vic. 3821

Telephone

0400 095 077

Contact Person:

Dave Sayers

MANUFACTURER

Name

Availcare Pty Ltd

Address

161 Hamiltons Road, Warragul South, Vic. 3821



TESTING AUTHORITY

NOVITA CHILDREN'S SERVICES, NOVITATECH TEST LABORATORY

Address

171 Days Road, Regency Park, South Australia, 5010

Telephone

(08) 8243 8261

Fax

(08) 8243 8208

Testing Supervisor

Wayne Wurfel

Senior Test Technician

Authorised signatory

Checked

Andrew Rose

Team Leader

Dates of testing period

August 2016

Date of issue of this report

15th August 2016


AS 1428.1 – 2009 Design for access and mobility, Clause 17 – Grab-rails

Test/Requirement	Result	Specification according to AS1428.1	Reference in clause of AS1428.1
Outside diameter	PASS (32 mm)	Min 30 mm / Max 40 mm	12 (a)
Exposed edges and corners	PASS	Not less than 5 mm	12 (b)
Withstand a load of 1100N at any position and in any direction	PASS	Shall be no visible deformation, loosening or rotation	6.2(c)
Clearance between a grab-rail and any obstruction	PASS (52 mm)	Clearance to wall: not less than 50 mm, not more than 60 mm.	6.2(d)
Obstruction to the passage of the hand	PASS	270°	6.2(e)

Remarks:

The test sample was attached to a horizontal timber rail using 3 supplied fasteners at each mounting bracket. Test requirement for static strength – Must be able to withstand a load of 1100 N in any direction. The test load was applied to rail in the ‘worst case’ position, where maximum stress and deformation of the grab rail could be applied with each direction of force.

Consideration must be given to the strength of the substrate that the rail is attached to and the fasteners used for attachment when assessing the true load performance of the grab rail in actual mounted situations. The manufacturers recommended mounting instructions must be followed when installing this product.



WW. End of remarks-----

The sample submitted for this test satisfies the relevant requirements of AS1428.1 (Clause 17) for grab-rails (except the methods indicated in this report as “not tested” and/or tested with deviations).

PASS

Traceable Equipment used for Measurements in this report					
Gauge Number	Gauge Type		Gauge Number	Gauge Type	
TLE004	Standard finger Probe	<input type="checkbox"/>	TLE141	Tape Measure, 5 Metre	<input checked="" type="checkbox"/>
TLE009	Cold Climate Chamber	<input type="checkbox"/>	TLE144	Stop Watch	<input type="checkbox"/>
TLE010	Test Rig (Static Load Drop)	<input checked="" type="checkbox"/>	TLE148	Protractor, Vernier	<input type="checkbox"/>
TLE011	2 Drum Durability Rig	<input type="checkbox"/>	TLE151	Accelerometer	<input type="checkbox"/>
TLE012	Stability Ramp - Static	<input type="checkbox"/>	TLE167	Test Masses, 25kg	<input type="checkbox"/>
TLE016	Square, Steel - Large	<input type="checkbox"/>	TLE175	2 Drum Durability rig	<input type="checkbox"/>
TLE018	Rule, Steel – 1,000 mm	<input type="checkbox"/>	TLE176	Test Dummy	<input type="checkbox"/>
TLE019	Reference Load Gauge	<input type="checkbox"/>	TLE179	Test Rig Prosthetics, Foot	<input type="checkbox"/>
TLE024	Stability Ramp, Dynamic	<input type="checkbox"/>	TLE182	Multimeter	<input type="checkbox"/>
TLE028	Spring Balance 0-100g	<input type="checkbox"/>	TLE183	Impact Pendulum	<input type="checkbox"/>
TLE029	Spring Balance 0– 5kg	<input type="checkbox"/>	TLE184	Test Dummy	<input type="checkbox"/>
TLE030	Spring Balance 0-20kg	<input type="checkbox"/>	TLE185	Inclinometer	<input checked="" type="checkbox"/>
TLE032	Thermometer	<input type="checkbox"/>	TLE186	Inclinometer, small	<input type="checkbox"/>
TLE049	Torque Wrench	<input type="checkbox"/>	TLE196	Test Rig Prosthetics, Knee	<input type="checkbox"/>
TLE067	Tyre Pressure Gauge	<input type="checkbox"/>	TLE201	Load Cell	<input checked="" type="checkbox"/>
TLE068	Impact Mass, 25 kg Soccer	<input type="checkbox"/>	TLE203	Impactor	<input type="checkbox"/>
TLE077	Force Gauge, RLG	<input type="checkbox"/>	TLE204	Pendulum Impact Hammer	<input type="checkbox"/>
TLE084	Rule, Steel – 300mm	<input type="checkbox"/>	TLE205	Tape Measure, 8 Metre	<input type="checkbox"/>
TLE087	Test Obstacles	<input type="checkbox"/>	TLE210	Test Obstacle, Threshold	<input type="checkbox"/>
TLE105	Thermohygrograph	<input checked="" type="checkbox"/>	TLE211	Prosthetic Set up Gauge	<input type="checkbox"/>
TLE106	Scales, Digital	<input type="checkbox"/>	TLE212	Test Rig, Proof Test	<input type="checkbox"/>
TLE112	Vernier Caliper, 200mm	<input type="checkbox"/>	TLE216	Load Pad, Seat Base	<input type="checkbox"/>
TLE114	Spring Balance, 50kg	<input type="checkbox"/>	TLE218	Square, Steel - Small	<input type="checkbox"/>
TLE131	Test Dummy	<input type="checkbox"/>	TLE220	DC Wattmeter	<input type="checkbox"/>
TLE132	Test Dummy	<input type="checkbox"/>	TLE221	Temp/Humidity Meter	<input type="checkbox"/>
TLE133	Test Dummy	<input type="checkbox"/>	TLE225	Caliper, Digital 200mm	<input checked="" type="checkbox"/>

NOTES:

- 1 U₉₅ Uncertainty of measurements where not specified: linear ± 1 mm, angular $\pm 30'$, force, mass $\pm 1\%$, temperature $\pm 1^\circ\text{C}$, cycles ± 1 count. This means the true measurement is within the stated tolerances at least ninety five times in one hundred
- 2 All testing was carried out in a controlled environment laboratory using methods set out in the Standards documents, all deviations and additions to the Standards' methods are noted in remarks.
- 3 All instruments either carried valid calibration certificates throughout the test period or were checked against traceable Standards before and after use.
- 4 NovitaTech has no control over the selection of test samples. Any extension of the findings of this report to cover production items must be based on production being truly represented by the sample(s).
- 5 Any non-conformances are indicated in red.
- 6 Items marked NA – Not applicable to sample tested

_____ END OF REPORT _____

