

Technical Data & Certification



Contents

Certificate of approval ISO 9001.2008	3
Pull out Certificate R000410.01	5
Pull out test data R000231	11
Smoke Emission Test	18





CERTIFICATE OF APPROVAL

This is to certify that the "Linian Fire Clip" is manufactured in accordance with:

ISO 9001:2008.

The Quality Management System is applicable to:


Manufacture of presswork, Laser Cut Parts, U-bolts, Wire & Rod Forms, machined Components, Washers, Spring Clips and Welded Fabrications.

ISSUED BY:

IAN ARBUCKLE


TECHNICAL DIRECTOR





CONTROL INFORMATION			
Unique Identification Number R000410			
Creation Date	10 th October 2018		
Revision Number	01		
Controlled Copy	No		
Distribution	MASTER FILE, External release.		

Contents:



	Prepared by	Checked by	Approved by	
evolution		Rylling	Rylling	UKAS TISTING 7485
	Mr Barry Cowan	Mr Ryan Murphy	Mr Ryan Murphy	Evolution Fasteners (UK) Ltd
	Snr Lab Technician	Technical Manager	Technical Manager	

1.0 - Customer and Laboratory Details

Customer: Linian Supply Company Ltd.

34 Payne Street

Port Dundas Trading Estate

Glasgow G4 OLF

Contact: Mr. Ian Arbuckle (Managing Director)

Laboratory: Evolution Technical and Analytical Services

Units 2A & 2B Clyde Gateway Trade Park

Dalmarnock Road Rutherglen Glasgow G73 1AN

Contact: Mr. Barry Cowan (Senior Laboratory Technician)

2.0 - Job Details, Specifications and Scope

Order Number: 537

Report number: R000410

Description: Withdrawal force (pull out resistance) testing.

Test standard(s): BS 5080-1: 1993

"Structural fixings in concrete and masonry. Method of test for tensile loading."

3.0 - Sample Details and Sampling Plan

Sample Details: Client provided samples in finished form.


Sample Inspection: Visual inspection upon arrival

Sampling Plan: Not applicable.

Page **2** of **5**

Test Report No. R000410

Tests marked "Not UKAS accredited" in this report/ certificate are not included in the UKAS schedule of accreditation for our laboratory. Tests marked "SC" have been sub-contracted. Opinions and interpretations expressed herein are outside the scope of UKAS accreditation. This test report shall not be reproduced except in full, without written approval of the laboratory. Results in this report relate only to the items tested. This report is without prejudice, without recourse, non-assumptist, errors and omissions excepted, no assured value, no liability, all rights reserved.



4.0 - Test Procedure

Test Standard: BS 5080-1: 1993

Procedure: 1. Insert sample into pre-drilled hole of substrate


2. Insert substrate into Shimadzu AGS-X 10kN universal testing machine


3. Attach sample to grips

4. Start-up TrapeziumX software and choose program

5. Calibrate software

6. Begin testing and record results at test end.






5.0 Results

Part number	Test I.D.	Substrate	Embedment depth (mm)	Hole diameter (mm)	Result (N)	Average (N)	Standard deviation
	01			(11111)	237.76		(N)
		1					
	02				211.55		
	03				230.74		
Linian clip	04	C35 grade	Full	5.5	270.54	271.54	37.88
single	05	concrete	embedment		308.20		
	06				337.17		
	07		EVOL	UTIO	274.24		
	08		VE		285.19		
	09			1	296.15		
	10	65	1.1		263.81		
					101		

Part number	Test I.D.	Substrate	Embedment depth (mm)	Hole diameter (mm)	Result (N)	Average (N)	Standard deviation (N)
	01			Carl.	187.81		
	02	121	33 10		184.49		
	03		QUALITAS TE	MPTATIONIS	185.12		
Linian clip	04	C35 grade	Full	5.5	191.54	194.88	21.04
double	05	concrete	embedment		221.65		
	06				166.49		
	07		EI	AS /	208.85		
	08				235.07		
	09				192.36		
	10				175.42		



6.0 Revision history

Revision history (R.000410.01)		
Revision number	Changes made by	Details of change
01	BC	Original issue







Prepared by	Checked by	Approved by
Mr. B. Cowan	Mr. Ryan Murphy	Mr. Ryan Murphy
Snr. Lab. Technician	Associate Director	Associate Director



CONTROL INFORMATION		
Unique Identification Number R000231		
Creation Date	29 th January 2016	
Revision Number	01	
Controlled Copy	No	
Distribution	MASTER FILE, external release	

Contents	Page
1.0 – Customer and Laboratory Details	2
2.0 – Job Details, Specifications and Scope	2
3.0 – Sample Details and Sampling Plan	3
4.0 – Test Procedure	3
4.1 – Test Conditions 5.0 – Test Results	3
5.0 – Test Results	4-5
6.0 – Revision History	6
QUALITY TO THIS	
ETAS	



Prepared by	Checked by	Approved by
_	· · · · · · · · · · · · · · · · · · ·	
Mr. B. Cowan	Mr. Ryan Murphy	Mr. Ryan Murphy
Snr. Lab. Technician	Associate Director	Associate Director



1.0 - Customer and Laboratory Details

Customer: Linian Supply Company Ltd.

34 Payne Street

Port Dundas Trading Estate

Glasgow G4 OLF

Contact: Mr. Ian Arbuckle

Laboratory: Evolution Technical and Analytical Services

Units 2A & 2B Clyde Gateway Trade Park

Dalmarnock Road Rutherglen

Glasgow G73 1AN

Contact: Mr. Barry Cowan (Senior Laboratory Technician)

2.0 - Job Details, Specifications and Scope

Order Number: 37

Report number: R000231

Description: Withdrawal force (pull out resistance) testing.

Test standard(s): BS 5080-1: 1993

"Structural fixings in concrete and masonry. Method of test for tensile loading."

Note(s): Not UKAS accredited test



Prepared by	Checked by	Approved by
Mr. B. Cowan	Mr. Ryan Murphy	Mr. Ryan Murphy
Snr. Lab. Technician	Associate Director	Associate Director

UKAS UKAS TISSING 7485 Evolution Fasteners (UK) Ltd

3.0 - Sample Details and Sampling Plan

Sample Details: Client provided samples in finished form.

Sample Inspection: Not performed.

Sampling Plan: Not applicable.

4.0 - Test Procedure

Test Standard: BS 5080-1: 1993

Procedure: 1. Insert sample into pre-drilled hole of specified diameter in substrate

2. Insert substrate block into Shimadzu AGS-X 10kN universal testing machine

3. Attach sample to grips

4. Start up TrapeziumX software and choose program

5. Calibrate software

6. Begin testing and record results at test end.

4.1 - Test Conditions

Test speed: 1mm/min

Temperature: 17.2°C



Checked by	Approved by
Mr. Ryan Murphy	Mr. Ryan Murphy
Associate Director	Associate Director
	· · · · · · · · · · · · · · · · · · ·



5.0 - Test Results

		Table 1: Pu	ıll out from con	crete		
Product code/description	Test I.D. number	Substrate	Embedment depth (mm)	Hole diameter (mm)	Record result (N)	Mean load (N)
	01				184.525	
	02				301.097	
	03				211.470	
	04				178.857	
Linian clip	05	C35 grade	30.0	5.5	240.134	<u>215.432</u>
(single)	06	concrete			285.522	
	07	M			211.797	
	08				175.679	
	09			0	205.266	
	10				215.432	
	5	3	CE IS	Y/\	ń	

	Tal	ble 2: Pull out f	rom precon cor	ncrete block	4	
Product	Test I.D.	Substrate	Embedment	Hole	Record	Mean load
code/description	number		depth (mm)	diameter	result (N)	(N)
				(mm)		
	11	IALITA	S TEMPTATI		149.907	
	12	QUALITA	J ILI I IAII	ONIS	193.642	
	13				206.008	
	14				224.134	
Linian clip	15	Precon	30.0	5.5	166.613	<u>179.225</u>
(single)	16	concrete	TAC		176.619	
	17	block	IAS		209.363	
	18	(density			197.791	
	19	11N/mm²)			131.410	
	20				136.762	



Prepared by	Checked by	Approved by
Mr. B. Cowan	Mr. Ryan Murphy	Mr. Ryan Murphy
Snr. Lab. Technician	Associate Director	Associate Director



	•	Table 3։ Pull oւ	ıt from C16 grad	de timber		
Product	Test I.D.	Substrate	Embedment	Hole	Record	Mean load
code/description	number		depth (mm)	diameter	result (N)	(N)
				(mm)		
	21				438.731	
	22				375.471	
	23				379.509	
	24				386.615	
Linian clip	25	C16 grade	30.0	5.5	383.995	<u>391.347</u>
(single)	26	timber			304.729	
	27	->10	01117		429.885	
	28	EV			373.296	
	29	M			457.939	
	30),			383.302	



TEST REPORT No. R000231




Prepared by	Checked by	Approved by
Mr. B. Cowan	Mr. Ryan Murphy	Mr. Ryan Murphy
Snr. Lab. Technician	Associate Director	Associate Director

7485 Evolution Fasteners (UK) Ltd

6.0 - Revision History

	Revision history (R.000231)				
Revision number	Changes made by	Details of change			
01	BC	Original issue			
	EVIO UTI				
	L EVO = OA				
(2)					
		4151			
10,1					
	ALITAS TEMPTATION				
	QUALITAS TEMPTATIONIS	S			
	ETAC				
	LIAS				

[END OF DOCUMENT]



Our Ref. 4RS-SF-050864-K36755rev

Your Ref.

10th March 2006

Mr. Wes Arbuckle, The Linian Supply Company Limited, 34-38 Payne Street, Port Dundas Trading Estate, Glasgow, G4 0LF

Dear Mr. Arbuckle.



Unit 11, Ironbridge Close, Great Central Way London NW10 0UF

> Telephone: 020 8955 1700 Facsimile: 020 8830 1003 Email: enquiries@4-rail.com

Re. Toxicity Testing of One Coating Sample Applied to Cable Clips Supplied by The Linian Supply Company Limited

The toxic fume emission requirements detailed in London Underground Limited Standard Number 2-01001-002 Fire safety performance of materials, Section 5.2.3, deals with the chemical composition that is required for materials with respect to Toxic Fume Emission Requirements. This section states that for unrestricted use of a material, neither it nor its constituents shall have deliberately incorporated by selection, addition or modification any significant amounts of organically bound halogens, nitrogen sulphur or phosphorous.

Trace levels of such chemical groups are acceptable – the criterion for 'trace level' shall be that that the summation of the weight for weight percentage of the chemical group divided by the atomic weight for the group shall not exceed 0.015%.

Qualitative and quantitative analysis of the red coating system applied to the cable clip showed that it contained 1.07% nitrogen and 0.31% sulphur; which produced a summation value of 0.086 which is greater than the limit in the standard.

Information supplied by BRE confirms that the other fire performance requirements detailed within LUL Engineering Standard 2-01001-002 Fire safety performance of materials, have been met, indicating that the cable clips possess good fire safety performance.

Information supplied by the client indicates that the cable clips are intended to be used in stations and will spaced at 300mm intervals along the cable.

It is therefore 4-RAIL Services opinion that although the coating system does not fulfil the requirements for 'trace level', the good reaction to fire performance and small amount of coating material applied to each clip would mean that in the event of a fire, the applied coating would have an negligible contribution to any toxic fumes emitted.

However, it should be noted that final approval of a material can only be made by the regulating departments of the rail service operating company concerned.

I hope that this information is sufficient, but if you require any further information please let me know.

Yours sincerely,

Sara Finch

Materials Consultant

Sara Fincl

Enc.