

## **Environmental Remediation Equipment inc.**

T: 514.326.8852 F: 514.326.8961 sales@ereinc.com 8605, Champ d'Eau. Montréal, Qc. H1P 3B8



## Bright Dyes FLT Orange products

Bright Dyes FLT Orange products are specially formulated versions of Xanthene dye for convenient use in water tracing and leak detection studies. This fluorescent orange dye is certified by NSF International to ANSI/NSF Standard 60 for use in drinking water. It may be detected visually, by ultraviolet light and by appropriate fluoremetric equipment. Today it is most often used visually. Visually the dye appears orange to red-orange, depending on its concentration and under ultraviolet light as bright yellow. The dye is resistant to absorption on most suspended matter in fresh and salt water. However, compared to Bright Dyes FLT Yellow/Green products it is slightly more resistant to degradation by sunlight but less resistant than our FWT Red products. As always the suitability of these products for any specific application should be evaluated by a qualified hydrologist or other industry professional.

General Properties	Tablets	Liquids	Powders
Detectability of active ingredient <sup>1</sup>	Visual <100 ppb	Visual <100 ppb	Visual <100 ppb
Maximum absorbance wavelength <sup>2</sup>	515/535 nm	515/535 nm	515/535 nm
Appearance	Brick red convex	Reddish-Orange	Brick red fine
	1.6cm diameter	aqueous solution	powder
NSF (Max use level in potable water)	0.3 ppb	0.8 ppb	0.1 ppb
Weight	1.35 gms + 0.05		
Dissolution Time <sup>3</sup>	50% < 3 minutes		50% < 3 minutes
	95% < 6 minutes		95% < 6 minutes
Specific Gravity		1.05 + 0.05 @ 25° C	
Viscosity <sup>4</sup>		1.8 cps	
рН	7.5 + 0.5	8.0 + 0.5 @ 25° C	7.5 + 0.5

Coverage of Products	One Tablet	One Pint Liquid	One Pound Powder
Light Visual	350 gallons	40,000 gallons	604,000 gallons
Strong Visual	35 gallons	4,000 gallons	60,400 gallons

Caution: These products may cause irritation and/or staining if allowed to come in contact wit the skin. The use of gloves and goggles is recommended when handling this product, as with any other dye or chemical. To our best knowledge the information and recommendations contained herein are accurate and reliable. However, this information and our recommendations are furnished without warranty, representation, inducement, or license of any kind, including, but not limited to the implied warranties and fitness for a particular use or purpose. Customers are encouraged to conduct their own tests and to read the material safety data sheet carefully before using.





<sup>&</sup>lt;sup>1</sup> In deionized water in 100 ml flask. Actual detectability and coverage in the field will vary with specific water conditions.

<sup>&</sup>lt;sup>2</sup> No significant change in fluorescence between 6 and 11 pH.

<sup>&</sup>lt;sup>3</sup> (One tablet, 1 gram of powder), in flowing deionized water in a 10 gallon tank.

<sup>&</sup>lt;sup>4</sup>Measured on a Brookfield viscometer, Model LV, UL adapter, 60 rpm @ 25° C.