

TEST REPORT

Applicant: CURIE LIMITED
B3-1 G/F
SUPERLUCK INDL CTR PHASE 2
57 SHA TSUI RD
TSUEN WAN NT HK

Date: Apr 22, 2020
This is to supersede report no.
HKGT05112613 dated Apr 21,
2020

Attn: ALDRIN OR

Sample Description As Declared :

No. Of Sample : Several
Buyer's Name : -
Agent's Name : -
Manufacturer's Name : Curie Limited
Sample Description : Curie Ultrahigh-Efficiency Viral Filter超高效病毒濾材
Colour : White
Style No. : 1001
Order No. / PO No. : -
Product End Uses : -
Fibre Content : Nonwoven
Fabric/GMT Weight : 20g
Ref. : -

Date Received/Date Test Started : Apr 15, 2020

Applicant's Provided Care Instruction/Label :

-

TEST REPORT

Original Sample Photo:



For any queries on this report, you are welcome to contact our customer service representatives:

US3

Angie Yu (852) 98639123 or email to angie.yu@intertek.com

TEST REPORT

Tests Conducted (As Requested By The Applicant)

1 Evaluation of Viral Filtration Efficiency (VFE):

Summary: The VFE test is performed to determine the filtration efficiency of test articles by comparing the viral control counts upstream of the test article to the counts downstream. A suspension of bacteriophage ΦX174 was aerosolized using a nebulizer and delivered to the test article at a constant flow rate and fixed air pressure. The challenge delivery was maintained at 1.1 – 3.3 x 10³ plaque forming units (PFU) with a mean particle size (MPS) of 3.0 ± 0.3 μm. The aerosols droplets were drawn through a six-stage, viable particle, Andersen sampler for collection. The VFE test procedure was adapted from ASTM F2101.

All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Test side: Either

Test Area: ~40 cm²

VFE Flow Rate: 28.3 Liters per minute (L/min)

Conditioning Parameters: 85 ± 5% relative humidity (RH) and 21 ± 5 °C for a minimum of 4 hours

Positive Control Average: 1.6 x 10³ PFU

Negative Monitor Count: <1 PFU

MPS: 2.9 μm

TEST REPORT

Tests Conducted (As Requested By The Applicant)

Evaluation of Viral Filtration Efficiency (Cont'd)

Result:

Test Article Number	Percent VFE (%)
1	>99.9 ^a
2	>99.9 ^a
3	>99.9 ^a
4	>99.9 ^a
5	>99.9 ^a

^a There were no detected plaques on any of the Andersen sampler plates for this test article.

The filtration efficiency percentages were calculated using the following equation:

$$\%VFE = \frac{C - T}{C} \times 100$$

C= Positive control average

T= Plate count total recovered downstream of the test article

Note: The plate count total is available upon request

Remark: The test was conducted by competent subcontractor lab.