

## Bacterial Filtration Efficiency (BFE) and Differential Pressure (Delta P) Final Report


Test Article: 15040808, 15040809, 15040810, 15040811, 15040812  
Purchase Order: NA2410  
Laboratory Number: 823921  
Study Received Date: 27 May 2015  
Test Procedure(s): Standard Test Protocol (STP) Number: STP0004 Rev 11

**Summary:** The BFE test is performed to determine the filtration efficiency by comparing the upstream bacterial control counts to downstream test article counts. A suspension of *Staphylococcus aureus* was aerosolized using a nebulizer and delivered to the test article at a constant flow rate and challenge delivery. The challenge delivery is maintained at  $2,200 \pm 500$  colony forming units (CFU) with a mean particle size (MPS) at  $3.0 \mu\text{m} \pm 0.3 \mu\text{m}$ . The aerosol droplets were drawn through a six-stage, viable particle, Andersen sampler for collection. This procedure allows a reproducible bacterial challenge to be delivered to test materials. This test method complies with ASTM F2101-07 and EN 14683:2014, Annex B.


The Delta P test determines the breathability by measuring the differential air pressure on either side of the test article using a manometer, at a constant flow rate. The Delta P test was designed to comply with MIL-M-36954C, Section 4.4.1.2 and complies with EN 14683:2014, Annex C.

All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Test Side: Inside  
BFE Area Tested:  $\sim 45.6 \text{ cm}^2$   
BFE Flow Rate: 28.3 Liters per minute (L/min)  
Delta P Flow Rate: 8 Liters per minute (L/min)  
Conditioning Parameters:  $85 \pm 5\%$  relative humidity (RH) and  $21 \pm 5^\circ\text{C}$  for a minimum of 4 hours.  
Positive Control Average: 2,639 CFU  
Negative Monitor Count:  $<1$  CFU  
MPS:  $2.9 \mu\text{m}$   
Test Article Dimensions:  $\sim 105 \text{ mm} \times \sim 160 \text{ mm}$

  
Study Director

Janelle R. Bentz, M.S.

  
08 Jun 2015  
Study Completion Date

**Results:**

Test Article	Percent BFE (%)	Delta P (mm H <sub>2</sub> O/cm <sup>2</sup> )	Delta P (Pa/cm <sup>2</sup> )
15040808	>99.9 <sup>a</sup>	4.9	48.5
15040809	>99.9 <sup>a</sup>	4.8	47.4
15040810	>99.9 <sup>a</sup>	4.8	47.2
15040811	>99.9 <sup>a</sup>	4.8	47.0
15040812	>99.9 <sup>a</sup>	4.8	46.9

<sup>a</sup> There were no detected colonies on any of the Andersen sampler plates for this test article.

The filtration efficiency percentages were calculated using the following equation:

$$\% \text{ BFE} = \frac{C - T}{C} \times 100$$

C = Positive control average

T = Plate count total recovered downstream of the test article

Note: The plate count total is available upon request

FOR INFORMATION ONLY  
PROFIT ROYAL PHARMACEUTICAL LIMITED  
盈宗製藥有限公司