

Declaration of Conformity

In Accordance with ANSI/ISEA 125-2014



Alexander Andrew, Inc. 1306 S. Alameda St Compton, CA 90221

Declaration #

A0714008a

Declaration Date

7.23.14

Tested Item #

7395A

Rotating Flat Roof SRD Anchor

Additional Items Conforming Under this Declaration:

7395B

7395D

Alexander Andrew, Inc. declares that the product(s) listed above is in conformity with the requirements of the following performance standard(s):

OSHA 1926.502

Conformity Assessment Method in accordance with ANSI/ISEA 125-2014

Level 1

Level 2

Level 3

Level 1: FallTech Lab
Outside the Scope of
ISO/IEC Standard 17025:2005

Level 2: FallTech Lab
Within the Scope of
ISO/IEC Standard 17025:2005

Level 3: Independent 3rd Party Lab
accredited to
ISO/IEC Standard 17025:2005

Supporting
Documentation

20140723-5

Authorized Signature

Name

Dustin Hawkins

Title

VP Business Development

Date


3.20.15

FallTech Test Report							
Test Report Number	20140723-5	Date	7/23/2014	Rev	D	Rev Date	11/11/2014
Report Prepared For	FallTech						
Initiated By	Dan Redden	Test Specification	OSHA 1926.502 1926.502(d)(16)(v)				
Base Part #	7395A	Description	Rotating SRD Anchor, Flat Roof				
Proposed Part #	N/A	Build By Whom	Production	BOM	No		
Test Request #	N/A	Date Received		Date Complete	5/7/2014		
Test Operator	Dan Redden	Test Operator	N/A				

Material/Sample Identification	
Sample ID	Description
N/A	Rotating SRD Anchor, Flat Roof (Pivotal Bolt)
N/A	Rotating SRD Anchor, Flat Roof (Backplate Support)

Test Summary				
Test Specification	Test Criteria		Test Result	Pass/Fail
OSHA 1926.502 1926.502(d)(16)(v)	Static Strength, Vertical	Withstand 3,600 Lbf Load (2X Potential Impact Energy of 1800 Lbf) for 1 Minute	3,936 Lbf	Pass
OSHA 1926.502 1926.502(d)(16)(v)	Static Strength, Horizontal	Withstand 3,600 Lbf Load (2X Potential Impact Energy of 1800 Lbf) for 1 Minute	4,039 Lbf	Pass

Conclusion
FallTech P/N 7395A Rotating SRD Anchor, Flat Roof meets the requirements of OSHA 1926.502.

Report Signatories and Approval			
Lab Quality Manager Soung Liew		Date	7/28/2014
Witnessed by	Not Applicable	Date	Not Applicable

Rev A	Change P/N from 870 BLU/873 ZNC to 7395A
Rev B	Correct mistake for the sample description
Rev C	Clarify the pull directions as pivotal and backplate support pull
Rev D	Created digital copy

This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2005. This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system (refer to the joint ISO-ILAC-IAF Communiqué dated January 2009).

