

VOC Content Test Certificate

Wednesday, 16th January 2019

Supplier: Pasco Construction Solutions Pty Ltd (13-15 Brighton Street, Richmond, VIC 3121).

Sample Description: Pasco Aquaproof 115UV

Date Tested: January 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

<p align="center">Specification</p> <p align="center">Green Building Council of Australia</p> <p align="center">Green Star Design & As Built V1.1 13.1.1</p> <p align="center">Green Star Interiors V1.1 12.1.1B</p>	<p align="center">Pasco Aquaproof 115UV</p>
<p>Acoustic sealants, architectural sealant, waterproofing membranes: 250 grams per Litre as VOC content per material</p>	<p align="center">240 gram per Litre as VOC content per material</p> <p align="center">PASS</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV190122