

# Certificate



## Prüfbescheinigung „Unabhängig Geprüft“ Certificate „Independently Tested“

Bescheinigungs-Nr. (Certificate No.): 20GZK1212-01

Das genannte Produkt entspricht den aufgeführten Prüfgrundlagen.  
(The mentioned product is in compliance with the mentioned test requirements.)

*Bescheinigungsinhaber (Certificate Holder)*  
HVAC Distributing LLC  
60 Remington Way  
Hickory, Kentucky 42051  
United States of America

*Markenname (Brand name)*  
MRCOOL

*Produkt (Product)*  
Universal Inverter Ducted Split System

*Typbezeichnung (Type)*  
Outdoor unit: MDUO18024036  
Indoor unit: MDUI18024

*Beschreibung (Description)*  
208V/230V~, 60Hz, R401A

*Prüfbericht-Nr. (Test Report No.)*  
191213082GZU:2020-01-07

*Geprüft nach (Tested according to)*  
Gebrauchstauglichkeit (Performance)  
Intertek test plan for Tickmark TP-EA4-Air\_Conditioner-MP

*Gültig bis (valid until)*  
2021-07-22  
*Erstellt am (Issued on)*  
2020-07-23



95074  
Intertek Deutschland GmbH  
Dipl.-Ing. Bernhard Miedtank

Dem Zertifikat liegen die Allgemeinen Geschäftsbedingungen der Intertek Deutschland GmbH zu Grunde. Bitte beachten Sie die umseitigen Hinweise.  
The General Business Conditions of Intertek Deutschland GmbH is an integral part of this certificate. Please also refer to the information overleaf.

**Anhang zur Bescheinigung Nr.: 20GZK1212-01**  
(Attachment to Certificate No.)

**Intertek Tick Mark**  
The tested product fulfills the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark.  
The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

<div style="border: 1px solid black; padding: 5px;"> <div style="display: flex; justify-content: space-between; align-items: center;"> <div style="text-align: center;"> <p><b>Independently tested</b></p> <p><b>Intertek</b></p> <p style="font-size: 8px;">Testing no. 20GZK1212</p> </div> <div style="border: 1px solid black; padding: 5px; width: 80%;"> <p>Exclusively tested for </p> <ul style="list-style-type: none"> <li>✓ 100% Heating Capacity at -5°F</li> <li>✓ 78% Heating Capacity at -22°F</li> <li>✓ 100% Cooling Capacity at 115°F</li> <li>✓ 78% Cooling Capacity at 130°F</li> </ul> <p style="font-size: 8px;">Testing no. 20GZK1212 www.intertek.de/directory</p> </div> </div> </div>	
	<p>Indoor unit: MDUI18024</p>
<p>Outdoor unit: MDUO18024036</p>	

	Segment / Section	Marking text for label
	Segment 1      Safety	
<input checked="" type="checkbox"/>	Section 1.1      Regulation document review	
<input checked="" type="checkbox"/>	Section 1.2      Electrical Safety	
<input checked="" type="checkbox"/>	Section 1.3      Mechanical Safety	
<input checked="" type="checkbox"/>	Section 1.4      Chemical Safety	
	Segment 2      Performance	
<input checked="" type="checkbox"/>	Section 2.2      Function	✓ 100% Heating Capacity at -5°F ✓ 78% Heating Capacity at -22°F ✓ 100% Cooling Capacity at 115°F ✓ 78% Cooling Capacity at 130°F
	Remarks: * only the chosen and passed sections can be listed above	

Dem Zertifikat liegen die Allgemeinen Geschäftsbedingungen der Intertek Deutschland GmbH zu Grunde. Bitte beachten Sie die umseitigen Hinweise.  
The General Business Conditions of Intertek Deutschland GmbH is an integral part of this certificate. Please also refer to the information overleaf.