



PPG Paints™ SPEEDHIDE® Interior Latex Fire Retardant Flat 42-7XI - FIRE HAZARD CLASSIFICATION

Flame Spread Rating: Class “A” when tested in accordance with ASTM E84 (NFPA 255). The coating obtained the following UNDERWRITERS LABORATORIES INC. AND UNDERWRITERS’ LABORATORIES OF CANADA fire hazard classification.

Class A Flame Spread Rating

COATING (SYSTEM) DETAILS	CLASSIFICATION OR RATING (WHEN APPLIED TO DOUGLAS FIR)	
	Flame Spread	Smoke Developed
PRIMER – None BASE COAT – 42-7XI applied in one coat at 155 sq. ft. (14.4 m ²) per U.S. gal. (3.78 L) TOP COAT - None	5	35-65

ASTM E84-10 Extended 30 Minute Rating

COATING (SYSTEM) DETAILS	CLASSIFICATION OR RATING (WHEN APPLIED TO DOUGLAS FIR)	
	Flame Spread	Smoke Developed
PRIMER – None BASE COAT – 42-7XI applied in two coats at 155 sq. ft. (14.4 m ²) per U.S. gal. (3.78 L) each TOP COAT - None	0	35