


Smart Process & Control LTD Unit 11, Totman Close, Brook Road Industrial Estate, Rayleigh, Essex, SS6 7UZ Telephone: 01268 773422 www.smartprocess.co.uk



# SDM230-MBus vI

DIN Rail Multifunction Power Meter (MID Certified)

• MID B+D Certified

Class B (kWh) EC Directive 2004/22/EC

Multifunction 100A Direct Connected

• Built In Pulsed & MBus Outputs



# SDM230-MBus Multifunction Power Meter

The SDM230-MBus is a new generation modern design power monitor that will measure and display electrical power quality parameters. It has been engineered to cover most applications (Single Phase networks / Built in Pulse and MBus / Import and Export kWh), replacing the need for several different models of this power meter.

As the demand for MID certified meters has increased, we have obtained annex B and D of the EC Directive 2004/22/EC. This power meter has been tested and certified for single phase networks and import and export active energy (kWh).

The SDM230-MBus is produced to the highest quality and utilizes the latest microprocessor and technology. It has a blue backlit display and 16 different measuring parameters. With built in pulsed outputs and MBus it is fully compatible for integration with BMS and remote monitoring systems.

# Parameters

- Phase to Neutral Voltage (V)
- Phase Current (A)
- Frequency (Hz)
- Power Factor (PF)
- Power Max Demand (MD kW)
- Active Power (kW)
- Reactive Power (kVAr)
- Apparent Power (kVA)

- Import Active Energy (kWh)
- Export Active Energy (kWh)
- Total Active Energy (kWh)
- Import Reactive Energy (kVArh)
- Export Reactive Energy (kVArh)
- Total Reactive Energy (kVArh)

# **Specifications**

## Measured Parameters

The unit can monitor and display the following parameters of a single phase two wire (1p2w) system.

#### Voltage and Current

- Phase to neutral voltages 176 to 276V a.c.
- Imin-Iref (Max) 0.5-10(100A)
- This meter is certified and tested at class I (Accurate to within ±1%). If the meter has a load smaller than the lmin (minimum current) we cannot guarantee class I accuracy.

#### Power factor and Frequency and Max. Demand

- Frequency in Hz
- Instantaneous power:
- Power 0 to 3600 MW
- Reactive power 0 to 3600 MVAr
- Volt-amps 0 to 3600 MVA
- Maximum demanded power since last Demand reset Power factor

#### **Energy Measurements**

Imported/Exported active energy	0 to 99999.99 kWh
Imported/Exported reactive energy	0 to 99999.99 kVArh
Total active energy	0 to 99999.99 kWh
Total reactive energy	0 to 99999.99 kVArh

### Measured Inputs

Voltage inputs through 3-way fixed connector with 19mm<sup>2</sup> maximum terminal wire.

Nominal Voltage Input	(Ph+N) 176 to 276V
Max Continuous Voltage	120% of nominal
Nominal Input Current	0.5-10(100)A
Max Continuous Current	120% of nominal
Nominal Input Current Burden	0.5VA
Frequency	50Hz(±10%)

#### Accuracy


Voltage	0-5% of range maximum
Current	0 -5% of nominal
Frequency	0.2% of mid-frequency
Power factor	1% of unity (0.01)
Active power (W)	±1% of range maximum
Reactive power (VAr)	±1% of range maximum
Apparent power (VA)	±1% of range maximum
Active energy (Wh)	Class I IEC 62053-21
Reactive energy (VARh)	±1% of range maximum

### Interfaces for External Monitoring

Two interfaces are provided:

• MBus

• Relay output indicating real-time measured energy.(configurable)



### Pulse Output

The meter provides two pulsed outputs, both pulsed outputs are passive type. The first pulsed output is configurable. The pulsed output can be set to read total / import / export/ kWh /

kVarh. The pulse constant can be set to generate 1 pulse per: 0.001(default) /0.01/0.1/1kWh/kVarh. The second pulsed output is non-configurable. It is fixed to read total kWh.

Rate can be set to generate I pulse per: 0.001 = I Wh/VArh (default) 0.01 = I0 Wh/VArh 0.1 = I00 Wh/VArh I = I kWh/kVArh

Pulse width 200/100/60 ms.

#### M-Bus

The meter provides a M-bus port for remote communication. M-bus protocol is applied.

Baud rate 300, 2400, 4800, 9600.

### Reference Conditions of Influence Quantities

Influence Quantities are variables that affect measurement errors to a minor degree. Accuracy is verified under nominal value (within the specified tolerance) of these conditions.

Ambient temperature	23°C ±I°C
Input waveform	50Hz ±2%
Input waveform	Sinusoidal (distortion factor < 0 005)
Auxiliary supply voltage	Nominal ±1%
Auxiliary supply frequency	Nominal ±1%
Auxiliary supply waveform (if AC)	Sinusoidal (distortion factor < 0.05)
Magnetic field of external origin	Terrestrial flux

#### Environment

Operating temperature	-25°C to +55°C*
Storage temperature	-40°C to +70°C*
Relative humidity	0 to 95%, non-condensing
Altitude	Up to 3000m
Warm up time	I minute
Vibration	10Hz to 50Hz, IEC 60068-2-6, 2g
Shock	30g in 3 planes


 $\ensuremath{^*\!Maximum}$  operating and storage temperatures are in the context of typical daily and seasonal variation.

#### **Mechanics**

DIN rail dimensions	mm x mm (WxH) per DIN 43880
Mounting	DIN rail (DIN 43880)
Sealing	IP51 indoor
Material	Self-extinguishing UL 94 V-0



# Dimensions



Installation

