




# Green Electrical Supply

maximize your green<sup>®</sup>




[www.GreenElectricalSupply.com](http://www.GreenElectricalSupply.com)

# INSTALLATION INSTRUCTION FOR Aleddra SUREFIT® DBA TUBE




1. Turn off the power to the light fixture at the breaker panel before installation.




2. Open the diffuser from the light fixture.
3. Remove the fluorescent tubes. Please dispose of these items properly as they contain mercury.



4. Put led tube into the lighting fixture.



5. Install the LED tubes, close the diffuser.
6. Turn on the Power.



- \* For one ballast by three fluorescent tubes fixture, at least need to put two pieces of SureFit DBA tube.  
For one ballast by four fluorescent tubes fixture, at least need to put three pieces of SureFit DBA tube.

## **WARNING:**

- Risk of fire. Do not install this lamp in a pre-heat luminaire.
- Risk of electric shock. Disconnect power before installation.
- Use only in place of fluorescent lamps specified on label.
- This device is not intended for use with emergency exists.
- These lamps are to be used in indoor dry location only. Not suitable for wet location.
- These lamps are not to be used with a light dimmer.
- Direct replacement for 32W48T8 Lamps only.
- If the lamp or luminaire exhibits undesirable operation (Buzzing, Flickering, etc), immediately turn off power, remove lamp from luminaire and contact manufacturer.
- Please check the installation instruction and specification carefully before installation.
- Please test sample before mass installation.