DesignLights Consortium





Classification	Standard
Primary Use	Retrofit Kits for Fuel Pump Canopy Luminaires
Reported Input Wattage	46.4 W
Reported Light Output	5778 lm
Reported CCT	5000 K
Reported CRI (Ra)	83
Product ID	PJFZK5QR
DLC Family Code	HHHCWC
Listing Status	Listed
Date Qualified	2020-03-30

PRODUCT INFORMATION VIEW DETAILS

Qualified Product List	Solid State Lighting
Technical Requirements Version	5.1
Product ID	PJFZK5QR
Manufacturer	ESL Vision
Brand	ESL Vision
Model Number	ESL-MUR-45W-350
Parent	Yes
Classification	Standard
DLC Family Code	нннсмс
Input Power Type	AC
Notes	Product Updated 7/27/2022

PRODUCT CATEGORIZATION VIEW DETAILS

Category	Outdoor Retrofit Kit	
General Application	Mid Output	
Primary Use Designation	Retrofit Kits for Fuel Pump Canopy Luminaires	

CONTROL FEATURES VIEW DETAILS

Integral Controls	Yes

Dimming Capability and Range	Continuous Dimming to 10% or below
Integral Control Capability	No Control Capability
Sensor Type	Exterior Photocell,Occupancy Sensing
SSL V5 Wired Communication Protocol	0-10V Analog
SSL V5 Wireless Communication Protocol	No Wireless Protocol
Field Adjustable Light Output	No
White-Tunable	No
Warm-Dimming	No
Field Adjustable Light Distribution	No

REPORTED PHOTOMETRIC PERFORMANCE VIEW DETAILS

Reported Light Output	5778 lm
Reported Efficacy (AC)	124.59 lm/W
Reported CCT	5000 K
Reported CRI (Ra)	83
Reported R9	5
Reported IES Rf	84
Reported IES Rg	96
Reported IES Rcs,h1	-12
Reported Default Light Output	5778 lm

REPORTED ELECTRICAL PERFORMANCE VIEW DETAILS

Reported Input Wattage	46.4 W
Reported Total Harmonic Distortion	13 %
Reported Power Factor	0.928
Reported Default Input Wattage	46.4 W
Voltage Range	120-277 V

TESTED PHOTOMETRIC PERFORMANCE VIEW DETAILS

Tested Light Output 5778 lm Tested Efficacy (AC) 124.59 lm/W Tested CCT 4929 K Tested CRI (Ra) 83 Tested R9 5 Tested IES Rf 83 Tested IES Rg 94 Tested IES Rcs,h1 -12 %		
Tested CCT 4929 K Tested CRI (Ra) 83 Tested R9 5 Tested IES Rf 83 Tested IES Rg 94	Tested Light Output	5778 lm
Tested CRI (Ra) 83 Tested R9 5 Tested IES Rf 83 Tested IES Rg 94	Tested Efficacy (AC)	124.59 lm/W
Tested R9 5 Tested IES Rf 83 Tested IES Rg 94	Tested CCT	4929 K
Tested IES Rf 83 Tested IES Rg 94	Tested CRI (Ra)	83
Tested IES Rg 94	Tested R9	5
	Tested IES Rf	83
Tested IES Rcs,h1 -12 %	Tested IES Rg	94
	Tested IES Rcs,h1	-12 %

Tested Duv	0.0055	
------------	--------	--

TESTED ELECTRICAL PERFORMANCE VIEW DETAILS

Tested Voltage	120
Tested Input Wattage	46.4 W
Tested Total Harmonic Distortion	13 %
Tested Power Factor	0.928

LISTING INFORMATION VIEW DETAILS

Testing in a Manufacturer-Selected Housing (Luminaire Specific)	General Purpose	
---	-----------------	--

VERSION HISTORY VIEW DETAILS

2022-07-27	Listed	5.1	Standard
2022-06-30	Delisted	5	Standard
2020-03-30	Listed	5	Standard
2018-11-02	Listed	4.4	Standard
2018-06-15	Listed	4.3	Standard