



**Materials & Finishes - Standard:**

- **Pregalvanized (PG):** Conforms to ASTM A653 SS GR 33, G90.
- **Unistrut Defender (DF):** Conforms to ASTM A1046 SS GR 33
- **Hot Dip Galvanized (HG):** Steel conforms to ASTM A1011 SS GR 33, Finish conforms to ASTM A123
- **Perma-Green (GR):** Steel conforms to ASTM A1011 SS GR 33, E-Coat finish
- **Perma-Gold (ZD):** Steel conforms to ASTM A1011 SS GR 33, Finish conforms to ASTM B633, Type II SC3
- **Plain (PL):** Conforms to ASTM A1011 SS GR 33

Part No.	Length (ft)	Finish	Product Weight / Ft (lbs/ft)
P7000	10	PG	0.25
P7000	10	HG	0.276
P7000	10	GR	0.25
P7000	10	PL	0.25
P7000	10	SS	0.25
P7000	10	EA	0.1

**Materials & Finishes - Special Metals:**

- **Stainless Steel, Type 304 (SS):** ASTM A240, Type 304 \*
- **Stainless Steel, Type 316 (ST):** ASTM A240, Type 316 \*
- **Aluminum (EA):** ASTM B221, Type 6063-T6 (Extruded) \*

\* These materials have different physical properties and performance characteristics. Please [contact us](#) for design support.

Beam Loading - P7000						
Span (in)	Max Allow. Uniform Load (lbs)	Deflection at Uniform Load (in)	Uniform Loading at Deflection			Lateral Bracing Reduction Factor
			Span/180 (lbs)	Span/240 (lbs)	Span/360 (lbs)	
18	80	0.12	60	50	30	0.98
24	60	0.22	40	30	20	0.95
30	50	0.36	20	20	10	0.95
36	40	0.50	20	10	10	0.90

Refer to the General Specifications for loading information.

Column Loading - P7000					
Unbraced Height (in)	Allowable Load at Slot Face (lbs)	Max Column Load Applied at C.G.			
		K=0.65 (lbs)	K=0.80 (lbs)	K=1.0 (lbs)	K=1.2 (lbs)
18	420	1,200	990	720	510
24	330	900	640	410	280
30	260	620	410	KL/r>200	KL/r>200
36	200	430	280	KL/r>200	KL/r>200

Refer to the General Specifications for loading information.

**Project:**

**Architect / Engineer:**

**Date:**  **Phone:**

**Contractor:**

**Address:**

**Notes:**

**Approval Stamp:**