

## DECLARATION OF PERFORMANCE

According to Annex III of the Regulation (EU) Nr.305/2011 (Construction Products Regulation)



### ASTRO X SERIES®

#### CE PIPE COLLAR

2531-CPR-CXO10292

**1. Unique identification code of product-type:**

XSPC

**2. Intended use/es:**

For fire compartmentation and / or fire protection or performance, ETA-20/1085 and EAD 350454-00-1104.

**3. Manufacturer:**

Astroflame Fireseals Ltd, Unit 8, The I O Centre, Stephenson Road, Segensworth, Fareham Hampshire, PO15 5RU

**4. Not applicable**

**5. System/s of AVCP:** AVCP - System 1

**6b. European Assessment Document:** EAD 350454-00-1104 - September 2017

**European Technical Assessment:** ETA-20/1085

**Technical Assessment Body:** ETA Danmark

**Notified Body/ies:** 2531

**7. Declared performance:**

Essential Characteristics	Performance/Harmonised technical specification
Reaction to Fire	Class E according to EN13501-1
Reaction to Fire	Resistance to fire performance & field of application in accordance with EN13501-2 See ETA 20/1085 - Annex A
Dangerous Substances	See ETA-20/1085 Clause 1.5
Service & Durability	Type: X Intended for use in conditions exposed to weathering in accordance with EOTA technical documents TR024
Other	Not applicable/No performance determined

**8. Appropriate Technical Documentation and/or Specific Technical Documentation:** ETA 20/1085

Link to the online copy of the declaration of performance: [www.astroflame.com](http://www.astroflame.com)

Signed on the behalf of the manufacturer by:

P.Kieser - Managing Director 15/02/2022

(Place of signature : Segensworth Fareham)

C.Dickens - Technical Managing 15/02/2022