

PHYSICAL TESTING REPORT

LUCIDEON

insight creating advantage



0013

Mactac Europe
Boulevard Kennedy
Zoning Industrial, Zone B
7060 Soignies
Belgium

FAO: Mrs. Beatrice Detournay

Report of Tests on: Self Adhesive Textured Laminate

Your Reference: Floor Grip

Lucideon Reference: (144809)-24837

Date Reported: 03-Nov-2014

Order Number: 4270

Date Logged: 08-Oct-2014

Date(s) of Test(s): 30-Oct-2014 to 30-Oct-2014

Inclined Platform Test for Slip Resistance In Shod Conditions

DIN 51130:2010

No.	Operator 1 - Angle of Inclination	Operator 2 - Angle of Inclination
	°	°
1	21.2	19.8
2	20.8	20.7
3	20.2	20.7

Description of Test Specimen(s): 1m x 0.5m laminate sheet

Average of Six Shod Results (Corrected): 20.6 °

Category: R11

The critical angle at which a test person reaches the limit of safe walking on an inclined plane is used as a measure of slip resistance.

Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.

End of Test Report

Mr Simon Hall
Author

Page 1 of 1

This report is issued in accordance with the Conditions of Business of Lucideon Limited and relates only to the sample(s) tested. No responsibility is taken for the accuracy of the sampling unless this is done under our own supervision. This report shall not be reproduced in part without the written approval of Lucideon Limited, nor used in any way as to lead to misrepresentation of the results or their implications.

Lucideon is the trading name of Lucideon Limited. Registered in England No. 1960455 Registered Office as above.

Lucideon Ltd
Queens Road, Penkhull
Stoke-on-Trent
Staffordshire ST4 7LQ, UK
T +44 (0)1782 764428
enquiries@lucideon.com
www.lucideon.com
Reg. England 1960455