Model S0P50

Portable Gravity Fed Eyewash Station



SPECIFICATIONS:

Model S0P50 portable eyewash station shall include a polyethylene 18 gallon tank, no moving parts and can be wall mounted or placed on a countertop or other flat surface. Eyewash heads provide a minimum of 0.4 GPM flow rate for 15 minutes and include a yellow eyewash pull strap for ease of activation. Tank includes integral handles on the top and sides, wide fill opening with threaded cap, highly visible identification/operation label and inspection/maintenance label. Unit is supplied with a heavy duty stainless steel wall bracket.

STANDARD EQUIPMENT:

Tank: Highly visible yellow, UV protected polyethylene tank, with no moving parts.

Evewash: ABS plastic evewash heads with easy activation removable pull strap will deliver a minimum water flow of 0.4 GPM [1.5 liters] for 15 minutes. Pull strap caps form an airtight seal which prevents dust and debris from collecting on the eyewash

Mounting: A J-shaped heavy duty stainless steel wall bracket for wall mounting allows easy removal and remounting of the eyewash station. The eyewash station can also be placed on a countertop or other flat surface.

Drain hose: Supplied with three feet of 1/2" ID drain hose.

Labels: Highly visible high gloss identification/operation label and inspection/ maintenance label are fixed to the face of the tank.

Water preservative: Not included.

Weekly inspection tag: A waterproof test card to record the date and inspector's name, for weekly inspection of the eyewash station.



APPLICATION:

Ideal for low traffic or remote areas where a person's eyes may be exposed to injurious or corrosive materials and there is no immediately available supply of potable water. The eyewash station can be wall mounted or may be placed on a countertop or other suitable flat surface. The eyewash station must be installed per ANSI Z358.1.





Acorn Safety assumes no responsibility for use of void or superseded data. © Copyright Acorn Safety®, City of Industry, CA, Division of Acorn Engineering Company Member of Morris Group International™. Please visit

www.acorneng.com for most current specifications.

Submittal # SOP50 [EW] Revised: 08/15/17

Product carries the following certifications:



Acorn Engineering Company® Morris Group International™

ACORN SAFETY


P.O. Box 3527 City of Industry, CA 91744 U.S.A. Phone 800-591-9372 626-855-4804

www.acorneng.com

TECHNICAL DIMENSIONS

All dimensions are subject to manufacturer's tolerance of plus or minus 1/2" nominal and subject to change without notice. Acorn Safety® assumes no responsibility for use of void or superseded data. Dimensions may change with the addition of optional accessories. © Acorn Safety®, A Division of Acorn Engineering Company®, Member of Morris Group International™. Please visit www.acorneng.com for most current specifications.

☐ Model S0P50 : Portable Gravity Fed Eyewash Station



GENERAL NOTES:

- 1. ALL DIMENSIONS ARE IN INCHES [MM].
- *2. ANSI Z358.1 REQUIRES NOZZLES TO BE MOUNTED BETWEEN 33" 45" [838 1143] ABOVE THE FINISHED FLOOR.
- 3. TANK CAN ALSO BE PLACED ON A COUNTERTOP OR OTHER FLAT SURFACE.

S0P50 Revised: 08/15/17

Acorn Safety warrants that its products are free from defects in material or workmanship under normal use and service for a period of one year from date of shipment. Acorn's liability under this warranty shall be discharged solely by replacement or repair of defective material, provided Acorn is notified in writing within one year from date of shipment, F.O.B. Industry, California.

SUMMARY VAL FOR STURING	Model Number & Options Company		Quantity	ACORO SAFETY
CTION S PPROV	Contact	Title		800-591-9372
SELE & A MA	Signature (Approval for Manufacturing)	Date		or 626-855-4804 www.acorneng.com