

PHYSICAL TESTING REPORT



Queens Road, Penkhull, Stoke-on-Trent, Staffordshire ST4 7LQ, United Kingdom

> tel: +44 (0)845 026 0902 fax: +44 (0)1782 412331 email: enquiries@ceram.com web: www.ceram.com

Mrs Stone Store Unit 19H Hilton Business Park Hilton Derbyshire DE65 5FJ

REPORT OF TESTS ON: Brazilian Honed Slate

Your Reference: SL024

CERAM Reference: (101580)-7904

Date Reported 30-Mar-2010 Order Number: 355

Date Logged 26-Mar-2010 Date(s) of Test(s): 29-Mar-2010 to 29-Mar-2010

Inclined Platform Test for Slip Resistance of Flooring Materials Under Wet Barefoot Conditions

DIN 51097: 1992

	Operator 1- Angle of Inclination	Operator 2- Angle of Inclination
No.	•	•
1	24.7	21.6
2	23.7	20.3
3	24.1	20.7
4	24.0	20.6
5	24.0	21.1
6	23.5	20.7
7	24.1	20.6
8	24.0	19.8

Description of Test Specimen(s): 1m X 0.5m panel

Average Barefoot Result: 22 °

Category: B

The critical angle at which 2 test persons reach the limit of safe walking on an inclined plane is used as a measure of slip resistance.

Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.

End of Test Report

S Hall Authorised Signatory

