

OXYGEN CYLINDER SAFETY CHECKLIST (WEEKLY)

DATE	LOCATION	STORAGE AREA ACCESS SECURED	SIGNAGE IS INTACT AND LEGIBLE	CYLINDERS STORED IN VERTICAL SUPPORT BIN	ROOM IS VENTILATED	CEILING AND WALLS ARE INTACT (Fire Separation)	CYLINDERS LABELS ARE INTACT AND LEGIBLE	FIRE EXTINGUISHER IS AVAILABLE IN THE AREA	CYLINDERS NOT STORED AGAINST HEATERS AND ELECTRICAL OUTLETS AND CORDS	MSDS AVAIL-ABLE	AREA IS NOT CONGESTED	STORAGE AREA IS DRY, FREE OF DUST, AND BELOW 50°C	SAFE WORK PRACTICE IS POSTED IN THE AREA	CYLINDERS ARE NOT IN CLOSE PROXIMITY TO COMBUSTIBLE MATERIALS (36 inches)	SIGNATURE OF EMPLOYEE	SIGNATURE OF MANAGER (Deficiencies are Corrected)

#714 FRONT OF EACH PAGE

MARK "Y" FOR SATISFACTORY - "X" FOR UNSATISFACTORY (SEE COMMENTS ON REVERSE)