

Emission Test Certificate

Wednesday, January 15, 2013

Supplier: Armstrong World Industries (29-39 Mills Road, Braeside, VIC, 3195)

Sample Description: 2.0mm Homogeneous Sheet Vinyl Flooring

Date Tested: November 2013 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: EN 13419 (2003-01) “Building Products - Determination of The Emission Of Volatile Organic Compounds - Part 1: Emission Test Chamber Method”

Emission Data:

<p align="center">Specification</p> <p align="center">Green Building Council of Australia Green Star Office Design V3 IEQ-13</p>	<p align="center">2.0mm Homogeneous Sheet Vinyl Flooring</p>
<p align="center">Total Volatile Organic Compound Specific Area Emission Rate</p> <p align="center"><0.5 mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.024 mg/m²/hr</p> <p>Total Volatile Organic Compound Concentration: 0.014 mg/m³ *</p> <p align="center">(28 day exposure)</p>

* Based on the standard room model



Dr. Vyt Garnys
PhD, BSc(Hons) AImm, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)

Consultant

CV131116