

Emission Test Certificate

Tuesday October 2nd, 2007

Manufacturer: Armstrong World Industries (Australia Pty Ltd)

29 – 29 Mills Road

Braeside Victoria 3195

Sample Description: Armstrong Accolade Safe Plus

Date Tested: August-September 2007

Test Method: EN 13419 “Building Products – Determination of the Emission of Volatile Organic Compounds Part 1: Emission Test Chamber Method”

Emission Data:

	German AgBB Requirement ug/m²/hr	Product Total Volatile Organic Compound Specific Area Emission Rate ug/m²/hr (average of duplicate samples) Armstrong Accolade Safe Plus
3-Day Emissions	<10,000	100
28-Day Emissions	<1,000	45



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Project CV070819