

Emission Test Certificate

Friday 11th March 2022

Supplier: Armstrong Flooring Pty Ltd (29-39 Mills Road, Braeside, VIC, 3195, Australia)

Sample Description: Rejuvenations/Rejuvenations Plus HET Sheet

Date Tested: March 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (28 days):

Green Building Council of Australia Green Star Design & As Built V1.3 - 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B	Rejuvenations/Rejuvenations Plus HET Sheet
Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/m ² /hr	Total Volatile Organic Compound Emission Rate: 0.019 mg/m ² /hr
4-phenylcyclohexene Emission Rate Limit: ≤0.05 mg/m ² /hr	4-phenylcyclohexene Emission Rate: <0.003 mg/m ² /hr
Formaldehyde Emission Rate Limit: ≤0.1 mg/m ² /hr	Formaldehyde Emission Rate: <0.006 mg/m ² /hr



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Consultant



Tuan Duong
B.Eng. (Chemical)
Consultant