

Emission Test Certificate

Friday 4th September 2020

Supplier: Armstrong Flooring Pty Ltd (29-39 Mills Road, Braeside, Victoria 3195, Australia)

Sample Description: Timberline Plus / Translations Plus

Date Tested: June 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (3 days):

Green Building Council of Australia Green Star Design & As Built V1.3 - 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B	Timberline Plus / Translations Plus
Total Volatile Organic Compound Emission Rate Limit: $<0.500 \text{ mg/m}^2/\text{hr}$	Total Volatile Organic Compound Emission Rate: $0.052 \text{ mg/m}^2/\text{hr}$
4-phenylcyclohexene Emission Rate Limit: $<0.05 \text{ mg/m}^2/\text{hr}$	4-phenylcyclohexene Emission Rate: $<0.005 \text{ mg/m}^2/\text{hr}$
Formaldehyde Emission Rate Limit: $<0.1 \text{ mg/m}^2/\text{hr}$	Formaldehyde Emission Rate: $0.029 \text{ mg/m}^2/\text{hr}$



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B.Eng. (Chemical)
Consultant

CV190653 R01