

## DECLARATION OF CONFORMITY

Batch Test Declaration Date: 01.10.2020

TEST REPORT	
( Roofing Systems )	
Product Description	Universal 5' Guardrails with Bases Complete Kit (55')
Product Code	GUS05
Standards	OSHA 1926 Subpart M
	OSHA 1926.502(b)

TEST SUMMARY		
Test Specification	Test Criteria	Test Result
OSHA 1926 Subpart M OSHA 1926.502(b)	1926.502(b)(4) • When the 200 pound (890 N) test load specified in paragraph (b)(3) of this section is applied in any downward or outward direction, the top edge of the guardrail shall not deflect to a height less than 39 inches (1.0 m) above the walking/working level. Guardrail system components selected and constructed in accordance with the Appendix B to subpart M of this part will be deemed to meet this requirement.	PASS
	1926.502(b)(5) • Midrails, screens, mesh, intermediate vertical members, solid panels, and equivalent structural members shall be capable of withstanding, without failure, a force of at least 150 pounds (666 N) applied in any downward or outward direction at any point along the midrail or other member.	

Additional Conformity Assessment Method in accordance with ANSI/ISEA 125-2021:

- Level 2: Manufactured in a facility with a QMS registered to ISO 9001

This Certificate is a guarantee that the above standard(s) was met by the requirements of such standard. Testing was performed under normal operation mode. The results of testing apply only to the particular sample tested and to the specific test carried out. This Certificate is only issued for products which have passed the testing requirements of listed standard(s).



Travis Turner

Title: Engineering Manager