

# Contactors and Contactor Assemblies

## 3RT1 Contactors

SIRIUS



### Accessories for contactors

#### Selection and ordering data



3RH19 21-1F...



3RH19 21-2F...



3RH19 21-1C...



3RH19 21-2C...



3RH19 21-1LA..



3RH19 21-1MA..

For contactors	Rated operational current <sup>2)</sup> NEMA A600 / Q600	Auxiliary contacts				Screw connection		Cage Clamp connection		Weight approx.	Pack.
		Ident. no.	Design			Order No.	List Price \$	Order No.	List Price \$		
Type			NO	NC	NO	NC				kg	

#### Auxiliary switch blocks for snapping onto the front acc. to EN 50 005

Sizes S0 to S12<sup>1)</sup>

##### 4-pole auxiliary switch blocks

3RT10 2, 3RT1. 3 to 3RT1. 7, 3RT11	Ident. no.	Design	Order No.	List Price \$	Order No.	List Price \$	Weight approx.	Pack.
	40	4 - - -	3RH19 21-1FA40		3RH19 21-2FA40		0.065	1 unit
	31	3 1 - -	3RH19 21-1FA31		3RH19 21-2FA31			
	22	2 2 - -	3RH19 21-1FA22		3RH19 21-2FA22			
	04	- 4 - -	3RH19 21-1FA04		3RH19 21-2FA04			
	22 U	- - 2 2	3RH19 21-1FC22		3RH19 21-2FC22			

##### Single-pole auxiliary switch blocks acc. to EN 50 005 and EN 50 012

3RT1. 2 to 3RT1. 7, 3RT11	Ident. no.	Design	Order No.	List Price \$	Order No.	List Price \$	Weight approx.	Pack.
	-	1 - - -	3RH19 21-1CA10		3RH19 21-2CA10		0.015	1 unit
	-	- 1 - -	3RH19 21-1CA01		3RH19 21-2CA01			
	-	- - 1 -	3RH19 21-1CD10		-			
	-	- - - 1	3RH19 21-1CD01		-			

##### 2-pole auxiliary switch blocks with cable entry from one side

###### • Cable entry from above

3RT10 2, 3RT1. 3 to 3RT1. 7, 3RT11	Ident. no.	Design	Order No.	List Price \$	Order No.	List Price \$	Weight approx.	Pack.
	-	1 1 - -	3RH19 21-1LA11		-		0.065	1 unit
	-	- 2 - -	3RH19 21-1LA20		-			
	-	- - 2 -	3RH19 21-1LA02		-			

###### • Cable entry from below

3RT10 2, 3RT1. 3 to 3RT1. 7, 3RT11	Ident. no.	Design	Order No.	List Price \$	Order No.	List Price \$	Weight approx.	Pack.
	-	1 1 - -	3RH19 21-1MA11		-		0.065	1 unit
	-	- 2 - -	3RH19 21-1MA20		-			
	-	- - 2 -	3RH19 21-1MA02		-			

EN50005 and EN50012 designate the markings of the auxiliary terminal numbers.  
For position of the terminals see pages 2/166-169.  
For int. circuit diagrams see pages 2/156-160.

1) Exception: 3RT16.  
2) UL ratings, Appendix page 19/7.