




Product name .....	Micro Solar Inverter
Trade Mark .....	
Factory's name .....	Dongguan kaideng Energy Technology Co., Ltd.
Factory address .....	4 th floor, Fuyuan business building, no. 1, Lane 13, xin'an maiyuan Road, Chang 'an town, Dongguan City, Guangdong, China

Model/Type reference .....	WVC-600	WVC-700	WVC-800
Ratings:			
Max. DC Input voltage [V] .....	60		
MPPT input voltage range [V] .....	30-60		
Max. input DC current [A] .....	14/14	16/16	18/18
Short-circuit current [A] .....	16/16	18/18	20/20
Nominal output AC voltage [V] .....	230 V~, 50/60Hz		
Max. output AC current [A] .....	2,6	3,05	3,50
Nominal active output power [W] .....	600	700	800
Max. apparent output power [VA] .....	600	700	800
Note: All test were performed on 230Vac, 50Hz.			

# Contents

Revision history of test report .....	4
Copy of marking plate .....	5
General remarks - documentation.....	7
General remarks for testing .....	8
General product information .....	9
General product information .....	10
Assessment .....	11
Annex 1 – Test Results.....	14
<b>5.2 Evidence of permissible network perturbations .....</b>	<b>15</b>
5.2.1 General.....	15
5.2.2 Rapid voltage changes .....	16
5.2.3 Flicker .....	18
5.2.4 Harmonics and interharmonics .....	20
5.2.4.1 a) Harmonics test .....	20
5.2.4.1 b) Test Harmonics DIN EN 61000-4-7 ( $\geq 75$ A per Phase).....	24
5.2.5 Commutation .....	28
5.2.6 Feed in of DC current.....	29
<b>5.3 Evidence of symmetry behaviour of inverters.....</b>	<b>30</b>
5.3.1 General.....	30
5.3.2.1 Calculation of asymmetry .....	31
<b>5.4 Evidence of the behaviour of the generating unit on the network .....</b>	<b>32</b>
5.4.1 General.....	32
5.4.2 Measurement of the active power and reactive power range.....	33
5.4.3 Measurement of setting accuracy .....	34
5.4.3.4 Measurement of the power gradient .....	35
5.4.3.5 Measurement priority interfaces / energy management system .....	37
5.4.4 Active power feed-in for PGU's at overfrequency .....	38
5.4.6 Active power feed-in for PGUs at underfrequency.....	42
5.4.8 Static voltage stability / reactive power supply .....	46
5.4.8.3 Test of the displacement factor/active power characteristic curve $\cos \phi$ (P) .....	50
5.4.8.4 Test the reactive power-voltage characteristic Q(U) .....	57
<b>5.5 Testing of NS protection.....</b>	<b>62</b>
5.5.2 NS protection .....	62
5.5.3 Central NS-protection .....	65
5.5.4 Integrated NS protection.....	66
5.5.6 Interface switch .....	67
5.5.7.2 Check of setting values.....	70
5.5.7.3 Wiring check.....	72
5.5.7.4 Voltage and frequency control .....	79
5.5.7.5 Reporting NS protection .....	81
5.5.9 Constructional characteristics of NS protection .....	82
5.5.10 Islanding detection .....	83
<b>5.7 Evidence of <math>P_{AV,E}</math>-Control.....</b>	<b>94</b>
<b>5.8 Evidence dynamic grid support.....</b>	<b>95</b>
Annex 2 – Pictures of the unit .....	198
Annex 3 – Test equipment list .....	202









**Revision history of test report**

<b>Issued Date</b>	<b>Description</b>	<b>Report Number</b>
2022-12-29	Initial issue.	220907STA099-EG-DE-001

## Copy of marking plate

<h1 style="text-align: center;">WVC-600</h1> <h2 style="text-align: center;">Micro Solar Inverter</h2>	<b>Product Parameters</b> Maximum Output Power: 600W AC Voltage Range: 80-280V Maximum Output Efficiency: >95% Power Factor: >99.5% Output THD: <5% Night Time Power: <50mW Waterproof: IP65	 
<b>Model:WVC-600</b> Automatic adaptation of AC voltage worldwide. Forward excitation full complement high frequency modulation grid-connected mode High precision voltage sensing micro-grid mode Real-time collection of IOT multi-point collection data Smartphone APP Monitoring System Automatic adaptation of the world's AC frequency No professional installation and maintenance required Built-in high-precision electricity meter Dual engine maximum power point tracking(MPPT)	<b>WARNING</b> This device complies with Part 15 of the FCC Rules. Operation is Subject to the following two conditions 1.This device may not cause harmful interference 2.This device must accept any interference received,including interference that may cause undesired operation.	
   	<b>CAUTION</b> -Risk of electric shock Normally grounded conductors may be ungrounded and energized when a ground-fault is indicated. -Do not remove cover or user serviceable parts inside Refer servicing to qualified service personnel. -Both AC and DC voltage sources are terminated inside this equipment. Each circuit must be individually disconnected before servicing. -When the photovoltaic array is exposed to light, it supplies a DC voltage to this equipment -To be connected only to a dedicated branch circuit Maximum branch circuit over current protection: 35A	
<h1 style="text-align: center;">WVC-700</h1> <h2 style="text-align: center;">Micro Solar Inverter</h2>	<b>Product Parameters</b> Maximum Output Power: 700W AC Voltage Range: 80-280V Maximum Output Efficiency: >95% Power Factor: >99.5% Output THD: <5% Night Time Power: <50mW Waterproof: IP65	 
<b>Model:WVC-700</b> Automatic adaptation of AC voltage worldwide. Forward excitation full complement high frequency modulation grid-connected mode High precision voltage sensing micro-grid mode Real-time collection of IOT multi-point collection data Smartphone APP Monitoring System Automatic adaptation of the world's AC frequency No professional installation and maintenance required Built-in high-precision electricity meter Dual engine maximum power point tracking(MPPT)	<b>WARNING</b> This device complies with Part 15 of the FCC Rules. Operation is Subject to the following two conditions 1.This device may not cause harmful interference 2.This device must accept any interference received,including interference that may cause undesired operation.	
   	<b>CAUTION</b> -Risk of electric shock Normally grounded conductors may be ungrounded and energized when a ground-fault is indicated. -Do not remove cover or user serviceable parts inside Refer servicing to qualified service personnel. -Both AC and DC voltage sources are terminated inside this equipment. Each circuit must be individually disconnected before servicing. -When the photovoltaic array is exposed to light, it supplies a DC voltage to this equipment -To be connected only to a dedicated branch circuit Maximum branch circuit over current protection: 35A	

Copy of marking plate

<h1 style="text-align: center;">WVC-800</h1> <h2 style="text-align: center;">Micro Solar Inverter</h2>	<p><b>Product Parameters</b></p> <table border="0"> <tr> <td>Maximum Output Power:</td> <td>800W</td> </tr> <tr> <td>AC Voltage Range:</td> <td>85-280V</td> </tr> <tr> <td>Maximum Output Efficiency:</td> <td>&gt;95%</td> </tr> <tr> <td>Power Factor:</td> <td>&gt;99.5%</td> </tr> <tr> <td>Output THD:</td> <td>&lt;5%</td> </tr> <tr> <td>Night Time Power:</td> <td>&lt;50mW</td> </tr> <tr> <td>Waterproof:</td> <td>IP65</td> </tr> </table>	Maximum Output Power:	800W	AC Voltage Range:	85-280V	Maximum Output Efficiency:	>95%	Power Factor:	>99.5%	Output THD:	<5%	Night Time Power:	<50mW	Waterproof:	IP65	 
Maximum Output Power:	800W															
AC Voltage Range:	85-280V															
Maximum Output Efficiency:	>95%															
Power Factor:	>99.5%															
Output THD:	<5%															
Night Time Power:	<50mW															
Waterproof:	IP65															
<p><b>Model:WVC-800</b></p> <p>Automatic adaptation of AC volgage worldwide.          Forward excitation full complement high frequency modulation grid-connected mode          High precision voltage sensing micro-grid mode          Real-time collection of IOT multi-point collection data          Smartphone APP Monitoring System          Automatic adaptation of the world's AC frequency          No professional installation and maintenance required          Built-in high-precision electricity meter          Dual engine maximum power point tracking(MPPT)</p>	<p><b>WARINING</b></p> <p>This device complies whth Part 15 of the FCC Rules. Operation is Subject to the following two conditions</p> <ol style="list-style-type: none"> <li>1.This device may not cause harmful interference</li> <li>2.This device must accept any interference received.including int erference that may cause undesired operation.</li> </ol> <p><b>CAUTION</b></p> <ul style="list-style-type: none"> <li>-Risk of electric shock Normally grounded conductors may be ungrounded and energized when a groundnd-fault is indicated.</li> <li>-Do not remove cover mo user serviceable parts inside Refer servicing to qualified service personnel.</li> <li>-Both AC and DC voltage sources are terminated inside this equipment. Each circui must be individually disconnected before servicing.</li> <li>-When the photovoltaic array is exposed to light, it supplies a DC voltage to this equipment</li> <li>-To be connected only to a dedicated branch circuit</li> </ul> <p>Maximum branch circuit over current protection: 35A</p>  															
   																

**General remarks - documentation**
**Possible test case verdicts**

Test case does not apply to the test object ....: N/A  
 Test case is not rated .....: N/R  
 Test item does meet the requirement .....: P (Pass)  
 Test item does not meet the requirement ....: F (Fail)

**Testing**

Date of receipt of test items .....: 2022-09-07  
 Date(s) of performance of tests .....: 2022-09-07 to 2022-12-19

**General remarks:**

The test result presented in this report relate only to the object(s) tested. This report shall not be reproduced in part or in full without the written approval of the issuing testing laboratory.

"(see Annex #)" refers to additional information appended to the report.

"(see appended table)" refers to a table appended to the report.


Throughout this report a comma / point is used as the decimal separator.

Conformity statements are decided in accordance with IEC GUIDE 115:2021 Procedure 2 (accuracy method), unless otherwise normatively specified or contractually agreed.

Direction definition of P and Q:

in this test report, the regarded system of the voltage and current vectors is the active sign convention system:

- If the inverter feeds to the grid the active power is measured with positive sign.
- If the inverter injects reactive power / current with leading power factor the reactive power / current is marked "leading" or "inductive" (under-excited) or has a negative sign.
- If the inverter injects reactive power / current with lagging power factor the reactive power / current is marked "lagging" or "capacitive" (over-excited) or has a positive sign.




## General remarks for testing

**Test setup:**


For the testing 2 test setups were used:

- a) *Test setup 1*: used for tests except islanding prevention testing.



**Figure 1 – Test setup 1**

- b) *Test setup 2*: Basic test configuration for islanding detection function




**Figure 2 – Test circuit for islanding detection function in a power conditioner (inverter) from IEC 62116:2014**



**General product information**

Equipment mobility ..... : Permanent connection  
 Operating condition ..... : Continuous  
 Class of equipment..... : Class I  
 Protection against ingress of water ..... : IP65 according to EN 60529  
 Mass of equipment [kg] ..... : Approximately 1,46kg

The system consists of an array of micro-inverters that convert direct current (DC) to alternating current (AC) and feed it into the public grid. The system is designed to install one micro-inverter for every two PV modules. Each micro-inverter works independently, ensuring that each PV module maximum power generation. This setup enables the user to directly control the efficiency of the individual PV module arrays, increasing the flexibility and availability of the system dependability. (see Figure 3)



**Figure 3 – Scheme of an installation**

**The product was tested on:**

Hardware Version: A0

Software Version: WVC-700R3-22-60-Life-E2


**General product information**
**Description of the power circuit (Figure 4):**

The inverter converts DC voltage into alternating voltage. The unit does provide galvanic separation from input to output (transformer).

The output is switched off redundantly by the high-power switching bridge and relay. This assures that the opening of the output circuit will also operate in case of a single error.

The controller (U172) controls the relay by switching signals; measures the Bus voltage, grid voltage, frequency, AC current with injected DC and the array insulation resistance to ground.

The unit provides relay in series in all output conductors. All the relay are tested before each start up.


**Figure 4 – Block diagram**

**Assessment**

Clause/§	Requirement	Verdict
<b>5.2</b>	<b>Evidence of permissible network perturbations</b>	
5.2.1	General	P
5.2.2	Rapid voltage changes	P
5.2.3	Flicker	P
5.2.4	Harmonics and interharmonics	P
5.2.4.1 a)	Test Harmonics DIN EN 61000-3-2 ( $\leq 16$ A per Phase)	P
5.2.4.1 a)	Test Harmonics DIN EN 61000-3-12 ( $\geq 16$ A and $\leq 75$ A per Phase)	N/A
5.2.4.1 b)	Test Harmonics and interharmonics DIN EN 61000-4-7 ( $\geq 75$ A per Phase)	P
5.2.5	Commutation	N/A
5.2.6	Feed in of DC current	P
<b>5.3</b>	<b>Evidence of symmetry behaviour of inverters</b>	
5.3.1	General	N/A
5.3.2.1	Calculation of the asymmetry of three-phase inverters	N/A
5.3.2.2.1	Failure of single inverter modules	N/A
5.3.2.2.2	Power drop of single inverter modules	N/A
5.3.2.3.2	Symmetrical operation with a symmetry device	N/A
<b>5.4</b>	<b>Evidence of the behaviour of the generating unit on the network</b>	
5.4.1	General	P
5.4.2	Measurement of the active and reactive power range	P
5.4.3.3	Measurement of setting accuracy	P
5.4.3.4	Measurement of the power gradient	P
5.4.3.5	Measurement Priority Interfaces / Energy Management	N/A
5.4.4	Active power feed-in for PGUs at over-frequency	P
5.4.5	Active power feed-in of Storage systems for over-frequency	P
5.4.6	Active power feed-in for PGUs at underfrequency	P
5.4.7	Active power feed-in for storage systems at underfrequency	N/A
5.4.8	Static voltage stability / reactive power supply	P
5.4.8.2	Tests of the Reactive power / $\cos \varphi$ setting accuracy	P
	The regulating and control behaviour of the reactive power	P
5.4.8.3	Test of the displacement factor/active power characteristic curve $\cos \varphi$ (P)	P
	Test 1) for conducted PGUs - Accuracy (characteristic)	P
	Test 2) for conducted PGUs - dynamics	N/A
	Test 3) supply-dependent PGUs - Accuracy (characteristic curve)	P
	Test 4) supply-dependent PGUs - Dynamic	P
5.4.8.4.1	Test of the accuracy of the Q(U) regulation	P

**Assessment**

Clause/§	Requirement	Verdict
5.4.8.4.2	Test of the dynamics of the Q(U) regulation	P
<b>5.5</b>	<b>NS-protection</b>	
5.5.2	NS protection	P
5.5.2.1	Functional safety	P
5.5.3	Central NS-protection	N/A
5.5.4	Integrated NS-protection	P
5.5.6	Interface switch	P
5.5.6.2	Central interface switch	N/A
5.5.6.3	Integrated interface switch	P
5.5.7.2	Check of setting values	P
5.5.7.3	Wiring check	N/A
5.5.7.4	Voltage and frequency control	P
5.5.7.4.1	Voltage and frequency control – Single Phase	P
	Voltage and frequency control – Multi Phase (Phase to N)	N/A
	Voltage and frequency control – Multi Phase (Phase to Phase)	N/A
	Voltage and frequency control – Measuring the rise-in voltage protection as a running 10-minute mean value	P
	Voltage and frequency control – Frequency measurement	P
5.5.7.5	Reporting of NS protection	P
5.5.9	Constructional characteristics of NS protection	P
5.5.10.1	General	P
5.5.10.2	Passive Islanding Protection	N/A
5.5.10.3	Islanding protection according to table 6 – Load imbalance (real, reactive load) for test condition A (PGU output = 100%)	P
	Islanding protection according to table 7 – Load imbalance (real, reactive load) for test condition B (PGUT output = 66%)	P
	Islanding protection according to table 8 – Load imbalance (real, reactive load) for test condition C (PGU output = 33%)	P
<b>5.6</b>	<b>Connecting conditions and synchronization</b>	
5.6.1	General	P
5.6.2	Connecting conditions and synchronisation	P
<b>5.7</b>	<b>Evidence of P<sub>AV,E</sub> - Control</b>	
5.7.1	General	N/A
5.7.2.1	Test control dynamic	N/A
5.7.2.2	Test disconnection function	N/A
<b>5.8</b>	<b>Evidence dynamic grid support</b>	
5.8.1	General	P

**Assessment**

Clause/§	Requirement	Verdict
5.8.3	Testing of the dynamic grid support PGU Type 1	N/A
5.8.3	Testing of the dynamic grid support PGU Type 2	P
5.9	<b>Test of Ancillary Unit</b>	



## Annex 1 – Test Results

<b>5.2 Evidence of permissible network perturbations</b>	
<b>5.2.1 General</b>	<b>P</b>
<p>The electrical installations of the customer system shall be planned, constructed and operated so that reactions to the network operator's network and to the systems of other customers are permanently reduced to a permissible minimum. Should interfering reactions on the network operator's network occur nonetheless, the customer shall apply measures to his system that are to be coordinated with the network operator. The network operator is entitled to disconnect the power generation system concerned from the network until the deficiencies are corrected.</p> <p><u>System perturbations are defined as:</u></p> <ul style="list-style-type: none"> <li>- Rapid voltage changes</li> <li>- Flicker</li> <li>- Harmonics, interharmonics and higher frequencies (up to 9 kHz)</li> </ul>	

5.2.2 Rapid voltage changes									P
The purpose of the test is to determine $k_i$ and $k_{imax}$ . The following three cases must be tested (where applicable). <ul style="list-style-type: none"> <li>- Switch-on for any capacity</li> <li>- Unfavourable case when switching the generator step</li> <li>- Switch-on for nominal capacity</li> </ul> Note: For PV-plants the inverter is the generator <ul style="list-style-type: none"> <li>- Switch-off for nominal capacity (no emergency shutdown, but operative shutdown)</li> </ul> If the manufacturer knows more critical cases (e.g., different $\cos \varphi$ parameters) then these additional have to be tested									
<b>Test conditions:</b>									
Frequency: 50 Hz $\pm$ 0,5%									
THD of the voltage supply: $\leq$ 3 %									
Voltage rises of the PGU at 100 P <sub>E<sub>max</sub></sub> %: $\leq$ 3 %									
<b>WVC-800</b>									
<b>Switch-on for any capacity (10% P<sub>E<sub>max</sub></sub>)</b>									
Phase	L1			L2			L3		
Single period effective values of the current [A]	0,094	0,082	0,063	--	--	--	--	--	--
Single period effective values of the voltage [V]	229,11	230,14	230,64	--	--	--	--	--	--
$k_i$ value [1]	0,027	0,024	0,018	--	--	--	--	--	--
$k_{imax}$ value [1]	0,027			--			--		
<b>Unfavourable case when switching the generator step (not necessary for electronic inverter)</b>									
Phase	L1			L2			L3		
Single period effective values of the current [A]	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Single period effective values of the voltage [V]	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
$k_i$ value [1]	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
$k_{imax}$ value [1]	N/A			N/A			N/A		
<b>Switch-on for nominal capacity</b>									
Phase	L1			L2			L3		
Single period effective values of the current [A]	0,069	0,077	0,081	--	--	--	--	--	--
Single period effective values of the voltage [V]	230,96	230,19	230,36	--	--	--	--	--	--
$k_i$ value [1]	0,020	0,022	0,023	--	--	--	--	--	--
$k_{imax}$ value [1]	0,023			--			--		



Switch-off for nominal capacity									
Phase	L1			L2			L3		
Single period effective values of the current [A]	2,110	2,106	2,096	--	--	--	--	--	--
Single period effective values of the voltage [V]	230,53	230,50	230,55	--	--	--	--	--	--
$k_i$ value [1]	0,607	0,605	0,603	--	--	-	-	--	--
$k_{imax}$ value [1]	0,607			--			--		
Grid Frequency [Hz]				50,00					
Grid voltage [V]				230,0					
Rated current $I_r$ [A]				3,5					
Highest $k_{imax}$ value for all switching operations [1]				0,607					
<p><b>Note:</b></p> <p>Limits:</p> <p><math>k_{imax} = 1,2</math> for synchronous generators with fine synchronization, converter; (electronic inverter)</p> <p><math>k_{imax} = 4</math> for asynchronous generators, which are switched on at 95% to 105% of their synchronous speed, if no further details are available regarding the type of current limitation. With regard to short-term compensation processes, the condition mentioned below for very short voltage changes must also be observed.</p> <p><math>k_{imax} = 8</math> for asynchronous generators that are powered up by the network if <math>I_a</math> is unknown. (<math>I_a</math> = starting current)</p> <p>The test results of the <b>WVC-800</b> can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.</p>									

<b>5.2.3 Flicker</b>					<b>P</b>	
<b>These tests are designed to provide evidence that the requirements of VDE-AR-N 4100:2019-04 are met.</b>						
Adherence to the thresholds for flicker must be verified as followed:						
<ul style="list-style-type: none"> <li>- For nominal currents <math>\leq 16</math> A per conductor to DIN EN 61000-3-3 (VDE 0838-3)</li> <li>- For nominal currents <math>&gt; 16</math> A and <math>\leq 75</math> A per conductor to DIN EN 61000-3-11 (VDE 0838-11)</li> </ul>						
<b>Test conditions:</b>						
Voltage: 86% $U_n$ to 109% $U_n$						
Frequency: 50 Hz $\pm 0,5\%$						
THD of the voltage supply: $\leq 3\%$						
Voltage rises of the PGU at 100% $P_{Emax}$ : $\leq 3\%$						
<b>Assessment criterion:</b>						
Long-term flicker strength $Plt$ to DIN EN 61000-3-3 (VDE 0838-3) must be $\leq 0,5$ .						
Determination of the flicker coefficient:						
$c_{\psi k} = P_{st} \times (S_k / P_n)$						
where $S_k$ is the short-circuit power of the network standby element (during the determination of the appropriate $P_{st}$ values)						
The value for the network standby element must be determined separately with measurements for rated currents $> 75$ A.						
<i>Note:</i>						
Grid impedance DIN EN 61000-3-3 (VDE 0838-3) [ $\Omega$ ]:		$R_A = 0,24\Omega$ $jX_A = 0,15\Omega$ / $R_N = 0,16\Omega$ $jX_N = 0,10\Omega$ ( $R_n$ and $jX_n$ only for single-phase units used!)				
Grid impedance DIN EN 61000-3-11 (VDE 0838-11) [ $\Omega$ ]:		$R_A = 0,24\Omega$ $jX_A = 0,15\Omega$ / $R_N = 0,16\Omega$ $jX_N = 0,10\Omega$ ( $R_n$ and $jX_n$ only for line to neutral single-phase or three units used!)				
		$R_A = 0,15\Omega$ $jX_A = 0,15\Omega$ / $R_N = 0,01\Omega$ $jX_N = 0,01\Omega$ ( $R_n$ and $jX_n$ only for line to line three-phase units used!)				
Test result:						
<b>a) Flicker to DIN EN 61000-3-3 (VDE 0838-3) for generator units <math>\leq 75</math> A</b>					<b>P</b>	
<b>EUT</b>		<b>Selection of limits</b>				
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input type="checkbox"/>		
<b>1- phase</b>	<b>3-phase</b>	Equipment with rated current $\leq 16$ A per phase		Equipment with rated current $\leq 75$ A per phase		
		<i>IEC EN 61000-3-3</i>		<i>IEC EN 61000-3-11</i>		
		$d_{max}$	$d_c$	$T_{max}$	$P_{st}$	$P_{It}$
		0,70	0,68	0	0,152	0,150
Output voltage of the impedance network [V]				231,47		
Reference impedance according the standard:						
<input checked="" type="checkbox"/>		Grid impedance DIN EN 61000-3-3 (VDE 0838-3) [ $\Omega$ ]:				$R_A = 0,24\Omega$ $jX_A = 0,15\Omega$ / $R_N = 0,16\Omega$ $jX_N = 0,10\Omega$ ( $R_n$ and $jX_n$ only for single-phase units used!)
<input type="checkbox"/>		Grid impedance DIN EN 61000-3-11 (VDE 0838-3) [ $\Omega$ ]:				$R_A = 0,24\Omega$ $jX_A = 0,15\Omega$ / $R_N = 0,16\Omega$ $jX_N = 0,10\Omega$ ( $R_n$ and $jX_n$ only for line to neutral single-phase or three units used!)
<input type="checkbox"/>		Grid impedance DIN EN 61000-3-11 (VDE 0838-3) [ $\Omega$ ]:				$R_A = 0,15\Omega$ $jX_A = 0,15\Omega$ / $R_N = 0,01\Omega$ $jX_N = 0,01\Omega$ ( $R_n$ and $jX_n$ only for line to line three-phase units used!)

<b>Flicker for rated currents <math>\leq 75\text{A}</math> to DIN EN 61000-3-3 (VDE 0838-3)</b>				
<b>Assessment criterion:</b>				
Long-term flicker strength: $P_{lt} \leq 0,5$				
Grid impedance angle $\psi_k$	<input checked="" type="checkbox"/> $32^\circ$ or <input type="checkbox"/> $45$			
Flicker coefficient $c(\psi_k)$	23,330			
<b>Note:</b>				
The test results of the <b>WVC-800</b> can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.				
<b>b) Flicker to DIN EN 61000-3-3 (VDE 0838-3) for generator units <math>\leq 75\text{ A}</math></b>				N/A
Adherence to the thresholds for flicker must be verified as followed:				
<ul style="list-style-type: none"> <li>- For PGUs (power generation units) and PSUs (power supply units) intended for PGSs (power generation systems) with nominal currents <math>&gt; 75\text{ A}</math>, the measurements must be conducted as in 5.2.3.2.</li> </ul>				
<b>Test conditions:</b>				
Voltage: $86\% U_n$ to $109\% U_n$				
Frequency: $50\text{ Hz} \pm 0,5\%$				
THD of the voltage supply: $\leq 3\%$				
Voltage rises of the PGU at $100\% P_{E_{max}}$ : $\leq 3\%$				
<b>Assessment criterion:</b>				
Long-term flicker strength: $P_{lt} \leq 0,5$				
<b>Test result:</b>				
<b>Flicker for rated currents <math>&gt; 75\text{A}</math> (at SCR = 20) (Calculation Flickermeter according to TG3)</b>				
Rated Output voltage [V]	--			
Grid impedance angle $\psi_k$ [ $^\circ$ ]	30	50	70	85
Flicker coefficient $c(\psi_k)$ [1]	--	--	--	--
Short-term Flicker $P_{st}$ [1]	--	--	--	--
Flicker step factor $k(f\psi_k)$ [1]	--	--	--	--
Voltage changes factor $k(u\psi_k)$ [1]	--	--	--	--

5.2.4 Harmonics and interharmonics							P
5.2.4.1 a) Harmonics test							
EUT		Selection of limits					
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>		
1-phase	3-phase	Equipment with input current $\leq 16$ A per phase		Equipment with input current $>16$ A and $\leq 75$ A per phase		Equipment with input current $>75$ A per phase	
WVC-800		IEC EN 61000-3-2		IEC EN 61000-3-12			
Phase	L1	L2	L3	/			
Power Level	33%	33%	33%				
AC Power [W]	265	--	--				
AC Voltage [V]	230,40	--	--				
AC Current [A]	1,15	--	--				
Frequency [Hz]	50,00	--	--				
Harmonic	Measured value $I_h$ [A]			Measured value $I_h$ [%I <sub>1</sub> ]			Limits [A] IEC EN 61000-3-2
	L1	L2	L3	L1	L2	L3	
1st	1,150	--	--	--	--	--	--
2nd	0,005	--	--	0,447	--	--	1,080
3rd	0,043	--	--	3,752	--	--	2,300
4th	0,003	--	--	0,282	--	--	0,430
5th	0,011	--	--	0,938	--	--	1,140
6th	0,002	--	--	0,181	--	--	0,300
7th	0,019	--	--	1,668	--	--	0,770
8th	0,002	--	--	0,153	--	--	0,263
9th	0,005	--	--	0,428	--	--	0,400
10th	0,001	--	--	0,123	--	--	0,184
11th	0,008	--	--	0,689	--	--	0,330
12th	0,001	--	--	0,092	--	--	0,153
13th	0,017	--	--	1,498	--	--	0,210
14th	0,001	--	--	0,084	--	--	0,131
15th	0,026	--	--	2,223	--	--	0,150
16th	0,001	--	--	0,077	--	--	0,115
17th	0,025	--	--	2,194	--	--	0,132
18th	0,001	--	--	0,071	--	--	0,102
19th	0,023	--	--	1,991	--	--	0,188
20th	0,001	--	--	0,079	--	--	0,092
21th	0,018	--	--	1,581	--	--	0,107
22th	0,001	--	--	0,076	--	--	0,084
23th	0,010	--	--	0,880	--	--	0,098
24th	0,001	--	--	0,074	--	--	0,077
25th	0,003	--	--	0,235	--	--	0,090
26th	0,001	--	--	0,076	--	--	0,071

27th	0,004	--	--	0,305	--	--	0,080
28th	0,001	--	--	0,075	--	--	0,066
29th	0,009	--	--	0,782	--	--	0,078
30th	0,001	--	--	0,078	--	--	0,061
31th	0,012	--	--	1,016	--	--	0,073
32th	0,001	--	--	0,077	--	--	0,057
33th	0,011	--	--	0,938	--	--	0,068
34th	0,001	--	--	0,074	--	--	0,054
35th	0,009	--	--	0,814	--	--	0,064
36th	0,001	--	--	0,083	--	--	0,051
37th	0,008	--	--	0,653	--	--	0,061
38th	0,001	--	--	0,072	--	--	0,048
39th	0,005	--	--	0,403	--	--	0,058
40th	0,001	--	--	0,071	--	--	0,046
<b>THD [%]</b>	--	--	--	0,447	--	--	--
<b>Phase</b>	<b>L1</b>		<b>L2</b>		<b>L3</b>		
<b>Power Level</b>	66%		66%		66%		
<b>AC Power [W]</b>	534		--		--		
<b>AC Voltage [V]</b>	230,0		--		--		
<b>AC Current [A]</b>	2,322		--		--		
<b>Frequency [Hz]</b>	50,00		--		--		
<b>Harmonic</b>	<b>Measured value <math>I_h</math> [A]</b>			<b>Measured value <math>I_h</math> [%<math>I_1</math>]</b>			<b>Limits [A]</b>
	<b>L1</b>	<b>L2</b>	<b>L3</b>	<b>L1</b>	<b>L2</b>	<b>L3</b>	IEC EN 61000-3-2
1st	2,322	--	--	--	--	--	--
2nd	0,011	--	--	0,471	--	--	1,080
3rd	0,098	--	--	4,224	--	--	2,300
4th	0,006	--	--	0,271	--	--	0,430
5th	0,010	--	--	0,431	--	--	1,140
6th	0,004	--	--	0,153	--	--	0,300
7th	0,036	--	--	1,535	--	--	0,770
8th	0,003	--	--	0,141	--	--	0,263
9th	0,031	--	--	1,344	--	--	0,400
10th	0,003	--	--	0,109	--	--	0,184
11th	0,018	--	--	0,776	--	--	0,330
12th	0,002	--	--	0,067	--	--	0,153
13th	0,012	--	--	0,527	--	--	0,210
14th	0,002	--	--	0,066	--	--	0,131
15th	0,023	--	--	0,974	--	--	0,150
16th	0,001	--	--	0,059	--	--	0,115
17th	0,023	--	--	1,005	--	--	0,132
18th	0,001	--	--	0,052	--	--	0,102
19th	0,024	--	--	1,014	--	--	0,188

20th	0,001	--	--	0,060	--	--	0,092
21th	0,021	--	--	0,917	--	--	0,107
22th	0,001	--	--	0,052	--	--	0,084
23th	0,014	--	--	0,597	--	--	0,098
24th	0,001	--	--	0,050	--	--	0,077
25th	0,007	--	--	0,291	--	--	0,090
26th	0,001	--	--	0,052	--	--	0,071
27th	0,005	--	--	0,217	--	--	0,080
28th	0,001	--	--	0,049	--	--	0,066
29th	0,010	--	--	0,418	--	--	0,078
30th	0,001	--	--	0,053	--	--	0,061
31th	0,011	--	--	0,487	--	--	0,073
32th	0,001	--	--	0,055	--	--	0,057
33th	0,009	--	--	0,381	--	--	0,068
34th	0,001	--	--	0,053	--	--	0,054
35th	0,007	--	--	0,307	--	--	0,064
36th	0,001	--	--	0,055	--	--	0,051
37th	0,006	--	--	0,268	--	--	0,061
38th	0,001	--	--	0,053	--	--	0,048
39th	0,007	--	--	0,316	--	--	0,058
40th	0,001	--	--	0,050	--	--	0,046
<b>THD [%]</b>	--	--	--	3,376	--	--	--

<b>Phase</b>	<b>L1</b>	<b>L2</b>	<b>L3</b>	/
<b>Power Level</b>	<b>100%</b>	<b>100%</b>	<b>100%</b>	
<b>AC Power [W]</b>	794	--	--	
<b>AC Voltage [V]</b>	230,0	--	--	
<b>AC Current [A]</b>	3,450	--	--	
<b>Frequency [Hz]</b>	50,00	--	--	

Harmonic	Measured value $I_h$ [A]			Measured value $I_h$ [%I <sub>1</sub> ]			Limits [A] IEC EN 61000-3-2
	L1	L2	L3	L1	L2	L3	
1st	3,450	--	--	--	--	--	--
2nd	0,016	--	--	0,461	--	--	1,080
3rd	0,129	--	--	3,737	--	--	2,300
4th	0,007	--	--	0,212	--	--	0,430
5th	0,081	--	--	2,339	--	--	1,140
6th	0,005	--	--	0,138	--	--	0,300
7th	0,084	--	--	2,439	--	--	0,770
8th	0,005	--	--	0,145	--	--	0,263
9th	0,056	--	--	1,620	--	--	0,400
10th	0,003	--	--	0,076	--	--	0,184
11th	0,026	--	--	0,743	--	--	0,330
12th	0,002	--	--	0,061	--	--	0,153

13th	0,002	--	--	0,072	--	--	0,210
14th	0,002	--	--	0,058	--	--	0,131
15th	0,034	--	--	0,975	--	--	0,150
16th	0,001	--	--	0,039	--	--	0,115
17th	0,030	--	--	0,881	--	--	0,132
18th	0,002	--	--	0,047	--	--	0,102
19th	0,030	--	--	0,859	--	--	0,188
20th	0,001	--	--	0,043	--	--	0,092
21th	0,022	--	--	0,646	--	--	0,107
22th	0,001	--	--	0,039	--	--	0,084
23th	0,013	--	--	0,387	--	--	0,098
24th	0,002	--	--	0,044	--	--	0,077
25th	0,011	--	--	0,317	--	--	0,090
26th	0,001	--	--	0,037	--	--	0,071
27th	0,019	--	--	0,551	--	--	0,080
28th	0,001	--	--	0,036	--	--	0,066
29th	0,031	--	--	0,907	--	--	0,078
30th	0,001	--	--	0,042	--	--	0,061
31th	0,037	--	--	1,066	--	--	0,073
32th	0,001	--	--	0,037	--	--	0,057
33th	0,036	--	--	1,053	--	--	0,068
34th	0,001	--	--	0,037	--	--	0,054
35th	0,035	--	--	1,008	--	--	0,064
36th	0,001	--	--	0,040	--	--	0,051
37th	0,030	--	--	0,876	--	--	0,061
38th	0,001	--	--	0,035	--	--	0,048
39th	0,024	--	--	0,695	--	--	0,058
40th	0,001	--	--	0,035	--	--	0,046
<b>THD [%]</b>	--	--	--	2,043	--	--	--

PV-curve simulated according to	
Voltage of defined MPP [V]	42
Current of defined MPP [A]	20,7
FFU of PV curve [1]	--
Impedance [ $\Omega$ ]	Line $R_A = 0,24 \text{ j}X_A = 0,15$ Neutral $R_N = 0,16 \text{ j}X_N = 0,10$

**Note:**

The test results of the **WVC-800** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.

5.2.4.1 b) Test Harmonics DIN EN 61000-4-7 ( $\geq 75$ A per Phase)											P
Harmonics											
P/ P <sub>RE</sub> [%]	5	10	20	30	40	50	60	70	80	90	100
Order	I <sub>h</sub> [%]										
1	6,599	11,910	22,551	33,204	43,639	53,851	63,856	73,490	81,834	92,510	99,130
2	0,127	0,067	0,112	0,157	0,190	0,240	0,302	0,376	0,411	0,450	0,486
3	1,039	0,242	0,777	1,211	1,739	2,256	2,718	3,204	2,688	2,528	0,891
4	0,034	0,046	0,066	0,094	0,123	0,148	0,176	0,210	0,173	0,207	0,206
5	1,236	0,715	0,379	0,326	0,265	0,207	0,199	0,231	0,758	1,801	2,252
6	0,042	0,039	0,047	0,054	0,070	0,082	0,091	0,116	0,102	0,165	0,140
7	1,129	0,861	0,428	0,574	0,759	0,899	1,002	1,027	0,971	1,589	2,444
8	0,057	0,030	0,043	0,056	0,066	0,078	0,094	0,108	0,119	0,144	0,146
9	0,802	0,741	0,293	0,136	0,424	0,666	0,873	1,083	1,315	1,160	1,684
10	0,048	0,028	0,035	0,042	0,051	0,059	0,068	0,077	0,089	0,073	0,069
11	0,529	0,570	0,493	0,226	0,232	0,382	0,525	0,651	0,899	0,617	0,807
12	0,042	0,025	0,027	0,029	0,034	0,038	0,041	0,045	0,049	0,048	0,064
13	0,626	0,434	0,647	0,501	0,408	0,376	0,382	0,360	0,428	0,446	0,054
14	0,051	0,025	0,027	0,029	0,031	0,036	0,041	0,048	0,051	0,064	0,060
15	0,534	0,433	0,725	0,745	0,698	0,670	0,661	0,660	0,670	0,933	0,909
16	0,043	0,024	0,025	0,027	0,028	0,031	0,034	0,041	0,044	0,052	0,036
17	0,358	0,390	0,587	0,734	0,726	0,706	0,690	0,660	0,688	0,949	0,843
18	0,037	0,024	0,024	0,023	0,025	0,028	0,030	0,034	0,034	0,032	0,048
19	0,353	0,333	0,388	0,664	0,715	0,716	0,705	0,669	0,654	0,852	0,852
20	0,043	0,024	0,025	0,026	0,028	0,031	0,036	0,045	0,045	0,041	0,044
21	0,380	0,304	0,210	0,526	0,634	0,661	0,650	0,581	0,549	0,647	0,665
22	0,041	0,024	0,024	0,025	0,026	0,028	0,030	0,036	0,037	0,040	0,037
23	0,296	0,292	0,169	0,293	0,422	0,458	0,438	0,359	0,294	0,288	0,418
24	0,039	0,023	0,024	0,025	0,025	0,026	0,029	0,034	0,034	0,039	0,045
25	0,234	0,251	0,249	0,077	0,212	0,249	0,225	0,155	0,114	0,159	0,310
26	0,039	0,023	0,023	0,024	0,024	0,026	0,030	0,037	0,038	0,034	0,036
27	0,261	0,182	0,305	0,105	0,056	0,113	0,128	0,174	0,230	0,374	0,511
28	0,039	0,023	0,023	0,025	0,024	0,025	0,027	0,032	0,034	0,033	0,036
29	0,237	0,145	0,333	0,267	0,130	0,133	0,217	0,347	0,423	0,688	0,855
30	0,039	0,023	0,023	0,025	0,025	0,026	0,030	0,038	0,036	0,042	0,042
31	0,167	0,166	0,270	0,346	0,228	0,188	0,260	0,409	0,533	0,811	1,016
32	0,035	0,023	0,023	0,025	0,025	0,026	0,030	0,038	0,039	0,037	0,035
33	0,158	0,170	0,151	0,323	0,228	0,155	0,196	0,332	0,423	0,798	1,011
34	0,035	0,023	0,023	0,025	0,024	0,026	0,028	0,035	0,036	0,032	0,034
35	0,168	0,142	0,042	0,281	0,226	0,146	0,156	0,283	0,399	0,746	0,975
36	0,040	0,026	0,025	0,027	0,027	0,027	0,031	0,039	0,038	0,037	0,039
37	0,134	0,099	0,098	0,225	0,252	0,196	0,162	0,213	0,296	0,667	0,843
38	0,032	0,023	0,022	0,023	0,024	0,026	0,028	0,035	0,037	0,035	0,034
39	0,103	0,088	0,201	0,140	0,261	0,260	0,226	0,170	0,208	0,543	0,664
40	0,034	0,024	0,023	0,023	0,023	0,025	0,027	0,033	0,033	0,032	0,034
THC [%]	2,511	1,798	1,793	2,152	2,569	3,028	3,482	3,966	3,802	4,542	4,879
THDU40 [%]	0,104	0,067	0,066	0,068	0,070	0,071	0,079	0,083	0,086	0,088	0,049



5.2.4.1 b) Test Harmonics DIN EN 61000-4-7 ( $\geq 75$ A per Phase)											P
Interharmonics											
Test result:											
P/P <sub>FE</sub> [%]	5	10	20	30	40	50	60	70	80	90	100
f [Hz]	I <sub>h</sub> [%]										
75	0,109	0,051	0,056	0,063	0,065	0,068	0,075	0,081	0,085	0,091	0,079
125	0,108	0,048	0,050	0,054	0,053	0,054	0,057	0,061	0,063	0,062	0,059
175	0,108	0,044	0,048	0,052	0,053	0,054	0,058	0,062	0,063	0,064	0,060
225	0,107	0,043	0,047	0,050	0,050	0,051	0,054	0,058	0,060	0,060	0,056
275	0,106	0,041	0,043	0,047	0,048	0,049	0,055	0,058	0,059	0,060	0,060
325	0,108	0,040	0,042	0,044	0,046	0,048	0,051	0,056	0,056	0,057	0,054
375	0,106	0,040	0,041	0,043	0,045	0,047	0,052	0,056	0,056	0,057	0,056
425	0,108	0,039	0,040	0,041	0,042	0,045	0,048	0,053	0,052	0,052	0,052
475	0,106	0,039	0,039	0,040	0,042	0,044	0,048	0,053	0,053	0,052	0,052
525	0,106	0,039	0,038	0,038	0,039	0,041	0,045	0,051	0,050	0,050	0,051
575	0,106	0,037	0,037	0,038	0,039	0,041	0,044	0,049	0,050	0,049	0,050
625	0,176	0,036	0,037	0,037	0,038	0,039	0,043	0,048	0,047	0,047	0,049
675	0,105	0,036	0,037	0,036	0,037	0,039	0,042	0,048	0,048	0,047	0,049
725	0,104	0,036	0,037	0,035	0,036	0,038	0,042	0,046	0,046	0,045	0,048
775	0,105	0,035	0,037	0,036	0,036	0,038	0,041	0,047	0,047	0,045	0,048
825	0,105	0,036	0,037	0,035	0,035	0,037	0,041	0,046	0,045	0,044	0,047
875	0,104	0,035	0,037	0,036	0,036	0,038	0,040	0,047	0,046	0,044	0,047
925	0,103	0,036	0,037	0,036	0,036	0,037	0,040	0,046	0,045	0,043	0,048
975	0,102	0,036	0,036	0,036	0,036	0,038	0,040	0,047	0,046	0,044	0,047
1025	0,102	0,036	0,037	0,036	0,036	0,037	0,040	0,047	0,046	0,044	0,047
1075	0,102	0,036	0,036	0,036	0,037	0,038	0,040	0,047	0,047	0,043	0,047
1125	0,099	0,036	0,036	0,037	0,036	0,037	0,039	0,046	0,047	0,044	0,047
1175	0,100	0,036	0,035	0,036	0,036	0,037	0,041	0,047	0,047	0,044	0,047
1225	0,100	0,035	0,036	0,037	0,037	0,037	0,040	0,047	0,048	0,045	0,047
1275	0,100	0,035	0,036	0,037	0,037	0,037	0,041	0,048	0,048	0,044	0,047
1325	0,099	0,035	0,036	0,037	0,036	0,037	0,041	0,048	0,049	0,045	0,048
1375	0,100	0,034	0,036	0,038	0,037	0,037	0,041	0,048	0,049	0,044	0,047
1425	0,098	0,035	0,037	0,038	0,036	0,037	0,040	0,049	0,050	0,045	0,047
1475	0,097	0,034	0,036	0,039	0,039	0,038	0,042	0,050	0,053	0,047	0,050
1525	0,098	0,035	0,036	0,037	0,037	0,037	0,042	0,051	0,051	0,045	0,048
1575	0,097	0,034	0,036	0,038	0,038	0,038	0,041	0,051	0,052	0,048	0,050
1625	0,095	0,035	0,036	0,038	0,037	0,037	0,042	0,051	0,051	0,045	0,048
1675	0,095	0,036	0,035	0,039	0,039	0,039	0,042	0,050	0,053	0,053	0,050
1725	0,100	0,036	0,036	0,038	0,037	0,037	0,041	0,049	0,050	0,044	0,048
1775	0,096	0,036	0,035	0,037	0,037	0,038	0,041	0,049	0,052	0,046	0,049
1825	0,092	0,036	0,036	0,037	0,037	0,037	0,041	0,050	0,050	0,045	0,048
1875	0,092	0,035	0,035	0,037	0,038	0,038	0,041	0,049	0,052	0,048	0,048
1925	0,093	0,035	0,037	0,036	0,037	0,038	0,040	0,048	0,049	0,044	0,048
1975	0,092	0,035	0,036	0,036	0,037	0,038	0,041	0,048	0,052	0,045	0,048

Higher Frequencies											
Test result:											
P/P <sub>rE</sub> [%]	5	10	20	30	40	50	60	70	80	90	100
f [kHz]	I <sub>h</sub> [%]										
2,1	0,247	0,156	0,336	0,139	0,345	0,415	0,403	0,303	0,262	0,612	0,718
2,3	0,218	0,128	0,246	0,196	0,262	0,390	0,423	0,340	0,253	0,406	0,481
2,5	0,200	0,121	0,157	0,213	0,153	0,272	0,329	0,280	0,209	0,212	0,273
2,7	0,174	0,118	0,216	0,186	0,120	0,183	0,264	0,273	0,273	0,315	0,327
2,9	0,148	0,215	0,250	0,182	0,200	0,421	0,964	1,169	1,402	1,626	1,538
3,1	0,110	1,073	1,413	1,793	2,340	3,389	5,345	6,623	7,571	8,424	8,644
3,3	0,076	1,175	1,475	1,924	2,482	2,610	1,392	1,589	1,535	1,206	1,236
3,5	0,051	0,300	0,325	0,338	0,397	0,395	0,362	0,417	0,487	0,583	0,638
3,7	0,033	0,184	0,208	0,216	0,332	0,325	0,335	0,390	0,402	0,502	0,606
3,9	0,023	0,135	0,159	0,192	0,272	0,320	0,335	0,378	0,401	0,487	0,587
4,1	0,015	0,160	0,170	0,230	0,205	0,287	0,295	0,314	0,341	0,412	0,484
4,3	0,011	0,155	0,141	0,209	0,144	0,208	0,219	0,214	0,235	0,292	0,323
4,5	0,008	0,159	0,140	0,144	0,127	0,132	0,146	0,138	0,154	0,196	0,215
4,7	0,006	0,154	0,165	0,119	0,125	0,128	0,137	0,160	0,186	0,235	0,283
4,9	0,006	0,140	0,153	0,177	0,148	0,191	0,212	0,243	0,276	0,355	0,426
5,1	0,000	0,144	0,144	0,225	0,201	0,251	0,287	0,317	0,358	0,473	0,560
5,3	0,006	0,142	0,173	0,222	0,239	0,269	0,313	0,342	0,382	0,536	0,633
5,5	0,007	0,132	0,172	0,184	0,250	0,260	0,298	0,313	0,345	0,524	0,621
5,7	0,007	0,136	0,129	0,128	0,217	0,226	0,248	0,250	0,269	0,459	0,543
5,9	0,009	0,125	0,112	0,107	0,156	0,173	0,181	0,172	0,196	0,369	0,432
6,1	0,010	0,121	0,120	0,119	0,116	0,133	0,140	0,147	0,203	0,326	0,366
6,3	0,013	0,124	0,126	0,121	0,151	0,148	0,146	0,183	0,254	0,371	0,362
6,5	0,014	0,117	0,124	0,125	0,201	0,229	0,220	0,226	0,289	0,487	0,474
6,7	0,016	0,119	0,113	0,167	0,195	0,274	0,263	0,225	0,287	0,593	0,621
6,9	0,019	0,112	0,121	0,229	0,149	0,275	0,294	0,208	0,256	0,632	0,714
7,1	0,021	0,105	0,126	0,269	0,118	0,243	0,304	0,196	0,210	0,608	0,726
7,3	0,024	0,102	0,112	0,273	0,158	0,199	0,292	0,204	0,174	0,528	0,651
7,5	0,024	0,096	0,106	0,244	0,247	0,168	0,280	0,226	0,177	0,444	0,545
7,7	0,024	0,093	0,108	0,183	0,343	0,156	0,274	0,252	0,210	0,430	0,502
7,9	0,022	0,091	0,100	0,159	0,370	0,177	0,267	0,284	0,251	0,461	0,581
8,1	0,018	0,090	0,094	0,114	0,262	0,244	0,242	0,320	0,282	0,446	0,684
8,3	0,016	0,089	0,092	0,133	0,128	0,304	0,191	0,356	0,318	0,348	0,685
8,5	0,015	0,090	0,094	0,124	0,198	0,291	0,148	0,381	0,383	0,232	0,542
8,7	0,012	0,091	0,101	0,137	0,175	0,178	0,228	0,363	0,465	0,287	0,334
8,9	0,010	0,093	0,116	0,146	0,171	0,212	0,322	0,273	0,492	0,438	0,345
PV-curve simulated according to											
Voltage of defined MPP [V]						42					
Current of defined MPP [A]						20,7					
FFU of PV curve [1]						--					
Impedance [Ω]											
Line						R <sub>A</sub> = 0,24 jX <sub>A</sub> = 0,15					

**Higher Frequencies**

Neutral

$$R_N = 0,16 \text{ } jX_N = 0,10$$

**Note:**

The normalization current is 3,48A.

The currents of the harmonics measured according to DIN EN 61000-4-7 (VDE 0847-4-7): 2009-12, 5.6;

The currents of the interharmonics measured accordance with DIN EN 61000-4-7 (VDE 0817-4-7), Annex A;

The measurements of higher-frequency harmonic currents between 2 kHz and 9 kHz must be conducted in line with DIN EN 61000-4-7 (VDE 0847-4-7), Annex B.

The test results of the **WVC-800** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.

5.2.5 Commutation	N/A
<p>This test serves to determine the commutation currents, the project - specific identification and assessment of the</p> <p>Commutation voltage dips according to VDE-AR-N 4100: 2020-06, 5.4.4.5 is required taking into account the short-circuit power at the point of connection.</p> <ul style="list-style-type: none"><li>- This check is only required for mains-controlled inverters.</li></ul>	


<b>5.2.6 Feed in of DC current</b>	<b>P</b>
------------------------------------	----------

**Test procedural:**  
 The inverter must be used in the adjustment range Test1, Test2 and Test 3.  
 Each test point shall be held for min 5 minutes and  $I_{AC}$ ,  $U_{AC}$ ,  $I_{dc}$  in AC of each phase has to be recorded.  
 Measurement of  $I_{dc}$  in AC must be done according to VDE AR-N 4100:2020-06 based on DIN EN 61000-4-7 (VDE-0847-4-7) over 10 fundamental periods.

**Assessment criterion:**  
 An inverter must not feed more than 0,5% of its rated current  $I_r$  or a maximum of 20 mA (the higher value is to be selected) as direct current.

Power Level [% of $V_{Ar}$ ]	30% $S_{E_{max}}$ to 40% $S_{E_{max}}$	60% $S_{E_{max}}$ to 70% $S_{E_{max}}$	>95% $S_{E_{max}}$
AC Power [VA]	265	534	794
AC Voltage [V]	229,99	229,99	230,01
AC Current [A]	1,150	2,322	3,450
Max. DC Current in AC [mA]	7	13	16
Max. DC Current in AC [% of $I_r$ ]	0,21	0,38	0,46
Average. DC Current in AC [mA]	6	10	8
Average. DC Current in AC [% of $I_r$ ]	0,17	0,27	0,23

**Graphs**



**Note:**  
 The test results of the **WVC-800** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.

<b>5.3 Evidence of symmetry behaviour of inverters</b>	<b>N/A</b>
<b>5.3.1 General</b>	<b>N/A</b>
<p>These tests serve to prove the requirements according to VDE-AR-N 4100: 2020-06, 5.5: These tests are not applicable for direct connected rotating machines! This test is necessary only for electronic inverters!</p>	
<p><b>Note:</b> The tests of the “symmetry characteristics of three-phase inverter modules” were performed on the unit with the highest output power. Here is the maximum asymmetry given.</p>	

5.3.2.1 Calculation of asymmetry	N/A
<b>Test procedural:</b> The maximum absolute difference between the apparent powers of the three phases is determined for each of the five measurements (1-min means) in the respective operating point. The maximum of these five values is again determined.	
<b>Assessment criterion:</b> The test is passed if the maximum value from the above measurements does not exceed 5 % $S_{E_{max}}$ and $\leq 4600$ VA.	
<b>Note:</b> The maximum inductive and capacitive values are specified by the manufacturer.	

**5.4 Evidence of the behaviour of the generating unit on the network**
**5.4.1 General**

(These tests are designed to provide evidence that the requirements of VDE-AR-N 4105:2018-11, 5.7.2.2 are met and to determine the values for  $S_{E_{max}}$  and  $P_{E_{max}}$ )

**P**
**Test Condition:**

The measurements were performed in the testing laboratory at the grid-simulator.

Test voltage between  $0,9 U_n$  and  $1,09 U_n$  with  $\pm 2\% U_n$  until the test

Test frequency:  $50\text{Hz} \pm 0,5\%$

**Note:**

If an examination is required for any other requirements, these apply to this test.



<b>5.4.2 Measurement of the active power and reactive power range</b> (These tests are designed to provide evidence that the requirements of VDE-AR-N 4105:2018-11, 5.7.2.2 are met)	<b>P</b>
---	----------

**Test:**

The setpoint signal must be reduced from 100% to 10%  $P_{rE}$ :

For adjustable PGUs in increments of 10%  $P_{rE}$  1 minute must elapse after every change to the setpoint setting so that the PGU can settle at the new setpoint. Then the active power of the PGU must be measured as a 1-min mean value.

**Assessment criterion:**

a) for adjustable PGUs:

- no network disconnection
- the active power value does not exceed the setpoint by more than  $\pm 5\% P_{rE}$
- the setting time determined this way is  $\leq 1\text{min}$

**Note:**

The setting time is  $\leq 1\text{min}$ . See "Graph of the setting accuracy".

<b>Setting values</b>	cos $\varphi = 1$ :	1,00
	cos $\varphi$ over-excited:	0,95
	cos $\varphi$ under-excited:	0,95

**Test:**

600s mean value	U [V]	P <sub>E<sub>max</sub>600 c)</sub> [W]	S <sub>E<sub>max</sub>600 c)</sub> [VA]	COS $\varphi_{E_{max}600}$ [-]
<b>0,90 U<sub>n</sub> at 100% P<sub>E<sub>max</sub></sub></b>				
cos $\varphi = 1$	207,0	787	787	0,999
cos $\varphi$ max. over-excited	207,0	776	816	0,950
<b>0,95 U<sub>n</sub> at 100% P<sub>E<sub>max</sub></sub></b>				
cos $\varphi$ max. under-excited	218,5	787	827	0,951
<b>1,0 U<sub>n</sub> at 100% P<sub>E<sub>max</sub></sub></b>				
cos $\varphi = 1$	230,0	802	802	0,999
cos $\varphi$ max. under-excited	230,0	794	836	0,950
cos $\varphi$ max. over-excited	230,0	792	832	0,952
<b>1,05 U<sub>n</sub> at 100% P<sub>E<sub>max</sub></sub></b>				
cos $\varphi$ max. over-excited	241,5	799	841	0,950
<b>1,09 U<sub>n</sub> at 100% P<sub>E<sub>max</sub></sub></b>				
cos $\varphi = 1$	250,7	814	814	0,999
cos $\varphi$ max. under-excited	250,7	806	848	0,950
<b>S<sub>E<sub>max</sub>600</sub> and P<sub>E<sub>max</sub>600</sub></b>				
S <sub>E<sub>max</sub>600</sub> = max(S <sub>E<sub>max</sub>600 a)</sub> , S <sub>E<sub>max</sub>600 b)</sub> , S <sub>E<sub>max</sub>600 c)</sub> ) [VA]		848		
P <sub>E<sub>max</sub>600</sub> = max (P <sub>E<sub>max</sub>600 a)</sub> , P <sub>E<sub>max</sub>600 b)</sub> , P <sub>E<sub>max</sub>600 c)</sub> ) [W]		814		

**Note:**

The test results of the **WVC-800** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.

<b>5.4.3 Measurement of setting accuracy</b>	<b>P</b>
--	----------

Test procedural:

The P setpoint was set by SW-Tool using RS485-interface.

(The active power can be set between 100%P<sub>n</sub> and 10%P<sub>n</sub> with a step size of 10%P<sub>n</sub>)


Assessment:

- no network disconnection occurs and
- the active power value does not deviate by more than 5% P<sub>rE</sub> from the target value.

% of rated capability	Setpoint		Measured value		Deviation (P <sub>meas</sub> - P <sub>set</sub> )		Limit ΔP <sub>E60</sub> in %
	[W]	[%P <sub>n</sub> ]	[W]	[%P <sub>n</sub> ]	[W]	[%P <sub>n</sub> ]	
100	800	100	793	99,1	7	-0,9	≤ ±5% of P <sub>rE</sub>
90	720	90	740	92,4	-20	2,4	
80	640	80	654	81,7	-14	1,7	
70	560	70	587	73,4	-27	3,4	
60	480	60	510	63,7	-30	3,7	
50	400	50	430	53,7	-30	3,7	
40	320	40	348	43,5	-28	3,5	
30	240	30	264	33,0	-24	3,0	
20	160	20	178	22,2	-18	2,2	
10	80	10	90	11,3	-10	1,3	

<b>Overall maximum active power deviation to set point [%P<sub>n</sub>]:</b>	3,7
--	-----

**Graph of the setting accuracy:**



**5.4.3.4 Measurement of the power gradient**
**P**

Test procedural:

The P setpoint was set by SW-Tool using RS485-interface.

The measurement of the power gradient takes place:

- Via a setpoint change from 100% to 5% of the rated effective power  $P_{rE}$  at time  $t_0$ . If the technical performance is  $>5\%$ , this should be specified.
- Via a setpoint change from 5% to 100% of the rated effective power  $P_{rE}$  at time  $t_0$ . Is the technical Performance  $>5\%$ , this should be specified?

Assessment:


- no network disconnection occurs and
- the power gradients determined in accordance with 5.4.3.4 shall not fall below  $0,33\% P_{rE}$  and shall not exceed  $0,66\% P_{rE}$ .
- The first gradient is to be formed 30 s after setting the setpoint jump.
- The formation of gradients is terminated 30 s before reaching the stationary final value.

Note:

 The test results of the **WVC-800** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.


**Verification the setting Power gradient change from  $100\%P_{rE}$  to  $5\%P_{rE}$** 

P_setting point step	Setting value	Measured value
$P_{\text{before power change}} = 100\% P_{rE} \pm 5\% P_{rE}$	100,0% $P_{rE}$	98,94% $P_{rE}$
Power gradient (during power change):	0,5 % $P_{rE} / s$	0,52% $P_{rE} / s$
$P_{\text{after power change}} = 5\% P_{rE} \pm 5\% P_{rE}$	5,0% $P_{rE}$	5,10% $P_{rE}$

**Graph of the gradient  $100\%$  to  $<5\% P_{rE}$** 

**Verification the setting Power gradient change from  $5\%$  to  $100\%$** 

P_setting point step	Setting value	Measured value
----------------------	---------------	----------------

$P_{\text{before power change}} = 5\% P_{rE} \pm 5\% P_{rE}$	5,0% $P_{rE}$	5,51% $P_{rE}$
Power gradient (during power change):	0,5 % $P_{rE}$ / s	0,54% $P_{rE}$ /s
$P_{\text{after power change}} = 100\% P_{rE} \pm 5\% P_{rE}$	100,0 % $P_{rE}$	99,92% $P_{rE}$
Limit of power gradient [% $P_{rE}$ / s]:	0,33 to 0,66	
Inverter remains in operation?	<input checked="" type="checkbox"/> yes	
	<input type="checkbox"/> no	

**Graph of the gradient <5% to 100%  $P_{rE}$** 


<b>5.4.3.5 Measurement priority interfaces / energy management system</b>	<b>N/A</b>
<b>Test 1 (Measurement priority interfaces)</b>	
<b>Note:</b>	
The unit provides only one interface for active power reduction. Test omitted.	
<b>Test 2 (logical interface):</b>	
<b>Test steps</b>	
<ul style="list-style-type: none"> <li>a) the PGU is operated with no less than 90% <math>P_{rE}</math>;</li> <li>b) the change of state of the logic signal.</li> </ul>	
<b>Assessment:</b>	
<b>Test 1:</b>	
<ul style="list-style-type: none"> <li>a) The lowest setpoint is always given priority</li> <li>b) the setpoint at the interface programmed for the NSM is never exceeded</li> </ul>	
<b>Test 2:</b>	
<ul style="list-style-type: none"> <li>c) during the examination of the logical interface (input port), the active power feed of the EZE was completely terminated within a maximum of 5 s after the state change of the logical signal.</li> </ul>	
<b>Note:</b>	
The inverter has no related logic interface, but it can limit the inverter power output through APP/PC software.	

5.4.4 Active power feed-in for PGU's at overfrequency									P	
(These tests are designed to provide evidence that the requirements of VDE-AR-N 4105:2018-11 5.7.4.3. and VDE-AR-N 4105:2018-11 8.3.1. are met)										
<b>Test cycle for adjustable PGUs:</b>										
<b>Test 1:</b>										
1-min mean value:		Expected active power output [%P <sub>E<sub>max</sub></sub> ]:	Frequency [Hz]	P <sub>setpoint</sub> [W]	P <sub>E60</sub> [W]	P <sub>E60</sub> [%P <sub>E<sub>max</sub></sub> ]	ΔP <sub>E60</sub> [%P <sub>E<sub>max</sub></sub> ]	Limit [ΔP <sub>E60</sub> ] [%P <sub>E<sub>max</sub></sub> ]	Available DC-power [%]:	
No.	[Hz]									
<b>Measurement: 100% P<sub>E<sub>max</sub></sub>; start frequency 50,20Hz; droop s setting = 5% (40% P<sub>ref</sub>/Hz)</b>										
a)	50,00	100	50,00	800	792	99,02	-0,98	≤10	100	
b)	50,25	98	50,25	784	752	93,99	-4,01			
c)	50,70	80	50,70	640	637	79,60	-0,40			
d)	51,40	52	51,40	416	450	56,21	4,21			
e)	50,70	80	50,70	640	638	79,78	-0,22			
f)	50,25	98	50,25	784	754	94,20	-3,80			
g)	50,00	100	50,00	800	792	99,04	-0,96			
h)	51,65	0	51,65	0	0	-0,04	-0,04			
i)	50,15	0	50,15	0	0	-0,04	-0,04			
j)	50,00	100	50,00	800	794	99,15	-0,85			
<b>Frequency Step</b>				<b>Response time [s]</b>			<b>Settling time [s]</b>			
b) → c)				0,2			0,2			
c) → d)				0,4			0,4			
d) → e)				0,4			0,4			
e) → f)				0,4			0,4			
Initial time delay T <sub>v</sub> setting value [s]:					Initial time delay T <sub>v</sub> measured value (Determined during frequency step a) → b)) [s]:					
2					0,2					
<b>Test 2:</b>										
1-min mean value:		Expected active power output [%P <sub>E<sub>max</sub></sub> ]:	Frequency [Hz]	P <sub>setpoint</sub> [W]	P <sub>E60</sub> [W]	P <sub>E60</sub> [%P <sub>E<sub>max</sub></sub> ]	ΔP <sub>E60</sub> [%P <sub>E<sub>max</sub></sub> ]	Limit [ΔP <sub>E60</sub> ] [%P <sub>E<sub>max</sub></sub> ]	Available DC-power [%]:	
No.	[Hz]									
<b>Measurement: 60% P<sub>E<sub>max</sub></sub>; start frequency 50,50Hz; droop s setting = 12% (16,67% P<sub>ref</sub>/Hz)</b>										
a)	50,00	60	50,00	480	485	60,65	0,65	≤10	60	
b)	50,40	60	50,40	480	488	60,98	0,98			
c)	50,70	58	50,70	472	478	59,70	1,70			
d)	51,40	51	51,40	408	421	52,66	1,66		100	
e)	50,70	58	50,70	464	468	58,47	0,47			
f)	50,40	60 – 100	50,40	480	488	61,01	1,01			
g)	50,00	100	50,00	800	792	99,01	-0,99			

Frequency Step	Response time [s]	Settling time [s]
b) → c)	0,2	0,2
c) → d)	0,4	0,4
d) → e)	0,4	0,4
e) → f)	0,4	0,4
Initial time delay $T_V$ setting value [s]:	Initial time delay $T_V$ measured value (Determined during frequency step a) → b)) [s]:	
2,0	0,2	

**DC setting values:**

PV-curve simulated according to	
Voltage of defined MPP [V]	42
Current of defined MPP [A]	20,7
FFU of PV curve [1]	--

**Note:**

\* Results recorded at 1 minute after the transient process of power change completed.

According to VDE-AR-N 4105, DC-coupled storage systems are classified as Type 2 units. Therefore, the test specifications of section 5.4.4 Active power feed-in of PGU for over frequency are to be used for these.

The test results of the **WVC-800** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.

**Assessment criterion:**

The test is regarded as passed:

The active power reduces between measuring points in clause 5.4.5.1 a) to g) and j), the expected active power output, after settling, adjusts with a deviation  $\leq \pm 10\% P_{E_{max}}$ . Deviations arising from the fact that the maximum discharge capacity is less than  $P_{E_{max}}$  are permissible. In the measuring points h) and i) no active power may be delivered.


The initial time delay  $T_V$  of the frequency-dependent adaptation of the active power output  $\leq 2$  s.

The response time of the adaptation of the active power output is a maximum of 1s


the settling time of the adaptation of the active power output is a maximum time of 30 s (for type 1 units and for type 2 units with rotating machines) or respectively a maximum time of 20 s

The connection time at point j) is at least 60 s and the power is then increased with a gradient of  $\leq 10\% P_{E_{max}}/\text{min}$ .



**Graph Test 1 @ 100% P<sub>E</sub>max**



**Gradient Test 1**





**Graph Test2 @ 60% P<sub>Emax</sub>**

**Gradient Test 2**


5.4.6 Active power feed-in for PGUs at underfrequency									P
<b>Test cycle for adjustable PGUs:</b>									
<b>Test 1:</b>									
1-min mean value:		Expected active power output [% of $P_{E_{max}}$ ]:	Frequency [Hz]:	$P_{setpoint}$ [W]:	$P_{E60}$ [W]:	$P_{E60}$ [% of $P_{E_{max}}$ ]:	$\Delta P_{E60}$ [%]	Limit $\Delta P_{E60}$ in %	Available DC-power [%]:
No.	[Hz]								
<b>Measurement: -100% <math>P_{E_{max}}</math>; start frequency 49,80Hz; droop s setting = 2% (100% <math>P_{ref}/Hz</math>)</b>									
a)	50,00	10	50,00	80	100	12,49	2,49	≤10	100%
b)	49,75	12	49,75	96	106	13,23	1,23		
c)	48,80	50	48,80	400	432	53,99	3,99		
d)	47,60	98	47,60	784	773	96,62	-1,38		
e)	48,80	50	48,80	400	430	53,70	3,70		
f)	49,85	12	49,85	96	106	13,21	1,21		
g)	50,00	10	50,00	80	100	12,47	2,47		
h)	47,35	0	47,35	0	0	-0,04	-0,04		
i)	47,60	0	47,60	0	-1	-0,06	-0,06		
j)	50,00	10	50,00	80	100	12,50	2,50		
Frequency Step				Response time [s]				Settling time [s]	
b) → c)				0,2				0,2	
c) → d)				0,4				0,4	
d) → e)				0,4				0,4	
e) → f)				0,4				0,4	
Initial time delay $T_V$ setting value [s]:						Initial time delay $T_V$ measured value (Determined during frequency step a) → b)) [s]:			
2						0,2			

5.4.6 Active power feed-in for PGUs at underfrequency									P
<b>Test 2:</b>									
1-min mean value:		Expected active power output [% of $P_{E_{max}}$ ]:	Frequency [Hz]:	$P_{setpoint}$ [W]:	$P_{E60}$ [W]:	$P_{E60}$ [% of $P_{E_{max}}$ ]:	$\Delta P_{E60}$ [%]:	Limit $\Delta P_{E60}$ in %	Available DC-power [%]:
No.	[Hz]								
<b>Measurement: 10% <math>P_{E_{max}}</math>; start frequency 49,80Hz; droop s setting = 2% (100% <math>P_{ref}/Hz</math>)</b>									
a)	50,00	60	50,00	480	486	60,74	0,74	$\leq \pm 10\%$ of $P_{E_{max}}$	100
b)	49,75	62	49,75	496	535	66,88	4,88		
c)	49,20	84	49,20	672	688	85,97	1,97		
d)	48,80	100	48,80	800	785	98,14	-1,86		
e)	49,20	84	49,20	672	690	86,26	2,26		
f)	49,85	60	49,85	480	483	60,36	0,36		
g)	50,00	60	50,00	480	486	60,75	0,75		
Frequency Step				Response time [s]				Settling time [s]	
b) $\rightarrow$ c)				0,4				0,4	
c) $\rightarrow$ d)				0,4				0,4	
d) $\rightarrow$ e)				0,4				0,4	
e) $\rightarrow$ f)				0,4				0,4	
Initial time delay $T_V$ setting value [s]:						Initial time delay $T_V$ measured value (Determined during frequency step a) $\rightarrow$ b)) [s]:			
2						0,4			
<b>DC setting values:</b>									
PV-curve simulated according to									
Voltage of defined MPP [V]					42				
Current of defined MPP [A]					20,7				
FFU of PV curve [1]					--				

<b>5.4.6 Active power feed-in for PGUs at underfrequency</b>	<b>P</b>
--	----------


**Assessment criterion:**



The test is regarded as passed if the Storage system:

- The active power reduces between measuring points 5.4.7.1 a) and j), the expected active power output, after settling, adjusts with a deviation  $\leq \pm 10\% P_{Emax}$ . Deviations arising from the fact that the maximum discharge capacity is less than  $P_{Emax}$  are permissible. In the measuring points h) and i) no active power may be delivered.
- The initial time delay  $T_V$  of the frequency-dependent adaptation of the active power output  $\leq 2s$ .
- The response time of the adaptation of the active power output /-consumption is a maximum of 1s and.
- the settling time of the adaptation of the active power output /-consumption is a maximum time of 20s.
- The connection time at point j) is at least 60s and the power is then increased with a gradient of  $\leq \pm 10\% P_{Emax}/min$ .

**Note:**

The test results of the **WVC-800** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.

**Graph Test 1 @ 100%  $P_{Emax}$** 



**5.4.6 Active power feed-in for PGUs at underfrequency**
**P**
**Gradient Test 1**

**Graph Test2 @ 60% P<sub>Emax</sub>**


<b>5.4.8 Static voltage stability / reactive power supply</b>						
The test serves as verification of the reactive power mode according to VD-AR-N 4105: 2018-11, 5.7.2 of the PGU in normal operation.						
<b>5.4.8.2 Tests of the Reactive power / cos <math>\phi</math> setting accuracy</b>						<b>P</b>
Setting values	cos $\phi$ under-excited			0,95	0,98	
	cos $\phi$ over-excited			0,95	0,98	
<b>Test:</b>						
60 s mean value	0,9 U <sub>n</sub>		U <sub>n</sub>		1,1 U <sub>n</sub>	
Active power	40 – 60% P <sub>E60</sub>	S <sub>E60</sub>	40 – 60% P <sub>E60</sub>	S <sub>E60</sub>	40 – 60% P <sub>E60</sub>	S <sub>E60</sub>
<b>cos <math>\phi</math> 0,95 over-excited</b>						
U [V]	207,0	207,0	230,0	230,0	253,0	253
P <sub>E60</sub> [W]	409	766	414	765	408	761
Q <sub>E60</sub> [Var]	132	252	133	252	131	250
S <sub>E60</sub> [VA]	430	806	435	806	429	801
cos $\phi$ <sub>E60</sub> over-excited	0,952	0,950	0,952	0,950	0,952	0,950
Q <sub>expected</sub> [Var]	131	250	131	250	131	250
$\Delta$ Q <sub>E60</sub> [%]	0,00	0,28	0,22	0,27	-0,03	-0,02
<b>cos <math>\phi</math> 0,95 under-excited</b>						
U [V]	207,0	207,0	230,0	230,0	253,0	253,0
P <sub>E60</sub> [W]	409	768	414	764	408	768
Q <sub>E60</sub> [Var]	-125	-250	-125	-246	-123	-252
S <sub>E60</sub> [VA]	428	807	432	802	426	808
cos $\phi$ <sub>E60</sub> under-excited	0,957	0,951	0,958	0,952	0,957	0,950
Q <sub>expected</sub> [Var]	-131	-250	-131	-250	-131	-250
$\Delta$ Q <sub>E60</sub> [%]	0,84	-0,01	0,87	0,50	1,01	-0,24
<b>cos <math>\phi</math> 0,98 over-excited</b>						
U [V]	207,0	207,0	230,0	230,0	253,0	253,0
P <sub>E60</sub> [W]	411	784	415	791	410	792
Q <sub>E60</sub> [Var]	83	159	84	155	82	153
S <sub>E60</sub> [VA]	419	800	423	806	418	807
cos $\phi$ <sub>E60</sub> over-excited	0,980	0,980	0,980	0,981	0,980	0,982
Q <sub>expected</sub> [Var]	81	159	81	159	81	159
$\Delta$ Q <sub>E60</sub> [%]	0,23	-0,02	0,29	-0,49	0,15	-0,76

cos $\varphi$ 0,98 under-excited						
U [V]	207,0	207,0	230,0	230,0	253,0	253,0
P <sub>E60</sub> [W]	411	784	415	792	409	793
Q <sub>E60</sub> [Var]	-82	-157	-85	-160	-82	-160
S <sub>E60</sub> [VA]	419	800	423	808	417	809
cos $\varphi$ <sub>E60</sub> under-excited	0,981	0,981	0,980	0,980	0,980	0,980
Q <sub>expected</sub> [Var]	-81	-159	-81	-159	-81	-159
$\Delta$ Q <sub>E60</sub> [%]	-0,12	0,28	-0,45	-0,16	-0,15	-0,13

**Limit**

cos $\varphi$ <sub>E60</sub>	cos $\varphi$ = 0,94 to 0,96 (c) and cos $\varphi$ = 0,94 to 0,96 (i) cos $\varphi$ = 0,97 to 0,99 (c) and cos $\varphi$ = 0,97 to 0,99 (i)	P
cos $\varphi$ settling steps	$\leq 0,01$	P
$\Delta$ Q <sub>E60</sub> in %	$\leq \pm 4\%$ P <sub>E<sub>max</sub></sub>	P

**Graph: Q/P diagram**

**Test:**

applies for PGUs Type 2 - only inverter  $\Sigma S_{E_{max}} \leq 4,6$  kVA

a) and b) For cos  $\varphi$  0,95 over-excited and  $\varphi$  0,95 under-excited, the active power will be measured at value between 40% P<sub>E<sub>max</sub></sub> and 60% and S<sub>E<sub>max</sub></sub> and a second time,

for cos  $\varphi$  0,98 over-excited and  $\varphi$  0,98 under-excited, the active power will be measured at a value between 40% P<sub>E<sub>max</sub></sub> and 60% and S<sub>E<sub>max</sub></sub>

applies for PGUs Type 2 - only inverter  $\Sigma S_{E_{max}} \geq 4,6$  kVA

c) and d) For cos  $\varphi$  0,90 over-excited and  $\varphi$  0,90 under-excited, the active power will be measured at value between 40% P<sub>E<sub>max</sub></sub> and 60% and S<sub>E<sub>max</sub></sub> and a second time,

for cos  $\varphi$  0,95 over-excited and  $\varphi$  0,95 under-excited, the active power will be measured at a value between 40% P<sub>E<sub>max</sub></sub> and 60% and S<sub>E<sub>max</sub></sub>

applies PGUs Type 1 as well as for type 2 plants with Stirling generators and fuel cells  $\Sigma S_{E_{max}} \leq 4,6$  kVA

e) without specification of the  $\cos \varphi$  the active power will be measured at value between 40%  $P_{E_{max}}$  and 60% and  $S_{E_{max}}$ .

applies for PGUs Type 1 as well as for type 2 plants with Stirling generators and fuel cells  $\Sigma S_{E_{max}} > 4,6$  kVA

f) and g) For  $\cos \varphi$  0,95 over-excited and  $\cos \varphi$  0,95 under-excited, the active power will be measured at value between 40%  $P_{E_{max}}$  and 60% and  $S_{E_{max}}$  and a second time,  
for  $\cos \varphi$  0,98 over-excited and  $\varphi$  0,98 under-excited, the active power will be measured at a value between 40%  $P_{E_{max}}$  and 60% and  $S_{E_{max}}$

applies for PGUs Type 2 Asynchronous generators:

h) without specification of the  $\cos \varphi$  the active power will be measured at value  $S_{E_{max}}$ . The test is performed only at  $U_n$ .

**Assessment criterion:**

applies for PGUs Type 2 - only inverter  $\Sigma S_{E_{max}} \leq 4,6$  kVA

The Q setpoint is calculated by using the required  $\cos \varphi$  setpoint one time at 0.95 and one time at 0.98 and the measured apparent power of the fundamental. The test is passed if all the Q 60 s mean values of the fundamental component for a) are in the range of Q set point  $\pm 4\% P_{E_{max}}$  overexcited and for b) in the range of Q set point  $\pm 4\% P_{E_{max}}$  under-excited. In addition, a setting of the  $\cos \varphi$  must be possible within a step size of at least 0.01.

applies for PGUs Type 2 - only inverter  $\Sigma S_{E_{max}} \geq 4,6$  kVA

The Q setpoint is calculated by using the required  $\cos \varphi$  setpoint one time at 0.90 and one time at 0.95 and the measured apparent power of the fundamental. The test is passed if all the Q 60 s mean values of the fundamental component for a) are in the range of Q set point  $\pm 4\% P_{E_{max}}$  overexcited and for c) in the range of Q set point  $\pm 4\% P_{E_{max}}$  under-excited. In addition, a setting of the  $\cos \varphi$  must be possible within a step size of at least 0.01.

applies for PGUs Type 1 as well as for type 2 plants with Stirling generators and fuel cells  $\Sigma S_{E_{max}} \leq 4,6$  kVA

The Q setpoint is calculated by using the required  $\cos \varphi$  setpoint one time at 0.95 and one time at 0.98 and the measured apparent power of the fundamental. The test is passed if all the Q 60 s mean values of the fundamental from e) are in the range Q maximal overexcited till Q minimal under-excited.

applies for PGUs Type 1 as well as for type 2 plants with Stirling generators and fuel cells  $\Sigma S_{E_{max}} \geq 4.6$  kVA

The Q setpoint is calculated by using the required  $\cos \varphi$  setpoint one time at 0.95 and one time at 0.98 and the measured apparent power of the fundamental. The test is passed if all the Q 60 s mean values of the fundamental component for a) are in the range of Q set point  $\pm 4\% P_{E_{max}}$  overexcited and for f) in the range of Q set point  $\pm 4\% P_{E_{max}}$  under-excited. In addition, a setting of the  $\cos \varphi$  must be possible within a step size of at least 0.01.

applies for PGUs Type 1 Asynchronous generators:

The test is passed if the  $\cos \varphi$  Q 60 s mean values of h) is in the range  $\cos \varphi = 0,95$  under excited  $\pm 0,02$ .


**Note:**

The test results of the **WVC-800** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.



**The regulating and control behavior of the reactive power**
**P**


The regulating or control behaviour of the reactive power is based on the PT-1 behaviour shown in Figure 10. Each reactive power value, which results from the control behaviour specified by the network operator, can be set between 6s and 60s (for Type 1 between 10s and 60s). The signal runtime includes the detection of the mains voltage or the active and reactive power.


**Comment:**


The regulation and control behaviour according to PT-1 is implemented and checked for all reactive power control modes.

<b>5.4.8.3 Test of the displacement factor/active power characteristic curve <math>\cos \varphi</math> (P)</b> The test serves as verification of the standard $\cos \varphi$ (P) curve according to VDE-AR-N 4105:2018-11, 5.7.2.4.			<b>P</b>
<b>Test 1) for conducted PGUs - Accuracy (characteristic)</b>			
<b>Measurement: 20-100-20% <math>P_{E_{max}}</math></b>			
$P_{E_{max}}/P$ [%]	20	100	20
U [V]	230,41	230,42	230,41
$P_{E30}$ [W]	165	759	160
$P_{E30}$ of $P_{E_{max}}$ [%]	20,61	94,88	19,95
$Q_{E30}$ [VAr]	25	-242	25
$Q_{expected}$	0	-249	0
$\Delta Q_{E30}$ [%]	3,16	0,94	3,16
$\cos \varphi_{E30}$	0,992	0,953	0,992
$\cos \varphi_{setpoint}$ of $P_{E30}$	1,00	0,95	1,00
P gradient [% of $P_{rE}/s$ ]	0,51		0,51
<b>Limit</b>			
$\Delta Q_{E30}$ in %	$\leq \pm 4,0\%$ relative to $P_{E_{max}}$		P
Note: The test results of the <b>WVC-800</b> can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.			

Graph of Test 1)



Graph of Test 1)


**Assessment criterion:**

Test 5.4.8.3 (1) and (3) are passed if, for all calculated reactive power values, the maximum deviation between the reactive power setpoint (calculated from the characteristic curve to be verified) and the reactive power actual value at the generator terminals is a maximum of  $\pm 4,0\%$  based on  $P_{Emax}$ .

**Test 3) supply-dependent PGUs - Accuracy (characteristic curve)**
**Measurement: 20-100% P<sub>E<sub>max</sub></sub>**

P <sub>E<sub>max</sub></sub> /P [%]	U [V]	P <sub>E30</sub> [W]	P <sub>E30</sub> of P <sub>E<sub>max</sub></sub> [%]	Q <sub>E30</sub> [VAr]	Q <sub>expected</sub>	ΔQ <sub>E30</sub> [%]	COS φ <sub>E30</sub>	COS φ <sub>setpoint</sub> of P <sub>E30</sub>	P <sub>DC</sub> [W]
20	230,37	167	20,90	19	0	2,43	0,993	1,00	184
30	230,38	247	30,89	20	0	2,46	0,997	1,00	272
40	230,37	325	40,67	14	0	1,81	0,999	1,00	358
50	230,39	401	50,18	8	0	1,04	0,999	1,00	442
60	230,38	484	60,46	-52	-68	2,07	0,994	0,99	532
70	230,38	566	70,69	-100	-114	1,66	0,985	0,98	622
80	230,39	643	80,32	-156	-160	0,54	0,972	0,97	707
90	230,39	721	90,11	-197	-210	1,67	0,965	0,96	793
100	230,40	779	97,35	-251	-250	-0,20	0,952	0,95	857



**Measurement: 100-20% P<sub>E<sub>max</sub></sub>**



P <sub>E<sub>max</sub></sub> /P [%]	U [V]	P <sub>E30</sub> [W]	P <sub>E30</sub> of P <sub>E<sub>max</sub></sub> [%]	Q <sub>E30</sub> [VAr]	Q <sub>expected</sub>	ΔQ <sub>E30</sub> [%]	COS φ <sub>E30</sub>	COS φ <sub>setpoint</sub> of P <sub>E30</sub>	P <sub>DC</sub> [W]
100	230,40	777	97,19	-251	-250	-0,10	0,952	0,95	855
90	230,40	718	89,74	-191	-210	2,35	0,966	0,96	790
80	230,41	639	79,90	-159	-160	0,20	0,971	0,97	703
70	230,38	567	70,88	-107	-114	0,87	0,983	0,98	624
60	230,40	478	59,70	-50	-68	2,27	0,994	0,99	525
50	230,39	406	50,76	8	0	0,94	0,999	1,00	447
40	230,38	323	40,38	14	0	1,78	0,999	1,00	355
30	230,39	246	30,78	19	0	2,44	0,997	1,00	271
20	230,37	167	20,82	10	0	1,30	0,998	1,00	183


**Limit**

ΔQ <sub>E30</sub> in %	≤ ±4,0% relative to P <sub>E<sub>max</sub></sub>	P
------------------------	--	---

<b>Test 4): supply-dependent PGUs - Dynamic</b>				
$P_{E_{max}}/P_n$ [%]	100	40	100	75
U [V]	230,31	230,30	230,30	230,30
$P_{E30}$ [W]	770	337	773	601
$P_{E30}$ of $P_{E_{max}}$ [%]	96,31	42,14	96,62	75,19
$Q_{E30}$ [VAr]	-241	7	-244	-122
$Q_{expected}$	-249	0	-249	-137
$\Delta Q_{E30}$ [%]	1,00	0,87	0,62	1,87
$\cos \varphi_{E30}$	0,95	1,00	0,95	0,98
$\cos \varphi_{setpoint}$ of $P_{E30}$	0,95	1,000	0,95	0,975
T [s]	--	9,6	9,4	9,2
<b>Limit</b>				
$\Delta Q_{E30}$ in %	$\leq \pm 4,0\%$ relative to $P_{E_{max}}$			P
<b>DC setting values:</b>				
PV-curve simulated according to				
Voltage of defined MPP [V]		42		
Current of defined MPP [A]		20,7		
FFU of PV curve [1]		--		

**Graph of Test 3)**

**Graph of Test 3): 20% to 100% to 20%**


**Graph of Test 4): 100% to 40%**

**Graph of Test 4): 40% to 100%**


**Graph of Test 4): 100% to 75%**

**Assessment criterion:**

Test 5.4.8.3 (2) is considered to have been passed if the PGU meets the requirements for the performance gradient in VDE AR-N 4105: 2018-11, 5.7.4.2.

Test 5.4.8.3 (4) is passed if the step response of the reactive power in test steps c) and e) shows PT1 behaviour according to VDE-AR-N 4105: 2018-11, 5.7.2.5 and for test step d) optionally the power gradient lies between the limits defined in VDE AR-N 4105: 2018-11, 5.7.4.1 or the step response of the reactive power also has PT1 behaviour according to VDE-AR-N 4105: 2018-11, 5.7.2.5.

**Note:**

The test results of the **WVC-800** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.



5.4.8.4 Test the reactive power-voltage characteristic Q(U)							
The validation of the Q (U) regulation according to VDE-AR-N 4105: 2018-05, 5.7.2.4 is divided into two partial tests, so that on the one hand the accuracy and on the other hand the dynamics of the Q (U) control is checked. For all inverter-coupled systems, only the inverter must be tested.							
5.4.8.4.1 Test of the reactive power-voltage characteristic Q(U)							P
Voltage steps	[Vac] L1	[Vac] L2	[Vac] L3	P <sub>start</sub> [W]	Q <sub>measured</sub> [VAr]	Q <sub>setting</sub> [VAr]	ΔQ [%P <sub>emax</sub> ]
100	230,26	--	--	802	-18	0	-2,25
99	228,00	--	--	800	-18	0	-2,26
98	225,71	--	--	799	-18	0	-2,29
97	223,42	--	--	764	9	0	1,12
96	221,14	--	--	762	68	62	0,73
95	218,83	--	--	758	130	125	0,69
94	216,55	--	--	751	201	187	1,76
93	214,26	--	--	748	260	250	1,32
92	211,95	--	--	746	260	250	1,30
91	209,67	--	--	745	258	250	1,11
90	207,36	--	--	743	258	250	0,99
91	209,68	--	--	745	258	250	1,05
92	211,98	--	--	746	259	250	1,19
93	214,00	--	--	747	260	250	1,25
94	216,43	--	--	749	211	187	2,98
95	218,73	--	--	757	135	125	1,24
96	221,04	--	--	761	73	62	1,34
97	223,33	--	--	763	12	0	1,52
98	225,63	--	--	799	-20	0	-2,45
99	227,94	--	--	800	-20	0	-2,47
100	230,23	--	--	801	-20	0	-2,45
101	232,53	--	--	803	-19	0	-2,43
102	234,83	--	--	804	-20	0	-2,44
103	237,13	--	--	776	-24	0	-3,01
104	239,43	--	--	772	-63	-62	-0,13
105	241,73	--	--	772	-103	-125	2,70
106	244,03	--	--	772	-174	-187	1,64
107	246,33	--	--	769	-233	-250	2,02
108	248,63	--	--	770	-248	-250	0,19
109	250,92	--	--	770	-249	-250	0,13

110	253,23	--	--	771	-250	-250	-0,03
109	250,91	--	--	770	-249	-250	0,13
108	248,63	--	--	769	-248	-250	0,15
107	246,33	--	--	769	-237	-250	1,57
106	244,04	--	--	772	-177	-187	1,28
105	241,73	--	--	772	-107	-125	2,26
104	239,44	--	--	772	-68	-62	-0,65
103	237,15	--	--	772	-27	0	-3,39
102	234,85	--	--	805	-20	0	-2,52
101	232,56	--	--	803	-20	0	-2,53
100	230,25	--	--	802	-20	0	-2,49


**Assessment criterion:**

To pass the Q (U) accuracy test, the measured stationary value pairs  $U_{PGU}$  and  $Q_{PGU}$ , taking account to the correct sign in the consumer metering system, must be within VDE-AR-N 4105: 2018-11, in 5.7.2.4, Figure 7 Q (U) shown characteristic. The stationary value pairs  $U_{PGU}$  and  $Q_{PGU}$  are determined by averaging over 30 seconds at the end of the respective measuring section analogously to Chapter 5.4.3.2. The permissible deviations are with the maximum measuring error of the voltage of 1%  $U_n$  stated in VDE-AR-N 4105: 2018-11 and a setting accuracy of 4%  $P_{EMax}$ .



$$Q_{EZE,tol} = \pm(0.01 \cdot U_{N,Y} \cdot k_{QU} + 0.04 \cdot P_{EMax}) = \pm 0,25 \cdot P_{EMax} \cdot (\sin(\arccos(\varphi_{min})) + 0.16).$$

**Note:**

The test results of the **WVC-800** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.

**Graph of Q(U) curve**


5.4.8.4.2 Test of the dynamics of the Q(U) regulation									P
Setting values	Qmax [var]	k↓QU			X <sub>Netz</sub>	ΔU <sub>ind,Y</sub> [V]	ΔU <sub>kap,Y</sub> [V]	Tau	
		249	--			--	215,28	244,72	3Tau = 10s
Voltage steps	U <sub>start</sub> [V] L1	U <sub>start</sub> [V] L2	U <sub>start</sub> [V] L3	U <sub>end</sub> [V] L1	U <sub>end</sub> [V] L2	U <sub>end</sub> [V] L3	Q <sub>start</sub> [VAr]	Q <sub>end</sub> [VAr]	Settling time[s]
Test1:100→106,4	230,03	--	--	244,74	--	--	20	-214	6,4
Test2:100→106,4	230,02	--	--	244,81	--	--	17	-221	6,6
Test3:100→106,4	230,02	--	--	244,73	--	--	19	-210	6,2
Test1:100→93,6	230,36	--	--	215,39	--	--	20	217	6,6
Test2:100→93,6	230,07	--	--	215,43	--	--	19	213	6,2
Test3:100→93,6	230,05	--	--	215,38	--	--	18	219	6,4
PV-curve simulated according to									
Voltage of defined MPP [V]					42				
Current of defined MPP [A]					20,7				
FFU of PV curve [1]					--				
P <sub>DC</sub> [W]					870				

**Graph of Q(U) dynamics: Test1:100→106,4**

**Graph of Q(U) dynamics: Test1:100→93,6**


**Assessment criterion:**

For passing the test on the dynamics of the Q (U) control, the measured, time profiles of the reactive power have to be determined in the “positive sequence”  $Q_{PGU}$  during the entire measuring period in the PT1-like tolerances according to VDE-AR-N 4105: 2018-11, 5.7.2.5. For this purpose, the tolerance bands are entered into the diagram of the respective measurement according to the formulas below. It should be distinguished according to the expected PGU behavior (inductive, capacitive). An exemplary representation of the tolerance bands for the capacitive case is shown in Figure 6. Physically caused compensation processes (for example with type 1 PGU) are to be excluded from the evaluation, if they decay in a time range smaller than one third of the Q (U) - set time.

The variable T corresponds to the set - up time of the generating plant and three times the parameterized PT1 time constant Tau ( $T = 3\text{Tau}$ ). The measurement of the time starts at the time of the excitation in 5. 4.8.3.2a) or the manipulation in 5.4.8.3.2 b).

Since the increase or decrease of the voltage according to the formula given in 5.4.8.3.2 represents only an approximation to the real behavior of the closed control loop, the steady-state final value  $Q_{set}$  is determined from the measurement. For this purpose, a 10 - second mean value is formed at the end of the one - minute measurement period via the three - phase reactive power in the positive sequence system. Likewise, the starting value of the reactive power (positive sequence)  $Q_{start}$  (= offset) before the respective voltage change is determined over a 10-second averaging.

The response time of the overall system to be evaluated is measured starting from the excitation according to 5.4.8.3.2 a) or the manipulation according to 5.4.8.3.2 b) until reaching 95% of the steady end value in the positive sequence  $Q_{soll}$  and is with the factor 5/3 to multiply. This factor takes into account the effect of the feedback on the control dynamics of the Q (U) control and is strongly related to the formula of the net replacement reactance.

**Note:**

The test results of the **WVC-800** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.

5.5 Testing of NS protection								
5.5.2 NS protection								P
The test for error detection with subsequent shutdown is carried out by means of error simulation, if necessary, with additional error tests (see VDE-AR-N 4105: 2018-11, 6.1).								
5.5.2.1 Functional safety								P
<b>Test procedural:</b>								
<ul style="list-style-type: none"> <li>- It should be checked that a single error does not result in the loss of the security function.</li> <li>- Typical errors must be checked, where applicable:               <ul style="list-style-type: none"> <li>a) Error of an AD converter or measuring card for voltage measurement;</li> <li>b) malfunction or freezing of a microprocessor or PLC;</li> <li>c) merging or clamping the contacts of the switching output;</li> <li>d) Overvoltage of the supply voltage;</li> <li>e) Breakage of the line in connecting lines between the measuring input and the control output to the dome switch;</li> <li>f) Failure of the supply voltage (auxiliary voltage).</li> </ul> </li> </ul>								
<b>Assessment criterion:</b>								
<ul style="list-style-type: none"> <li>- The NS protection must send a shutdown command to the coupling switch.</li> <li>- If the error is detected, the device is switched off within 10 s after error detection.</li> </ul> <p>If the auxiliary voltage fails with the central NS protection or if the control fails with the integrated NS protection, the switch-off command must be given immediately</p>								
<b>Note:</b>								
The errors in the control circuit simulate that the safety is even ensured during a single fault.								
Component No.	Fault	Test condition:		Test time: [min]	Fuse no.[A]	Fault condition:		Result:
		AC	DC			AC	DC	
Relay fault Z1 (pin5-4)	short before start-up	230Vac 0,01A	48Vdc, 0,02A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter cannot star-up. LED light indicate display Red.
Relay fault Z1 (pin7-3)	short before start-up	230Vac 0,01A	48Vdc, 0,02A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter cannot star-up. LED light indicate display Red.
Relay fault Z3 (pin3-8)	short before start-up	230Vac 0,01A	48Vdc, 0,02A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter cannot star-up. LED light indicate display Red.
Relay fault Z3 (pin4-6)	short before start-up	230Vac 0,01A	48Vdc, 0,02A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter cannot star-up. LED light indicate display Red.
Voltage monitoring R9	Open	230Vac 3,2A	48Vdc, 16,3A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter disconnection immediately from grid. LED light indicate display Red.
Voltage monitoring R10	Short	230Vac 3,2A	48Vdc, 16,3A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter disconnection immediately from grid. LED light indicate display Red.
Voltage monitoring U6(pin7-6)	Short	230Vac 3,2A	48Vdc, 16,3A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter disconnection immediately from grid. LED light indicate display

								Red.
Voltage monitoring C46	Short	230Vac 3,2A	48Vdc, 16,3A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter disconnection immediately from grid. LED light indicate display Red.
Voltage monitoring C1	Short	230Vac 3,2A	48Vdc, 16,3A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter disconnection immediately from grid. LED light indicate display Red.
Voltage monitoring C36	Short	230Vac 3,2A	48Vdc, 16,3A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter disconnection immediately from grid. LED light indicate display Red.
Voltage monitoring C4	Short	230Vac 3,2A	48Vdc, 16,3A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter disconnection immediately from grid. LED light indicate display Red.
Q6 (pinC-B)	Short	230Vac 3,2A	48Vdc, 16,3A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter disconnection immediately from grid. U4, Q5, Q6 damaged LED light indicate display Red.
Q6 (pinC-E)	Short	230Vac 3,2A	48Vdc, 16,3A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter disconnection immediately from grid. U4, Q5, Q6 damaged LED light indicate display Red.
Q5 (pinC-B)	Short	230Vac 3,2A	48Vdc, 16,3A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter disconnection immediately from grid. U4, Q5, Q6 damaged LED light indicate display Red.
Q5 (pinC-E)	Short	230Vac 3,2A	48Vdc, 16,3A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter disconnection immediately from grid. U4, Q5, Q6 damaged LED light indicate display Red.
Q9 (pinC-B)	Short	230Vac 3,2A	48Vdc, 16,3A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter disconnection immediately from grid. U4, Q7, Q9 damaged LED light indicate display Red.
Q9 (pinC-E)	Short	230Vac 3,2A	48Vdc, 16,3A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter disconnection immediately from grid. U4, Q7, Q9 damaged LED light indicate display Red.

Q7 (pinC-B)	Short	230Vac 3,2A	48Vdc, 16,3A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter disconnection immediately from grid. U4, Q7, Q9 damaged LED light indicate display Red.
Q7 (pinC-E)	Short	230Vac 3,2A	48Vdc, 16,3A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter disconnection immediately from grid. U4, Q7, Q9 damaged LED light indicate display Red.
PV ISO defected R76	short before start-up	230Vac 0,01A	48Vdc, 0,02A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter cannot star-up. LED light indicate display Red.
PV ISO defected R78	short before start-up	230Vac 0,01A	48Vdc, 0,02A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter cannot star-up. LED light indicate display Red.
PV ISO defected U12 pin4 - 1	short before start-up	230Vac 0,01A	48Vdc, 0,02A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter cannot star-up. LED light indicate display Red.
PV voltage monitoring C45	Short	230Vac 3,2A	48Vdc, 16,3A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter disconnection immediately from grid. LED light indicate display Red.
PV voltage monitoring C40	Short	230Vac 3,2A	48Vdc, 16,3A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter disconnection immediately from grid. LED light indicate display Red.
PV voltage monitoring R85	Open	230Vac 3,2A	48Vdc, 16,3A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter disconnection immediately from grid. LED light indicate display Red.
PV voltage monitoring R76	Open	230Vac 3,2A	48Vdc, 16,3A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter disconnection immediately from grid. LED light indicate display Red.
PV voltage monitoring R73	Open	230Vac 3,2A	48Vdc, 16,3A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter disconnection immediately from grid. LED light indicate display Red.
Communication between U2 pin 46	Open	230Vac 3,2A	48Vdc, 16,3A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter disconnection immediately from grid. LED light indicate display Red.
Communication between U2 pin 47	Open	230Vac 3,2A	48Vdc, 16,3A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter disconnection immediately from grid. LED light indicate display Red.
U2 pin24 to GND (+3.3VD to GND)	Short	230Vac 3,2A	48Vdc, 16,3A	5min	F1	230Vac, 0,01A	48Vdc, 0,02A	The inverter disconnection immediately from grid. LED light indicate display Red.

Note:

The test results of the **WVC-800** can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.




<b>5.5.3 Central NS-protection</b>	<b>N/A</b>
<b>5.5.3.1 Test</b>	<b>N/A</b>
- The auxiliary voltage of the NS protection is switched off	<b>N/A</b>
- The test facility on the NS protection is actuated	<b>N/A</b>
<b>Assessment criterion:</b> The test is considered to have been passed if a signal for the immediate shutdown is generated.	

<b>5.5.4 Integrated NS protection</b>	P
The integrated NS protection is tested in 5.5.7 and in connection with the examination of the entire NS protection chain and switch.	
<b>Note:</b> For test results see 5.5.2.1 Functional safety.	


<b>5.5.6 Interface switch</b>	
<b>5.5.6.1 General</b>	<b>P</b>
These tests serve to demonstrate the requirements of VDE-AR-N 4105: 2018-11, 6.4	
<b>5.5.6.2 Documentation for the design of the central interface switch</b>	<b>N/A</b>
<b>Some details of the central NS protection and the PGU are necessary for the design of a central interface switch. The manufacturer's documentation must therefore contain the following information.</b>	
- maximum operating time of the central interface switch (manufacturer NS protection)	<b>N/A</b>
- Operating time of the protective device (manufacturer NA protection)	<b>N/A</b>
- maximum initial short-circuit alternating current (manufacturer PGU)	<b>N/A</b>
- maximum AC circuit breaker / grid fuse for the PGU (manufacturer PGU)	<b>N/A</b>
- circuit diagram / connection diagram (NS protection / coupling switch) contains the required control and feedback signals (manufacturer NS protection)	<b>N/A</b>
<b>Assessment criterion:</b>	
The test is considered as pass when the documentation of the manufacturer included the necessary information.	
<b>Note:</b>	
Information checked in the manual and datasheet for the external NS protection and coupling switch used in the PGU.	

<b>5.5.6.3 Integrated interface switch</b>	<b>P</b>
<b>5.5.6.3.1 Test (functional chain integrated NS-protection and integrated interface switch)</b>	<b>P</b>
<b>Following monitoring options of an interface switch are valid (a) or (b) or (c):</b>	
<b>(a) Use of an interface switch in which a control voltage must be constantly applied when switched on and which switches off automatically when this voltage is not present. The operational switch-on and switch-off processes is monitored</b>	
The disconnection of the control voltage leads to the instantaneous disconnection of the interface switch.	P
A simulated defect during the closing and opening of the interface switch leads to an instantaneous shutdown of the PGU. A restart is not possible.	P
A simulated defect of the interface switch after the NS protection as operated leads to an instantaneous shutdown of the PGU. A restart is not possible.	P
The switch-off time of the whole reaction chain is within 0,2s.	P
<b>(b) The interface switch is switched on and off at least once a day by the NS protection and the proper functioning of the coupling switch is monitored.</b>	
A simulated defect of the interface switch during the daily test leads to an instantaneous shutdown of the PGU. A restart is not possible.	N/A
A simulated defect of the interface switch after the NS protection has operated leads to an instantaneous shutdown of the PGU. A restart is not possible.	N/A
A function for daily switching on and off is available and explained by a manufacturer's declaration.	N/A
<b>(c) Use of the integrated coupling switch and the integrated NA protection for PV and battery converters according to DIN EN 62109 (VDE 0126-14-1).</b>	
The integrated interface switch and NS protection is complied with DIN EN 62109 (VDE 0126-14-1).	N/A
<b>Note:</b> See test results 5.5.2.1 functional safety.	
The inverter has a galvanic separating break device. The interface switch is short-circuit proof for the maximum short-circuit current of the power generation unit.	
Max. initial short-circuit current of the PGU (power generation unit)	= 10A, 230 Vac
Max. switching current relay	= 16 A, 250 Vac
Response time of interface switch for integrated NS protection	≤ 15 ms


**Datasheet of the relay (Interface switch):**




File No.:E134517



File No.:116934



File No.:CQC17002168381



**Features**

- Low height: 15.7 mm
- 16A switching capability
- 5kV dielectric strength (between coil and contacts)
- Creepage distance: 10mm
- Meeting VDE 0700, 0631 reinforce insulation
- Product in accordance to IEC 60335-1 available
- Sockets available
- Plastic sealed and flux proofed types available
- UL insulation system: Class F available


**RoHS compliant**

CONTACT DATA	
Contact arrangement	1A, 1B, 1C      2A, 2B, 2C
Contact resistance <sup>1)</sup>	100mΩ max.(at 1A 6VDC)
Contact material	See ordering info.
Contact rating (Res. load)	12A/16A 250VAC      8A 250VAC
Max. switching voltage	440VAC / 300VDC
Max. switching current	12A / 16A      8A
Max. switching power	3000VA / 4000VA      2000VA
Mechanical endurance	1 x 10 <sup>7</sup> OPS
Electrical endurance	1H3B type: 1 x 10 <sup>5</sup> OPS (16A 250VAC, Resistive load, Room temp., 1s on 9s off) 2H4B type: 5 x 10 <sup>4</sup> OPS (8A 250VAC, Resistive load, Room temp., 1s on 9s off)

Notes: 1) The data shown above are initial values.

CHARACTERISTICS	
Insulation resistance	1000MΩ (at 500VDC)
Dielectric strength	Between coil & contacts      5000VAC 1min
	Between open contacts      1000VAC 1min
	Between contact sets      2500VAC 1min
Surge voltage (between coil & contacts)	10kV (1.2 / 50μs)
Operate time (at nomi. volt.)	15ms max.
Release time (at nomi. volt.)	8ms max.
Temperature rise (at nomi. volt.)	55K max.
Shock resistance *	Functional      98m/s <sup>2</sup>
	Destructive      980m/s <sup>2</sup>
Vibration resistance *	10Hz to 150Hz 10g/5g
Humidity	5% to 85% RH
Ambient temperature	-40°C to 85°C
Termination	PCB
Unit weight	Approx. 13.5g
Construction	Plastic sealed, Flux proofed

Notes: 1) The data shown above are initial values.  
2) \* Index is not in relay length direction.  
3) UL insulation system: Class F, Class B.



**HONGFA RELAY**

ISO9001. IATF16949 . ISO14001. OHSAS18001. IECQ QC 080000 CERTIFIED

2022 Rev. 1.00

COIL	
Coil power	Approx. 400mW

COIL DATA					at 23°C
Nominal Voltage VDC	Pick-up Voltage VDC max. <sup>1)</sup>	Drop-out Voltage VDC min. <sup>1)</sup>	Max. Voltage VDC <sup>2)</sup>	Coil Resistance Ω	
5	3.50	0.5	7.5	62 x (1±10%)	
6	4.20	0.6	9.0	90 x (1±10%)	
9	6.30	0.9	13.5	202 x (1±10%)	
12	8.40	1.2	18	360 x (1±10%)	
18	12.60	1.8	27	810 x (1±10%)	
24	16.80	2.4	36	1440 x (1±10%)	
48 <sup>3)</sup>	33.60	4.8	72	5760 x (1±15%)	
60 <sup>3)</sup>	42.00	6.0	90	7500 x (1±15%)	
110 <sup>3)</sup>	77.00	11.0	165	25200 x (1±15%)	

Notes: 1) The data shown above are initial values.  
2) Maximum voltage refers to the maximum voltage which relay coil could endure in a short period of time.  
3) For products with rated voltage ≥ 48V, measures should be taken to prevent coil overvoltage in order to protect coil in test and application (eg. Connect diodes in parallel).

<b>5.5.7.2 Check of setting values</b>					<b>P</b>
<b>5.5.7.2.1 Test</b>					<b>P</b>
<b>Test procedural:</b>					
<ul style="list-style-type: none"> <li>- Before the further tests begin, the factory setting values of the test object must be checked.</li> <li>- The test object must be reset to factory settings.</li> <li>- The test object must be put into operation according to the user manual. If an operator input is required, the setting for VDE-ARN 4105:2018 must be selected.</li> </ul>					
<b>Assessment criterion:</b>					
<ul style="list-style-type: none"> <li>- The exam is passed if the following points are met:</li> <li>- The factory setting values correspond               <ol style="list-style-type: none"> <li>a) With integrated NA protection of VDE-AR-N 4105: 2018-11, 6.5.2 Table 2 (see also Table 36).</li> <li>b) With central NA protection, either the factory settings of VDE-AR-N 4105: 2018-11, 6.5.2, Table 2 (see also Table 36) or these values can be set.</li> </ol> </li> <li>- In the event of an operator input, the test object only goes into operation after settings have been selected.</li> <li>- The setting values that can be changed according to 4105: 2018-11, 6.5.1 and 6.5.2 can be set within the specified limits and are protected against unauthorized access.</li> <li>- The setting values that cannot be changed according to VDE-AR-N 4105: 2018-11, 6.5.1 and 6.5.2 cannot be changed or are protected from unauthorized access by an additional separate protection system</li> </ul>					
<b>Setting values:</b>					
PGU type	Description	Parameter name	Set value in p.u.	Set value L-N	Set value L-L *2)
	nominal voltage	$U_n$	1	230,0V	400V
	Nominal frequency	$f_n$	1	50Hz	50Hz
a) name set of parameters (Parameter setup name in manual or software)					
<input type="checkbox"/>	Stirling generators, fuel cells, coupled directly or via a converter Synchronous and asynchronous generators with $P_n \leq 50$ kW	Excitation threshold $U_{>>}$	N/A	N/A	N/A
		Delay time $U_{>>}$	N/A	N/A	N/A
		Excitation threshold $U_{>}$	N/A	N/A	N/A
		Delay time $U_{>} * 1)$	N/A	N/A	N/A
		Excitation threshold $U_{<}$	N/A	N/A	N/A
		Delay time $U_{<}$	N/A	N/A	N/A
		Excitation threshold $U_{<<}$	N/A	N/A	N/A
		Delay time $U_{<<}$	N/A	N/A	N/A
		Excitation threshold $f_{>}$	N/A	N/A	N/A
		Delay time $f_{>}$	N/A	N/A	N/A
		Excitation threshold $f_{<}$	N/A	N/A	N/A
		Delay time $f_{<}$	N/A	N/A	N/A
b) name set of parameters (Parameter setup name in manual or software)					
<input type="checkbox"/>	directly coupled synchronous and asynchronous generators with $P_n > 50$ kW	Excitation threshold $U_{>>}$	N/A	N/A	N/A
		Delay time $U_{>>}$	N/A	N/A	N/A
		Excitation threshold $U_{>}$	N/A	N/A	N/A
		Delay time $U_{>} * 1)$	N/A	N/A	N/A
		Excitation threshold $U_{<}$	N/A	N/A	N/A
		Delay time $U_{<}$	N/A	N/A	N/A

	Excitation threshold U<<	N/A	N/A	N/A	N/A
	Delay time U<<	N/A	N/A	N/A	N/A
	Excitation threshold f>	N/A	N/A	N/A	N/A
	Delay time f>	N/A	N/A	N/A	N/A
	Excitation threshold f<	N/A	N/A	N/A	N/A
	Delay time f<	N/A	N/A	N/A	N/A
c) name set of parameters (Parameter setup name in manual or software)					
☒ Inverter	Excitation threshold U>>	N/A	--	287,5V	--
	Delay time U>>	N/A	--	100ms	--
	Excitation threshold U>	N/A	--	253,0V	--
	Delay time U> * 1)	N/A	--	100ms *1)	--
	Excitation threshold U<	N/A	--	184,0V	--
	Delay time U<	N/A	--	3000ms	--
	Excitation threshold U<<	N/A	--	103,5V	--
	Delay time U<<	N/A	--	300ms	--
	Excitation threshold f>	N/A	--	51,5Hz	--
	Delay time f>	N/A	--	100ms	--
	Excitation threshold f<	N/A	--	47,5Hz	--
	Delay time f<	N/A	--	100ms	--
*1) 10-min mean value					
*2) testing of external NS-protection					



Factory settings correspond to the values according the Inverter of Table 36 of VDE 0124	P
There are no factory settings. The information on the setting values in the instruction manual correspond to those in Inverter of Table 36 of VDE 0124.	N/A
External NS protection: settings and delay times are password protected settable	N/A
External NS protection: It is possible to read the setting values without a tool	N/A
Integrated NS protection: the setting values are visible via a data interface or display	P
The limit values for U> can be set between 110% and 115% and, in the case of directly coupled synchronous and asynchronous generators with P <sub>FE</sub> >50kW, the time delay for U< and U<< can be set. All other limit values are protected against unauthorized access.	P


<b>5.5.7.3 Wiring check</b>	<b>N/A</b>
<b>5.5.7.3.1 Test</b>	<b>N/A</b>
<b>Test procedural:</b> <ul style="list-style-type: none"><li>- The wiring of the test object must be checked by applying the test voltages.</li><li>- For single-phase EZE, the wiring test is adapted, only the feed-in phase is to be evaluated.</li><li>- It must be checked that the test object correctly evaluates line to line voltages and line to neutral conductor voltages. This test step is not applicable for single-phase EZE.</li></ul>	
<b>Assessment criterion:</b> <p>This check is not evaluated. If a phase rotation is detected, it shall be corrected and the test repeated.</p>	



<b>5.5.7.4 Voltage and frequency control</b>						<b>P</b>
<b>5.5.7.4.1 Voltage and frequency control – Single Phase</b>						<b>P</b>
<b>Test procedural:</b>						
<ul style="list-style-type: none"> <li>- For a single-phase EZE, only the feed-in phase needs to be checked.</li> <li>- Before each test step, the EZE must be operated symmetrically with rated voltage and rated frequency for at least 10 s in feed-in mode.</li> <li>- The P setpoint was set by SW-Tool using RS485-interface.</li> </ul>						
<b>Assessment criterion:</b>						
<ul style="list-style-type: none"> <li>- The permitted tolerance between setting value and trip value of the voltage may not exceed <math>\pm 1\%</math> of <math>U_n</math>.</li> <li>- The disconnection time includes disconnect time + operate time of the integrated relay. Therefore, limit is given with +0,100s according to Table 2 set values of the NS-protection according to VDE AR-N 4105:2018.</li> </ul>						
Note:						
The test results of the <b>WVC-800</b> can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.						
<b>Integrated NS protection single phase <math>\leq 30\text{kVA}</math></b>						
Setting values of the NS protection:	Setting	Value [V]	Time [s]	Setting	Value [V]	Time [s]
				U>>	287,5	0,1
	U<	184,0	3,0	U<<	103,5	0,3
<b>Operating time of the monitoring device:</b>						
<b>L1 to N:</b>						
	<b>Under voltage 1 (4.2):</b>			<b>Over voltage 1 (1.2):</b>		
Ramp [start V to stop V]	>188,6 → <179,4			<282,9 → >292,1		
Step size [V]	<1,15			<1,15		
Step length [s]	>3,200			>0,400		
Limit [V]	184,0 $\pm 1\%$ $U_n$			287,5 $\pm 1\%$ $U_n$		
Measurement [V]	183,2	183,4	183,2	286,4	286,5	286,6
<b>L1 to N:</b>						
	<b>Under voltage 1 (5.2):</b>			<b>Over voltage 1 (2.2):</b>		
Jump [start V to stop V]	>200,1 → <179,4			<282,9 → >292,1		
Step size [V]	>9,2			>9,2		
Step length [s]	>3,200			>0,400		
Limit [s]	3,000 $\leq t \leq 3,100$			0,100 $\leq t \leq 0,200$		
Measurement [s]	3,082	3,033	3,024	0,177	0,162	0,188
<b>L1 to N:</b>						
	<b>Under voltage 2 (6.2):</b>			/		
Ramp [start V to stop V]:	>108,1 → <98,9					
Step size [V]	<1,15					
Step length [s]	>0,500					
Limit [V]:	103,5 $\pm 1\%$ $U_n$					
Measurement [V]:	104,1	104,6	104,7			
<b>L1 to N:</b>						
	<b>Under voltage 2 (7.2):</b>			/		
Jump [start V to stop V]:	>108,1 → <98,9					
Step size [V]	>9,2					


Step length [s]	>0,500		
Limit [s]:	0,300 ≤ t ≤ 0,400		
Measurement [s]:	0,385	0,389	0,392

**Under voltage 1 (5.2):**

**Under voltage 2 (7.2):**





<b>5.5.7.4 Voltage and frequency control</b>		<b>P</b>
<b>5.5.7.4.1 Measuring the rise-in voltage protection as a running 10-minute mean value</b>		<b>P</b>
Setting values of the NS protection:	Setting U> [V]	253,0
	Setting T <sub>disconnection U&gt;</sub> [s]	600
<b>Operating time of the monitoring device:</b>		
L1-N:	<b>Over voltage 10-minute mean value (3.1):</b>	
Ramp [start V to stop V]	230,0 → 257,6	
Step size [V]	27,6	
Step length [s]	>600,2	
Limit for disconnection [s]	450 to 550	
Measurement [s]	478	
L1-N:	<b>Over voltage 10-minute mean value (3.2):</b>	
Ramp [start V to stop V]	230,0 → >248,4	
Step size [V]	18,4	
Step length [s]	>600,2	
Limit for reconnection [s]	no disconnection (also after 600s)	
Measurement [s]	No disconnection	
L1-N:	<b>Over voltage 10-minute mean value (3.3):</b>	
Ramp [start V to stop V]	243,8 → >262,2	
Step size [V]	18,4	
Step length [s]	>600,2	
Limit for disconnection[s]	225s to 375	
Measurement [s]	336	
<b>Note:</b> The test results of the <b>WVC-800</b> can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.		


**Over voltage 10-minute mean value (3.1):**



**Over voltage 10-minute mean value (3.2):**




Over voltage 10-minute mean value (3.3):




<b>5.5.7.4 Voltage and frequency control</b>				<b>P</b>		
<b>5.5.7.4.1 Voltage and frequency control – Frequency measurement</b>				<b>P</b>		
<b>Test procedural:</b>						
<ul style="list-style-type: none"> <li>- For a single-phase EZE, only the feed-in phase needs to be checked.</li> <li>- Before each test step, the EZE must be operated symmetrically with rated voltage and rated frequency for at least 10 s in feed-in mode.</li> <li>- The P setpoint was set by SW-Tool using RS485-interface.</li> </ul>						
<b>Assessment criterion:</b>						
<ul style="list-style-type: none"> <li>- The permitted tolerance between setting value and trip value of the voltage may not exceed <math>\pm 1\%</math> of <math>f_n</math>.</li> <li>- The disconnection time includes disconnect time + operate time of the integrated relay. Therefore, limit is given with +0,100s according to Table 2 set values of the NS-protection according to VDE AR-N 4105:2018.</li> </ul>						
<b>Note:</b>						
The test results of the <b>WVC-800</b> can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.						
Setting values of the NS protection:	Setting	Value [Hz]		Time [s]		
	f<	47,5		0,1		
	f>	51,5		0,1		
<b>Operating time of the monitoring device:</b>						
	<b>Under frequency (10.1):</b>			<b>Over frequency (8.1):</b>		
Ramp [start Hz to stop Hz]	47,60 → 47,40			51,40 → 51,60		
Step size [Hz]	<0,025			<0,025		
Step length [s]	>0,4			>0,4		
Limit [Hz]	47,50 $\pm 1\%$ $f_n$			51,50 $\pm 1\%$ $f_n$		
Measurement [Hz]	47,51	47,50	47,50	51,50	51,51	51,50
	<b>Under frequency (11.1):</b>			<b>Over frequency (9.1):</b>		
Jump [start Hz to stop Hz]	47,60 → 47,40			51,40 → 51,60		
Step size [Hz]	>0,2			>0,2		
Step length [s]	>0,4			>0,4		
Limit [s]	0,100 $\leq t \leq$ 0,200			0,100 $\leq t \leq$ 0,200		
Disconnection time [s]	0,104	0,137	0,138	0,125	0,108	0,124


### Under frequency (11.1):



### Over frequency (9.1):





5.5.7.5 Reporting NS protection	P
<p><b>Test procedural:</b></p> <ul style="list-style-type: none"> <li>- At least the last 5 error messages can be read at the EZE or the external NA protection.</li> <li>- The supply voltage must then be interrupted for 3 s.</li> <li>- The error messages must then be read out again.</li> </ul>	
<p><b>Assessment criterion:</b></p> <p>At least the last 5 error messages including time stamps that were recorded before the voltage interruption and at least 5 error messages including time stamps that were recorded after the voltage interruption must be documented</p>	
<p><b>Picture of 5 last dated failure:</b></p>	
	


<b>5.5.9 Constructional characteristics of NS protection</b>	<b>P</b>
<b>5.5.9.1 General</b>	<b>P</b>
These tests serve to demonstrate the requirements of VDE-AR-N 4105: 2018-11, 6.5.2.	
<b>5.5.9.2 Test</b>	<b>P</b>
Type of NS protection: <input checked="" type="checkbox"/> Internal / <input type="checkbox"/> external	
NS-protection is sealed or a password protection is used (or both)	P
adjustability of U> and the time delays for U< and U<< is given	P
All other protective functions are either permanently protected or protected from unauthorized access by additional, separate protection (example password)	P

<b>5.5.10 Islanding detection</b>	<b>P</b>
<p>For power generation systems, islanding detection must be carried out using one of the following processes:</p> <ul style="list-style-type: none"> <li>a) active method, e.g., by means of frequency – shift process (oscillating circuit)</li> <li>b) passive method by means of the three-phase voltage monitoring (possible only for power generation systems without inverters or for single-phase power generation units with inverters).</li> </ul> <p>(see 5.4.5.3 3-phase voltage control)</p> <p>With the passive process, it is important to provide evidence that the power generation unit can be set not equal to 120°.</p>	
<b>5.5.10.1 General</b>	<b>P</b>
<p>These tests serve as proof of the requirements of VDE-AR-N 4105: 2018-11, 6.5.3. The maximum switch-off time is 9 s.</p>	

5.5.10.2 Passive Islanding detection	N/A
<p>The passive procedure is implemented by the voltage increase and voltage decrease protection of the NS protection.</p>	
<p><b>Note:</b> A passive procedure is possible with the help of three-phase voltage monitoring (only for generating units without converter or for single-phase generating units with converter) The three-phase voltage monitoring is also permissible with the structural integration of several single-phase generating units that feed into different external conductors, as long as the currents of these generating units are regulated independently of each other so that any phase positions can be set.</p>	


5.5.10.3 Islanding protection according to table 6 - Load imbalance (real, reactive load) for test condition A (PGU output = 100%)										P
Test conditions		Frequency: $50 \pm 1\% f_n$ $U_n = 230 \pm 1\% U_n$ Distortion factor of chokes $\leq 2\%$								
Disconnection limit		2s (IEC 62116)								
No	P <sub>PGU</sub> <sup>1)</sup> [% of PGU rating]	Reactive load [% of Q <sub>L</sub> in 6.1.d) 1]	P <sub>AC</sub> <sup>2)</sup> [% of nominal]	Q <sub>AC</sub> <sup>3)</sup> [% of nominal]	I <sub>AC</sub> <sup>4)</sup> [A]	P <sub>PGU</sub> [W]	voltage [V]	Q <sub>r</sub> [1]	Run on Time [s]	Re- marks <sup>5)</sup>
1	100	100	0	0	0,047	803	44	0,997	257	BL
2	100	100	-5	-5	0,809	803	44	1,023	233	IB
3	100	100	-5	0	0,830	803	44	1,050	235	IB
4	100	100	-5	+5	0,809	803	44	1,076	224	IB
5	100	100	0	-5	0,067	803	44	0,972	203	IB
6	100	100	0	+5	0,067	803	44	1,022	223	IB
7	100	100	+5	-5	0,848	803	44	0,926	215	IB
8	100	100	+5	0	0,830	803	44	0,950	214	IB
9	100	100	+5	+5	0,848	803	44	0,973	203	IB
Parameter at 0%		L= 210,33mH			R= 65,88 Ω			C= 48,17μF		
<p>Note:</p> <p>RLC is adjusted to min. +/-1% of the inverter rated output power</p> <p>1) PPGU: PGU output power</p> <p>2) PAC: Real power flow at S1 in Figure 1. Positive means power from PGU to utility. Nominal is the 0 % test condition value.</p> <p>3) QAC: Reactive power flow at S1 in Figure 1. Positive means power from PGU to utility. Nominal is the 0 % test condition value.</p> <p>4) Fundamental of IAC when RLC is adjusted</p> <p>5) BL: Balance condition, IB: Imbalance condition.</p> <p>Condition A:</p> <p>PGU output power PPGU = Maximum 6)</p> <p>PGU input voltage 6) ≥ 75% of rated input voltage range</p> <p>6) Maximum PGU output power condition should be achieved using the maximum allowable input power. Actual output power may exceed nominal rated output.</p> <p>7) Based on PGU rated input operating range. For example, If range is between X volts and Y volts, 75 % of range = <math>X + 0,75 \times (Y - X)</math>. Y shall not exceed <math>0,8 \times</math> PGU maximum system voltage (i.e., maximum allowable array open circuit voltage). In any case, the PGU should not be operated outside of its allowable input voltage range.</p> <p>The test results of the <b>WVC-800</b> can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.</p>										

Disconnection at  $P_{AC}$  0% &  $Q_{AC}$  0%



5.5.10.3 Islanding protection according Table 7 – Load imbalance (reactive load) for test condition B (PGU output = 50 % – 66 %)										P
Test conditions			Frequency: $50 \pm 1\% f_n$ $U_n = 230 \pm 1\% U_n$ Distortion factor of chokes $\leq 2\%$							
Disconnection limit			2s (IEC 62116)							
No	P <sub>PGU</sub> <sup>1)</sup> [% of PGU rating]	Reactive load [% of Q <sub>L</sub> in 6.1.d <sup>1)</sup> ]	P <sub>AC</sub> <sup>2)</sup> [% of nominal ]	Q <sub>AC</sub> <sup>3)</sup> [% of nominal]	I <sub>AC</sub> <sup>4)</sup> [A]	P <sub>PGU</sub> [W]	Voltage [V]	Q <sub>f</sub> [1]	Run on Time [s]	Re- marks <sup>5)</sup>
12	66	66	0	-5	0,017	526	39	0,975	209	BL
13	66	66	0	-4	0,015	526	39	0,980	240	IB
14	66	66	0	-3	0,013	526	39	0,985	242	IB
15	66	66	0	-2	0,012	526	39	0,990	205	IB
16	66	66	0	-1	0,010	526	39	0,995	294	IB
2	66	66	0	0	0,007	526	39	1,000	239	IB
17	66	66	0	1	0,008	526	39	1,005	260	IB
18	66	66	0	2	0,008	526	39	1,010	301	IB
19	66	66	0	3	0,007	526	39	1,015	309	IB
20	66	66	0	4	0,007	526	39	1,020	237	IB
21	66	66	0	5	0,007	526	39	1,025	215	IB
Parameter at 0%			L= 319,55 mH			R= 100,18 Ω			C= 31,71 μF	
<p><b>Note:</b></p> <p>RLC is adjusted to min. +/-1% of the inverter rated output power</p> <p>1) P<sub>PGU</sub>: PGU output power</p> <p>2) P<sub>AC</sub>: Real power flow at S1 in Figure 1. Positive means power from PGU to utility. Nominal is the 0 % test condition value.</p> <p>3) Q<sub>AC</sub>: Reactive power flow at S1 in Figure 1. Positive means power from PGU to utility. Nominal is the 0 % test condition value.</p> <p>4) Fundamental of I<sub>AC</sub> when RLC is adjusted</p> <p>5) BL: Balance condition, IB: Imbalance condition.</p> <p>Condition B:</p> <p>PGU output power P<sub>PGU</sub> = 50 % – 66 % of maximum</p> <p>PGU input voltage <sup>6)</sup> = 50 % of rated input voltage range, ±10 %</p> <p><sup>6)</sup> Based on PGU rated input operating range. For example, If range is between X volts and Y volts, 50 % of range = X + 0,5 × (Y – X). Y shall not exceed 0,8 × PGU maximum system voltage (i.e., maximum allowable array open circuit voltage). In any case, the PGU should not be operated outside of its allowable input voltage range.</p> <p>The test results of the <b>WVC-800</b> can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.</p>										


Disconnection time at  $P_{AC}$  0% and  $Q_{AC}$  3%









5.5.10.3 Islanding protection according Table 8 – Load imbalance (reactive load) for test condition B (PGU output = 25 % – 33 %)										P
Test conditions		Frequency: $50 \pm 1\% f_n$ $U_n = 230 \pm 1\% U_n$ Distortion factor of chokes $\leq 2\%$								
Disconnection limit		2s (IEC 62116)								
No	P <sub>PGU</sub> <sup>1)</sup> [% of PGU rating]	Reactive load [% of Q <sub>L</sub> in 6.1. <sup>d)</sup> 1]	P <sub>AC</sub> <sup>2)</sup> [% of nominal]	Q <sub>AC</sub> <sup>3)</sup> [% of nominal]	I <sub>AC</sub> <sup>4)</sup> [A]	P <sub>PGU</sub> [W]	Voltage [V]	Q <sub>f</sub> [1]	Run on Time [ms]	Re- marks <sup>5)</sup>
22	33	33	0	-5	0,023	256	34	0,975	221	BL
23	33	33	0	-4	0,022	256	34	0,980	234	IB
24	33	33	0	-3	0,021	256	34	0,985	240	IB
25	33	33	0	-2	0,020	256	34	0,990	235	IB
26	33	33	0	-1	0,020	256	34	0,995	207	IB
3	33	33	0	0	0,017	256	34	1,000	220	IB
27	33	33	0	1	0,018	256	34	1,005	211	IB
28	33	33	0	2	0,018	256	34	1,010	236	IB
29	33	33	0	3	0,017	256	34	1,015	224	IB
30	33	33	0	4	0,017	256	34	1,020	248	IB
31	33	33	0	5	0,017	256	34	1,025	223	IB
Parameter at 0%		L= 639,10 mH			R= 200,40 Ω			C= 15,85 μF		
<p><b>Note:</b></p> <p>RLC is adjusted to min. +/-1% of the inverter rated output power</p> <p>1) P<sub>PGU</sub>: PGU output power</p> <p>2) P<sub>AC</sub>: Real power flow at S1 in Figure 1. Positive means power from PGU to utility. Nominal is the 0 % test condition value.</p> <p>3) Q<sub>AC</sub>: Reactive power flow at S1 in Figure 1. Positive means power from PGU to utility. Nominal is the 0 % test condition value.</p> <p>4) Fundamental of I<sub>AC</sub> when RLC is adjusted</p> <p>5) BL: Balance condition, IB: Imbalance condition.</p> <p>Condition B:</p> <p>PGU output power P<sub>PGU</sub> = 25 % – 33 %<sup>6)</sup> of maximum</p> <p>PGU input voltage<sup>7)</sup> &lt; 20 % of rated input voltage range</p> <p><sup>6)</sup> Or minimum allowable PGU output level if greater than 33 %.</p> <p><sup>7)</sup> Based on PGU rated input operating range. For example, if range is between X volts and Y volts, 20 % of range = X + 0,2 × (Y – X). Y shall not exceed 0,8 × PGU maximum system voltage (i.e., maximum allowable array open circuit voltage). In any case, the PGU should not be operated outside of its allowable input voltage range.</p> <p>The test results of the <b>WVC-800</b> can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.</p>										

Disconnection time at  $P_{AC}$  0% and  $Q_{AC}$  +2%



5.6.2. Connecting conditions and synchronisation			P
<b>Test:</b>			
	$f_{ist}$	<b>Reset time:</b>	<b>Limit:</b>
<b>Connecting conditions for frequencies:</b>			
a)	<47,45Hz	No reconnection	No resetting allowed
	Switch to:		
b)	≥47,55Hz	76 s	≥60s
c)	>50,15Hz	No reconnection	No resetting allowed
	Switch to:		
d)	≤50,05Hz	68 s	≥60s
<b>Connecting conditions for voltages:</b>			
e)	84%	No reconnection	No resetting allowed
	Switch to:		
f)	≥86%	80 s	≥60s
g)	111%	No reconnection	No resetting allowed
	Switch to:		
h)	≤109%	74 s	≥60s
<b>Test:</b>			
see points a) to h) for the test process.			
The measurement was carried out with a programmable AC source.			
e.g., connecting conditions for frequencies: Point a) and b). The AC source was programmed in such a way that the first step of 230V/50Hz to 200V/47,0Hz resulted in a faulty disconnection. Thereafter the voltage and frequency for 100s is set to 215V/47,45Hz. Switching on again is not permitted. After a lapse of 100s the voltage is set to 230V/47,55Hz. Setting again after 60s is permitted.			
<b>Assessment criterion:</b>			
After actuating the NS protection, it should be checked that the system can only be switched within the tolerance ranges ((80% $U_n \leq U \leq 110\% U_n$ ) and (47,50Hz $\leq f \leq 50,10$ Hz)) at the earliest after 60s after voltage and frequency has remained within the tolerance ranges.			
<b>Note:</b>			
The test results of the <b>WVC-800</b> can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.			

**Connecting conditions for frequencies: 47,55Hz**

**Connecting conditions for frequencies: 50,05Hz**


**Connecting conditions for voltages: 86%Un**

**Connecting conditions for voltages: 109%Un**


## 5.7 Evidence of $P_{AV,E}$ -Control

### 5.7.1 General

N/A

The test serves to prove the requirements of VDE-AR-N 4105: 2018 - 11, 5.5.2. The  $P_{AV,E}$ -monitoring may, but does not have to be integrated into the PGU. If the  $P_{AV,E}$ -monitoring is not as a unit built, but distributed over several devices, the entire impact chain is analogous to the examination of NA protection including the communicative Check coupling.




Bild 8 – Skizze des Prüfaufbaus zur Prüfung der Regeldynamik




Bild 1 – Wirkleistungs-Grenzkurve für Erzeugungsanlagen

The PGU with any necessary additional components is installed according to the manufacturer's instructions and parameterized so that the feed limitation  $P_{AV,E}$  is activated at  $\geq 60\% P_{rE}$ . The power jump can be simulated either by a jump in the primary energy supply or by the fall of a load become:

**a) Primary energy supply jump:** The primary energy supply is adjusted so that the PGU supplies the power  $P_{AV,E} = 60\% P_{rE}$  with a tolerance of -2%. At the time  $t_0$ , the primary energy supply is to be suddenly increased so that the PGU can provide the rated output.


**b) Loss of load:** The PGU is operated at nominal power. Via a load which is to be connected symmetrically to all feeding phases parallel to the PGU, the power at the grid connection point is set to  $P_{AV,E}$  with a tolerance of -2%. At time  $t_0$ , the load is switched off. The elimination of the load can also be simulated by an appropriate offset on the power measurement signal.

The closed loop must not be disconnected. Here, the sum of the effective active values of all 3 phases at the grid connection point must be recorded for at least 15s from the power jump.

<b>5.8 Evidence dynamic grid support</b>		
<b>5.8.1</b>	General	<b>P</b>
<b>5.8.3</b>	Testing of the dynamic grid support PGU Type 1	<b>N/A</b>
<b>5.8.3</b>	Testing of the dynamic grid support PGU Type 2	<b>P</b>

## 5.8.1 General


P

**FRT test for three-phase symmetrical (Test ref no. 1.x)**


Typ-A

**LVRT test for two-phase asymmetrical fault (Test ref no. 1.3.x to 4.3.x)**

Test No.	V/V <sub>nom</sub>	Phase-to-earth voltages			Phase angles		
		u <sub>1</sub> /u <sub>1,nom</sub>	u <sub>2</sub> /u <sub>2,nom</sub>	u <sub>3</sub> /u <sub>3,nom</sub>	φ <sub>u1</sub> (U)	φ <sub>u2</sub> (V)	φ <sub>u3</sub> (W)
1.3, 1.4	0,15 ± 0,05	0,62 ± 0,05	0,15 ± 0,05	0,62 ± 0,05	-143°	120°	23°
2.3, 2.4, 3.3, 3.4	0,50 ± 0,05	0,76 ± 0,05	0,50 ± 0,05	0,76 ± 0,05	-131°	120°	11°
4.3, 4.4	0,50 ± 0,05	0,93 ± 0,05	0,85 ± 0,05	0,93 ± 0,05	-123°	120°	3°
Normal condition	1	1	1	1	-120°	120°	0°



Typ-D

**FRT test for two-phase asymmetrical fault (Test ref no. 5.3.x to 7.3.x)**


Test No.	V/V <sub>nom</sub>	Phase-to-earth voltages			Phase angles		
		u <sub>1</sub> /u <sub>1,nom</sub>	u <sub>2</sub> /u <sub>2,nom</sub>	u <sub>3</sub> /u <sub>3,nom</sub>	φ <sub>u1</sub> (U)	φ <sub>u2</sub> (V)	φ <sub>u3</sub> (W)
5.3, 5.4	1,25 ± 0,05	1,08 ± 0,05	1,25 ± 0,05	1,06 ± 0,05	-115°	-120°	6°
6.3,6.4	1,20 ± 0,05	1,06 ± 0,05	1,20 ± 0,05	1,05 ± 0,05	-116°	-120°	5°
7.3,7.4	1,15 ± 0,05	1,04 ± 0,05	1,15 ± 0,05	1,04 ± 0,05	-117°	-120°	4°
Normal condition	1	1	1	1	-120°	120°	0°

**FRT test for two-phase asymmetrical fault (Test ref no. x.3.x)**




## 5.8.1 General

P



Typ-B



## Legende



- & — FRT-Kurve für 1-, 2- und 3-polige Netzfehler
- UG Effektivwert der aktuellen Spannung an den Generatorklemmen

**Bild 12 – Fault-Ride-Through-Grenzkurve für den Spannungsverlauf an den Generatorklemmen für eine Erzeugungseinheit vom Typ 2 und für Speicher**

Figure 12 - Fault ride-through limit curve for the voltage curve at the generator terminals for a **type 2** generation unit and for storage


5.8.3 Testing of the dynamic grid support									P
For PGUs Type 2 and storage systems									P
1-phase systems									
Test	Voltage dip to [p.u.]	Dip type	duration [s]	P set point [p.u.]	Q set point [p.u.]	Comment	Recovery response time [s]		Test ref. No.*
							P	Q	
1	0,15 to 0,25	A	for 0,15 ≥0,150	1	0 to ± 0,1	Symmetric	0,380	0	1.1
				0,2 to 0,6			0,077	0	1.2
		D1 <sup>1)</sup>	/	1		Asymmetric (ph-ph + Dy5- transformer)	0,379	0	1.3
				0,2 to 0,6			0,087	0	1.4
		D2 <sup>2)</sup>		1			0,381	0	1.5
2	0,50 to 0,60	A	for 0,50 ≥1,500	1	Max. over excited	Symmetric	0,367	9,804	2.1
				0,2 to 0,6			0,068	9,765	2.2
		D1 <sup>1)</sup>	/	1		Asymmetric (ph-ph + Dy5- transformer)	0,373	9,998	2.3
				0,2 to 0,6			0,061	9,989	2.4
3	0,50 to 0,60	A	for 0,50 ≥1,500	1	Max. under excited	Symmetric	0,370	9,205	3.1
				0,2 to 0,6			0,068	9,824	3.2
		D1 <sup>1)</sup>	/	1		Asymmetric (ph-ph + Dy5- transformer)	0,389	9,670	3.3
				0,2 to 0,6			0,062	9,895	3.4
4	0,85 to 0,90	A	≥60,000	1	0 to ± 0,1	Symmetric	0,002	0	4.1
				0,2 to 0,6			0,050	0	4.2
		D1 <sup>1)</sup>		1		Asymmetric (ph-ph + Dy5- transformer)	0,054	0	4.3
				0,2 to 0,6			0,054	0	4.4
5	1,20 to 1,25	A	≥0,100	1	0 to ± 0,1	Symmetric	0,362	0	5.1
				0,2 to 0,6			0,061	0	5.2
		D1 <sup>1)</sup>		1		Asymmetric (ph-ph + Dy5- transformer)	0,261	0	5.3
				0,2 to 0,6			0,165	0	5.4
		D2 <sup>2)</sup>				1		0,369	0
6	1,15 to 1,20	A	≥5,000	1	0 to ± 0,1	Symmetric	0,362	0	6.1
				0,2 to 0,6			0,061	0	6.2
		D1 <sup>1)</sup>		1		Asymmetric (ph-ph + Dy5- transformer)	0,261	0	6.3
				0,2 to 0,6			0,122	0	6.4
7	1,10 to 1,15	A	≥60,000	1	0 to ± 0,1	Symmetric	0,362	0	7.1
				0,2 to 0,6			0,061	0	7.2
		D1 <sup>1)</sup>		1		Asymmetric (ph-ph + Dy5- transformer)	0,260	0	7.3
				0,2 to 0,6			0,488	0	7.4

5.8.3 Testing of the dynamic grid support	P
<p><b>Note:</b></p> <p>At least the recording must begin at least 10s before the error occurs. After a faulty declaration (Voltage in the range <math>0,85 U_n \leq U \leq 1,1U_n</math>), the recording must continue for at least another 60s.</p> <p>Behaviour during the network error:</p> <p>No disconnection of the PGU during the voltage drops the grid. If the PGU disconnects from the grid, the time of disconnection must be documented.</p> <ul style="list-style-type: none"> <li>Type 2 units and storage systems are not allowed to inject either active or reactive current during a line voltage at the PGUs terminals below <math>0,8 U_n</math> and above <math>1,15 U_n</math>. This requirement is met if, in the event of an under-/ under voltage dip, the injected current of the generating unit and / or the storage systems does not exceed 20% of the rated current <math>I_r</math> and no more than 10% <math>I_r</math> after 0,06s after the occurrence of this under-/ under voltage dip in any phase.</li> </ul> <p>Behaviour after the end of the error:</p> <ul style="list-style-type: none"> <li>Not disconnection of the PGU within 60s after the end of the fault.</li> <li>Type 2 units and storage systems: Reaction time of active power up to 1s, Reaction time of reactive power according to PT1 behaviour with <math>3\tau = 10s</math> in accordance with VDE-AR-N 4105: 2018-11, 5.7.2.5</li> </ul> <p>Table above shows test sequences for single-phase unit.</p> <ul style="list-style-type: none"> <li><sup>1)</sup> One-phase EZE are connected to the phase W and N for error pattern D1</li> <li><sup>2)</sup> One-phase EZE are connected to the phase V and N for error pattern D2</li> </ul> <p>The test has been performed twice and only show one times tested result in the test report.</p> <p>The test results of the <b>WVC-800</b> can be applied to other units in the product series directly, since it is identical in hardware and just power derated by software.</p>	

**5.8.3 For PGUs Type 2 and storage systems – no load**
**P**
**1.1**

**1.3**



<b>5.8.3</b>	<b>For PGUs Type 2 and storage systems – no load</b>	<b>P</b>
--------------	--	----------

**1.5**




**5.8.3 For PGUs Type 2 and storage systems – no load P**


**2.1**



**2.3**




**5.8.3 For PGUs Type 2 and storage systems – no load**
**P**
**3.1**


**3.3**


**5.8.3** For PGUs Type 2 and storage systems – no load **P**

**4.1**




**4.3**






**5.8.3** For PGUs Type 2 and storage systems – no load **P**

**5.1**




**5.3**



<b>5.8.3</b>	<b>For PGUs Type 2 and storage systems – no load</b>	<b>P</b>
--------------	--	----------

**5.5**




5.8.3


For PGUs Type 2 and storage systems – no load

P

6.1



6.3




**5.8.3 For PGUs Type 2 and storage systems – no load P**

**7.1**



**7.3**




**5.8.3 For PGUs Type 2 and storage systems P**
**1.1**

Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	1.1	
	1	Date	--	--	yyyy.mm.dd	2022.12.4	
	2	Time (start of test)	--	--	hh:mm:ss.f	16:50:22	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,15
	5	Setting dip duration	--	--	--	--	150
		Point of fault entry	Total	--	--	ms	10752
	7	Point of fault clearance	Total	--	--	ms	10902
	8	Fault duration in empty load test	Total	--	--	ms	150
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	0,150	
	10		Phase 2			0,149	
	11		Phase 3			0,150	
12	Total		1,001				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,002	
	14		Phase 2			1,000	
	15		Phase 3			1,001	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	1,009	
	17	Active power	Total	t1-10s to t1	p.u.	1,004	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,041	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	0,993		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,150	
	23		Phase 2			0,150	
	24		Phase 3			0,150	
	25	Line current	Phase 1	t1+60ms	p.u.	0,012	
	26		Phase 2			--	
	27		Phase 3			--	
	28	Line current	Phase 1	t1+100ms	p.u.	0,012	
	29		Phase 2			--	
	30		Phase 3			--	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,000	
32	Pos.		--				
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,002	
	34		Phase 2			1,000	
	35		Phase 3			1,001	
	36	Active power	Total	t2+3s to t2+10s	p.u.	1,004	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,305	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,041	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems


P



5.8.3

For PGUs Type 2 and storage systems


P




5.8.3		For PGUs Type 2 and storage systems				P	
1.2							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	1.2	
	1	Date	--	--	yyyy.mm.dd	2022.12.4	
	2	Time (start of test)	--	--	hh:mm:ss.f	16:57:58	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,15
	5	Setting dip duration		--	--	--	150
			Point of fault entry	Total	--	ms	10752
	7		Point of fault clearance	Total	--	ms	10902
	8		Fault duration in empty load test	Total	--	ms	150
	9	Voltage depth/height in empty load test		Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	0,150
	10			Phase 2			0,149
	11			Phase 3			0,150
12			Total	1,001			
Before dip <t1	13	Voltage		Phase 1	t1-10s to t1	p.u.	1,001
	14			Phase 2			1,000
	15			Phase 3			1,001
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,224	
	17	Active power		Total	t1-10s to t1	p.u.	0,220
	18			Pos.			--
	19	Reactive power		Total	t1-10s to t1	p.u.	0,049
	20			Pos.			--
21	Cosφ	Total	t1-10s to t1	--	0,976		
During dip t1 to t2	22	Voltage		Phase 1	t1+100ms to t2-20ms	p.u.	0,150
	23			Phase 2			0,150
	24			Phase 3			0,150
	25	Line current		Phase 1	t1+60ms	p.u.	0,014
	26			Phase 2			--
	27			Phase 3			--
	28	Line current		Phase 1	t1+100ms	p.u.	0,014
	29			Phase 2			--
	30			Phase 3			--
	31	Active power		Total	t1+100ms to t2-20ms	p.u.	0,000
	32			Pos.			--
After dip > t2	33	Voltage		Phase 1	t2+3s to t2+10s	p.u.	1,001
	34			Phase 2			1,000
	35			Phase 3			1,001
	36	Active power		Total	t2+3s to t2+10s	p.u.	0,220
	37			Pos.			--
	38	Active power rising time	Total	--	s	0,452	
	39	Reactive power		Total	t2+3s to t2+10s	p.u.	0,039
	40			Pos.			--
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	--	t2 to t2+60s	Yes / No	Yes



**5.8.3 For PGUs Type 2 and storage systems** **P**





**5.8.3**
**For PGUs Type 2 and storage systems**
**P**


**5.8.3 For PGUs Type 2 and storage systems P**
**1.3**

Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	1.3	
	1	Date	--	--	yyyy.mm.dd	2022.12.4	
	2	Time (start of test)	--	--	hh:mm:ss.f	18:18:34	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,15
	5	Setting dip duration	--	--	--	--	150
		Point of fault entry	Total	--	--	ms	10723
	7	Point of fault clearance	Total	--	--	ms	10873
	8	Fault duration in empty load test	Total	--	--	ms	150
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	0,617	
	10		Phase 2			0,150	
	11		Phase 3			0,616	
12	Total		1,001				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,001	
	14		Phase 2			1,000	
	15		Phase 3			1,002	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,995	
	17	Active power	Total	t1-10s to t1	p.u.	0,989	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,039	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	0,993		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,617	
	23		Phase 2			0,149	
	24		Phase 3			0,615	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,011	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,011	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,001	
32	Pos.		--				
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,001	
	34		Phase 2			1,000	
	35		Phase 3			1,002	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,991	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,439	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,040	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

**5.8.3 For PGUs Type 2 and storage systems P**




**5.8.3**
**For PGUs Type 2 and storage systems**
**P**


**5.8.3 For PGUs Type 2 and storage systems P**
**1.4**

Condition						Measured value
Item	No.	Parameter	Phase ref.	Time ref.	unit	
General Info.	0	Test number	--	--	--	1.4
	1	Date	--	--	yyyy.mm.dd	2022.12.4
	2	Time (start of test)	--	--	hh:mm:ss.f	18:21:42
	3	Fault type (phase)	--	--	--	D1
	4	Setting voltage depth	Line to line	--	p.u.	0,15
	5	Setting dip duration		--	--	150
		Point of fault entry	Total	--	ms	10723
	7	Point of fault clearance	Total	--	ms	10873
	8	Fault duration in empty load test	Total	--	ms	150
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	0,615
	10		Phase 2			0,149
	11		Phase 3			0,615
12	Total		1,001			
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,002
	14		Phase 2			1,000
	15		Phase 3			1,001
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,227
	17	Active power	Total	t1-10s to t1	p.u.	0,222
	18		Pos.			--
	19	Reactive power	Total	t1-10s to t1	p.u.	0,050
	20		Pos.			--
21	Cosφ	Total	t1-10s to t1	--	0,976	
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,617
	23		Phase 2			0,149
	24		Phase 3			0,616
	25	Line current	Phase 1	t1+60ms	p.u.	--
	26		Phase 2			--
	27		Phase 3			0,012
	28	Line current	Phase 1	t1+100ms	p.u.	--
	29		Phase 2			--
	30		Phase 3			0,010
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,001
	32		Pos.			--
	After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.
34		Phase 2		1,000		
35		Phase 3		1,002		
36		Active power	Total	t2+3s to t2+10s	p.u.	0,221
37			Pos.			--
38		Active power rising time	Total	--	s	0,406
39		Reactive power	Total	t2+3s to t2+10s	p.u.	0,038
40			Pos.			--
41		Reactive power rising time	total	--	s	--
42		PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes


**5.8.3 For PGUs Type 2 and storage systems P**



## 5.8.3

## For PGUs Type 2 and storage systems



P






5.8.3		For PGUs Type 2 and storage systems				P	
1.5							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	1.5	
	1	Date	--	--	yyyy.mm.dd	2022.12.12	
	2	Time (start of test)	--	--	hh:mm:ss.f	20:39:57	
	3	Fault type (phase)	--	--	--	D2	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,15
	5	Setting dip duration	--	--	--	--	150
		Point of fault entry	Total	--	--	ms	10723
	7	Point of fault clearance	Total	--	--	ms	10873
	8	Fault duration in empty load test	Total	--	--	ms	150
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	0,615	
	10		Phase 2			0,149	
	11		Phase 3			0,615	
12	Total		1,001				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,001	
	14		Phase 2			1,001	
	15		Phase 3			1,002	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	1,003	
	17	Active power	Total	t1-10s to t1	p.u.	0,986	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,007	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	0,992		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,615	
	23		Phase 2			0,149	
	24		Phase 3			0,616	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			0,015	
	27		Phase 3			--	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			0,013	
	30		Phase 3			--	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,000	
	32		Pos.			--	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,001	
	34		Phase 2			1,001	
	35		Phase 3			1,002	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,984	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,469	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,002	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

**5.8.3 For PGUs Type 2 and storage systems P**







**5.8.3**
**For PGUs Type 2 and storage systems**
**P**


**5.8.3 For PGUs Type 2 and storage systems P**
**2.1**

Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	2.1	
	1	Date	--	--	yyyy.mm.dd	2022.12.12	
	2	Time (start of test)	--	--	hh:mm:ss.f	20:28:21	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,5
	5	Setting dip duration	--	--	--	--	1500
		Point of fault entry	Total	--	--	ms	10610
	7	Point of fault clearance	Total	--	--	ms	12110
	8	Fault duration in empty load test	Total	--	--	ms	1500
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	0,500	
	10		Phase 2			0,501	
	11		Phase 3			0,501	
12	Total		1,001				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,001	
	14		Phase 2			1,000	
	15		Phase 3			1,002	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	1,016	
	17	Active power	Total	t1-10s to t1	p.u.	0,947	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,278	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	0,959		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,501	
	23		Phase 2			0,500	
	24		Phase 3			0,501	
	25	Line current	Phase 1	t1+60ms	p.u.	0,014	
	26		Phase 2			--	
	27		Phase 3			--	
	28	Line current	Phase 1	t1+100ms	p.u.	0,014	
	29		Phase 2			--	
	30		Phase 3			--	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,001	
	32		Pos.			--	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,001	
	34		Phase 2			1,000	
	35		Phase 3			1,002	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,951	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,311	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,227	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	9,553	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

**5.8.3 For PGUs Type 2 and storage systems** **P**



**5.8.3**
**For PGUs Type 2 and storage systems**
**P**



**5.8.3 For PGUs Type 2 and storage systems P**
**2.2**

Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	2.2	
	1	Date	--	--	yyyy.mm.dd	2022.12.12	
	2	Time (start of test)	--	--	hh:mm:ss.f	16:18:01	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,5
	5	Setting dip duration	--	--	--	--	1500
		Point of fault entry	Total	--	--	ms	10610
	7	Point of fault clearance	Total	--	--	ms	12110
	8	Fault duration in empty load test	Total	--	--	ms	1500
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	0,500	
	10		Phase 2			0,501	
	11		Phase 3			0,501	
12	Total		1,001				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,001	
	14		Phase 2			1,000	
	15		Phase 3			1,001	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,201	
	17	Active power	Total	t1-10s to t1	p.u.	0,203	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,064	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	0,956		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,501	
	23		Phase 2			0,501	
	24		Phase 3			0,501	
	25	Line current	Phase 1	t1+60ms	p.u.	0,064	
	26		Phase 2			--	
	27		Phase 3			--	
	28	Line current	Phase 1	t1+100ms	p.u.	0,020	
	29		Phase 2			--	
	30		Phase 3			--	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,001	
	32		Pos.			--	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,001	
	34		Phase 2			1,001	
	35		Phase 3			1,002	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,204	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,239	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,052	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	9,712	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems

P







## 5.8.3

## For PGUs Type 2 and storage systems

P







**5.8.3 For PGUs Type 2 and storage systems P**
**2.3**



Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	2.3	
	1	Date	--	--	yyyy.mm.dd	2022.12.12	
	2	Time (start of test)	--	--	hh:mm:ss.f	19:49:37	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,5
	5	Setting dip duration	--	--	--	--	1500
		Point of fault entry	Total	--	--	ms	10610
	7	Point of fault clearance	Total	--	--	ms	12111
	8	Fault duration in empty load test	Total	--	--	ms	1501
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	0,760	
	10		Phase 2			0,501	
	11		Phase 3			0,760	
12	Total		1,001				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,001	
	14		Phase 2			1,001	
	15		Phase 3			1,002	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	1,001	
	17	Active power	Total	t1-10s to t1	p.u.	0,945	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,312	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	0,950		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,761	
	23		Phase 2			0,500	
	24		Phase 3			0,761	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,034	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,034	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,001	
	32		Pos.			--	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,001	
	34		Phase 2			1,001	
	35		Phase 3			1,002	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,951	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,248	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,254	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	9,598	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems

P






**5.8.3 For PGUs Type 2 and storage systems**
**P**


5.8.3		For PGUs Type 2 and storage systems				P	
2.4							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	2.4	
	1	Date	--	--	yyyy.mm.dd	2022.12.12	
	2	Time (start of test)	--	--	hh:mm:ss.f	19:52:36	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,5
	5	Setting dip duration	--	--	--	--	1500
			Point of fault entry	Total	--	ms	10610
	7		Point of fault clearance	Total	--	ms	12111
	8		Fault duration in empty load test	Total	--	ms	1501
	9	Voltage depth/height in empty load test		Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	0,760
	10			Phase 2			0,501
	11			Phase 3			0,760
12			Total	1,001			
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,001	
	14		Phase 2			1,001	
	15		Phase 3			1,002	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,200	
	17	Active power	Total	t1-10s to t1	p.u.	0,226	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,234	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	0,952		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,761	
	23		Phase 2			0,500	
	24		Phase 3			0,761	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,034	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,035	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,001	
32	Pos.		--				
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,001	
	34		Phase 2			1,001	
	35		Phase 3			1,002	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,226	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,236	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,066	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	9,628	
	42	PGU does not disconnect from grid till 60s after fault	--	--	t2 to t2+60s	Yes / No	Yes

5.8.3

For PGUs Type 2 and storage systems



P



## 5.8.3

## For PGUs Type 2 and storage systems

P



<b>5.8.3</b>	<b>For PGUs Type 2 and storage systems</b>	<b>P</b>
--------------	--	----------

**3.1**


Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	3.1	
	1	Date	--	--	yyyy.mm.dd	2022.12.12	
	2	Time (start of test)	--	--	hh:mm:ss.f	14:20:05	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,5
	5	Setting dip duration		--	--	--	1500
		Point of fault entry	Total	--	--	ms	10610
	7	Point of fault clearance	Total	--	--	ms	12110
	8	Fault duration in empty load test	Total	--	--	ms	1500
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	0,500	
	10		Phase 2			0,501	
	11		Phase 3			0,501	
12	Total		1,001				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,001	
	14		Phase 2			1,001	
	15		Phase 3			1,002	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	1,030	
	17	Active power	Total	t1-10s to t1	p.u.	0,958	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	-0,296	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	0,954		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,501	
	23		Phase 2			0,500	
	24		Phase 3			0,501	
	25	Line current	Phase 1	t1+60ms	p.u.	0,012	
	26		Phase 2			--	
	27		Phase 3			--	
	28	Line current	Phase 1	t1+100ms	p.u.	0,012	
	29		Phase 2			--	
	30		Phase 3			--	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,001	
	32		Pos.			--	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,001	
	34		Phase 2			1,001	
	35		Phase 3			1,002	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,962	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,287	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	-0,251	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	9,712	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	



5.8.3

For PGUs Type 2 and storage systems



P



## 5.8.3

## For PGUs Type 2 and storage systems


P





**5.8.3 For PGUs Type 2 and storage systems P**
**3.2**

Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	3.2	
	1	Date	--	--	yyyy.mm.dd	2022.12.12	
	2	Time (start of test)	--	--	hh:mm:ss.f	16:13:57	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,5
	5	Setting dip duration	--	--	--	--	1500
		Point of fault entry	Total	--	--	ms	10610
	7	Point of fault clearance	Total	--	--	ms	12110
	8	Fault duration in empty load test	Total	--	--	ms	1500
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	0,500	
	10		Phase 2			0,501	
	11		Phase 3			0,501	
12	Total		1,001				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,001	
	14		Phase 2			1,001	
	15		Phase 3			1,002	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,248	
	17	Active power	Total	t1-10s to t1	p.u.	0,217	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	-0,067	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	0,954		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,501	
	23		Phase 2			0,501	
	24		Phase 3			0,501	
	25	Line current	Phase 1	t1+60ms	p.u.	0,013	
	26		Phase 2			--	
	27		Phase 3			--	
	28	Line current	Phase 1	t1+100ms	p.u.	0,012	
	29		Phase 2			--	
	30		Phase 3			--	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,001	
	32		Pos.			--	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,001	
	34		Phase 2			1,001	
	35		Phase 3			1,002	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,217	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,260	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	-0,055	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	9,261	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

**5.8.3 For PGUs Type 2 and storage systems** **P**



**5.8.3 For PGUs Type 2 and storage systems**
**P**




**5.8.3 For PGUs Type 2 and storage systems P**
**3.3**

Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	3.3	
	1	Date	--	--	yyyy.mm.dd	2022.12.12	
	2	Time (start of test)	--	--	hh:mm:ss.f	19:58:47	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,5
	5	Setting dip duration	--	--	--	--	1500
		Point of fault entry	Total	--	--	ms	10610
	7	Point of fault clearance	Total	--	--	ms	12111
	8	Fault duration in empty load test	Total	--	--	ms	1501
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	0,760	
	10		Phase 2			0,501	
	11		Phase 3			0,760	
12	Total		1,001				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,001	
	14		Phase 2			1,001	
	15		Phase 3			1,002	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	1,005	
	17	Active power	Total	t1-10s to t1	p.u.	0,957	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	-0,290	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	0,957		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,761	
	23		Phase 2			0,500	
	24		Phase 3			0,760	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,033	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,034	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,001	
	32		Pos.			--	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,001	
	34		Phase 2			1,001	
	35		Phase 3			1,002	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,960	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,208	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	-0,239	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	9,653	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems



P



## 5.8.3

## For PGUs Type 2 and storage systems

P









**5.8.3 For PGUs Type 2 and storage systems P**
**3.4**

Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	3.4	
	1	Date	--	--	yyyy.mm.dd	2022.12.13	
	2	Time (start of test)	--	--	hh:mm:ss.f	21:53:52	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,5
	5	Setting dip duration	--	--	--	--	1500
		Point of fault entry	Total	--	--	ms	10610
	7	Point of fault clearance	Total	--	--	ms	12111
	8	Fault duration in empty load test	Total	--	--	ms	1501
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	0,760	
	10		Phase 2			0,501	
	11		Phase 3			0,760	
12	Total		1,001				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,002	
	14		Phase 2			1,001	
	15		Phase 3			1,002	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,201	
	17	Active power	Total	t1-10s to t1	p.u.	0,202	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	-0,064	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	0,954		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,761	
	23		Phase 2			0,500	
	24		Phase 3			0,761	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,089	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,031	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,001	
	32		Pos.			--	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,001	
	34		Phase 2			1,001	
	35		Phase 3			1,002	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,201	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,087	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	-0,053	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	9,501	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems



P



## 5.8.3

## For PGUs Type 2 and storage systems



P




**5.8.3 For PGUs Type 2 and storage systems P**
**4.1**

Condition						Measured value
Item	No.	Parameter	Phase ref.	Time ref.	unit	
General Info.	0	Test number	--	--	--	4.1
	1	Date	--	--	yyyy.mm.dd	2022.12.12
	2	Time (start of test)	--	--	hh:mm:ss.f	20:35:38
	3	Fault type (phase)	--	--	--	A
	4	Setting voltage depth	Line to line	--	p.u.	0,85
	5	Setting dip duration		--	--	60000
		Point of fault entry	Total	--	ms	10798
	7	Point of fault clearance	Total	--	ms	70798
	8	Fault duration in empty load test	Total	--	ms	60000
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	0,851
	10		Phase 2			0,851
	11		Phase 3			0,851
12	Total		1,001			
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,001
	14		Phase 2			1,000
	15		Phase 3			1,001
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	1,007
	17	Active power	Total	t1-10s to t1	p.u.	1,001
	18		Pos.			--
	19	Reactive power	Total	t1-10s to t1	p.u.	0,006
	20		Pos.			--
21	Cosφ	Total	t1-10s to t1	--	0,999	
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,851
	23		Phase 2			0,851
	24		Phase 3			0,852
	25	Line current	Phase 1	t1+60ms	p.u.	0,097
	26		Phase 2			--
	27		Phase 3			--
	28	Line current	Phase 1	t1+100ms	p.u.	0,095
	29		Phase 2			--
	30		Phase 3			--
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,971
	32		Pos.			--
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,001
	34		Phase 2			1,001
	35		Phase 3			1,002
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,995
	37		Pos.			--
	38	Active power rising time	Total	--	s	0,018
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,005
	40		Pos.			--
	41	Reactive power rising time	total	--	s	--
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes

**5.8.3 For PGUs Type 2 and storage systems P**



**5.8.3**
**For PGUs Type 2 and storage systems**
**P**



**5.8.3 For PGUs Type 2 and storage systems P**
**4.2**

Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	4.2	
	1	Date	--	--	yyyy.mm.dd	2022.12.12	
	2	Time (start of test)	--	--	hh:mm:ss.f	12:03:19	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,85
	5	Setting dip duration	--	--	--	--	60000
		Point of fault entry	Total	--	--	ms	10798
	7	Point of fault clearance	Total	--	--	ms	70798
	8	Fault duration in empty load test	Total	--	--	ms	60000
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	0,851	
	10		Phase 2			0,851	
	11		Phase 3			0,851	
12	Total		1,001				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,001	
	14		Phase 2			1,001	
	15		Phase 3			1,002	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,248	
	17	Active power	Total	t1-10s to t1	p.u.	0,243	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,031	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	0,992		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,851	
	23		Phase 2			0,851	
	24		Phase 3			0,851	
	25	Line current	Phase 1	t1+60ms	p.u.	0,096	
	26		Phase 2			--	
	27		Phase 3			--	
	28	Line current	Phase 1	t1+100ms	p.u.	0,095	
	29		Phase 2			--	
	30		Phase 3			--	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,241	
	32		Pos.			--	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,001	
	34		Phase 2			1,001	
	35		Phase 3			1,002	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,242	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,292	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,031	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	


5.8.3

For PGUs Type 2 and storage systems

P







**5.8.3**
**For PGUs Type 2 and storage systems**
**P**


<b>5.8.3</b>	<b>For PGUs Type 2 and storage systems</b>	<b>P</b>
--------------	--	----------


**4.3**

Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	4.3	
	1	Date	--	--	yyyy.mm.dd	2022.12.12	
	2	Time (start of test)	--	--	hh:mm:ss.f	19:36:20	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,85
	5	Setting dip duration	--	--	--	--	60000
		Point of fault entry	Total	--	--	ms	21271
	7	Point of fault clearance	Total	--	--	ms	81406
	8	Fault duration in empty load test	Total	--	--	ms	60005
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	0,931	
	10		Phase 2			0,852	
	11		Phase 3			0,931	
12	Total		1,001				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,001	
	14		Phase 2			1,001	
	15		Phase 3			1,002	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	1,001	
	17	Active power	Total	t1-10s to t1	p.u.	0,986	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,015	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	0,991		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,931	
	23		Phase 2			0,851	
	24		Phase 3			0,932	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			1,059	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			1,057	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,971	
	32		Pos.			--	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,001	
	34		Phase 2			1,001	
	35		Phase 3			1,002	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,979	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,153	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,005	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

**5.8.3 For PGUs Type 2 and storage systems** **P**



**5.8.3** For PGUs Type 2 and storage systems **P**






<b>5.8.3</b>	<b>For PGUs Type 2 and storage systems</b>	<b>P</b>
--------------	--	----------

**4.4**

Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	4.4	
	1	Date	--	--	yyyy.mm.dd	2022.12.12	
	2	Time (start of test)	--	--	hh:mm:ss.f	16:36:22	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	0,85
	5	Setting dip duration	--	--	--	--	60000
		Point of fault entry	Total	--	--	ms	21271
	7	Point of fault clearance	Total	--	--	ms	81406
	8	Fault duration in empty load test	Total	--	--	ms	60005
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	0,931	
	10		Phase 2			0,852	
	11		Phase 3			0,931	
12	Total		1,001				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,002	
	14		Phase 2			1,001	
	15		Phase 3			1,002	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,242	
	17	Active power	Total	t1-10s to t1	p.u.	0,236	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,055	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	0,997		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	0,932	
	23		Phase 2			0,851	
	24		Phase 3			0,932	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,261	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,262	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,236	
	32		Pos.			--	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,002	
	34		Phase 2			1,001	
	35		Phase 3			1,002	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,237	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,418	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,056	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

**5.8.3 For PGUs Type 2 and storage systems P**




**5.8.3**
**For PGUs Type 2 and storage systems**
**P**


**5.8.3 For PGUs Type 2 and storage systems P**
**5.1**

Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	5.1	
	1	Date	--	--	yyyy.mm.dd	2022.12.4	
	2	Time (start of test)	--	--	hh:mm:ss.f	17:50:17	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	1,25
	5	Setting dip duration	--	--	--	--	100
		Point of fault entry	Total	--	--	ms	10556
	7	Point of fault clearance	Total	--	--	ms	10656
	8	Fault duration in empty load test	Total	--	--	ms	100
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	1,232	
	10		Phase 2			1,235	
	11		Phase 3			1,235	
12	Total		1,001				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,002	
	14		Phase 2			1,000	
	15		Phase 3			1,001	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	1,003	
	17	Active power	Total	t1-10s to t1	p.u.	0,992	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,024	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	0,993		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	1,232	
	23		Phase 2			1,233	
	24		Phase 3			1,234	
	25	Line current	Phase 1	t1+60ms	p.u.	0,012	
	26		Phase 2			--	
	27		Phase 3			--	
	28	Line current	Phase 1	t1+100ms	p.u.	0,011	
	29		Phase 2			--	
	30		Phase 3			--	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,000	
32	Pos.		--				
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,002	
	34		Phase 2			1,000	
	35		Phase 3			1,001	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,996	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,396	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,026	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	




**5.8.3** For PGUs Type 2 and storage systems **P**



## 5.8.3


## For PGUs Type 2 and storage systems

P



5.8.3		For PGUs Type 2 and storage systems				P	
5.2							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	5.2	
	1	Date	--	--	yyyy.mm.dd	2022.12.4	
	2	Time (start of test)	--	--	hh:mm:ss.f	17:42:42	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	1,25
	5	Setting dip duration	--	--	--	--	100
		Point of fault entry	Total	--	--	ms	10556
	7	Point of fault clearance	Total	--	--	ms	10656
	8	Fault duration in empty load test	Total	--	--	ms	100
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	1,232	
	10		Phase 2			1,235	
	11		Phase 3			1,235	
12	Total		1,001				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,001	
	14		Phase 2			1,000	
	15		Phase 3			1,001	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,226	
	17	Active power	Total	t1-10s to t1	p.u.	0,219	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,041	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	0,983		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	1,232	
	23		Phase 2			1,232	
	24		Phase 3			1,234	
	25	Line current	Phase 1	t1+60ms	p.u.	0,012	
	26		Phase 2			--	
	27		Phase 3			--	
	28	Line current	Phase 1	t1+100ms	p.u.	0,011	
	29		Phase 2			--	
	30		Phase 3			--	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,002	
	32		Pos.			--	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,001	
	34		Phase 2			1,000	
	35		Phase 3			1,001	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,218	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,302	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,042	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	


**5.8.3 For PGUs Type 2 and storage systems P**



## 5.8.3



## For PGUs Type 2 and storage systems


P



5.8.3		For PGUs Type 2 and storage systems				P	
5.3							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	5.3	
	1	Date	--	--	yyyy.mm.dd	2022.12.12	
	2	Time (start of test)	--	--	hh:mm:ss.f	19:29:29	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	1,25
	5	Setting dip duration	--	--	--	--	100
		Point of fault entry	Total	--	--	ms	10586
	7	Point of fault clearance	Total	--	--	ms	10686
	8	Fault duration in empty load test	Total	--	--	ms	100
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	1,087	
	10		Phase 2			1,235	
	11		Phase 3			1,067	
12	Total		1,002				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,001	
	14		Phase 2			1,001	
	15		Phase 3			1,002	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,998	
	17	Active power	Total	t1-10s to t1	p.u.	0,991	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,006	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	0,999		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	1,086	
	23		Phase 2			1,262	
	24		Phase 3			1,065	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,950	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,946	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,998	
	32		Pos.			--	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,001	
	34		Phase 2			1,001	
	35		Phase 3			1,002	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,990	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,035	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,006	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

<b>5.8.3</b>	<b>For PGUs Type 2 and storage systems</b>	<b>P</b>
--------------	--	----------




**5.8.3**
**For PGUs Type 2 and storage systems**
**P**




5.8.3		For PGUs Type 2 and storage systems				P	
5.4							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	5.4	
	1	Date	--	--	yyyy.mm.dd	2022.12.12	
	2	Time (start of test)	--	--	hh:mm:ss.f	19:31:57	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	1,25
	5	Setting dip duration	--	--	--	--	100
			Point of fault entry	Total	--	ms	10586
	7	Point of fault clearance	Total	--	--	ms	10686
	8	Fault duration in empty load test	Total	--	--	ms	100
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	1,087	
	10		Phase 2			1,235	
	11		Phase 3			1,067	
12	Total		1,002				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,001	
	14		Phase 2			1,001	
	15		Phase 3			1,002	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,228	
	17	Active power	Total	t1-10s to t1	p.u.	0,217	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,073	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	0,978		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	1,086	
	23		Phase 2			1,263	
	24		Phase 3			1,065	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,216	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,216	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,218	
32	Pos.		--				
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,001	
	34		Phase 2			1,001	
	35		Phase 3			1,002	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,217	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,056	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,073	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	


**5.8.3 For PGUs Type 2 and storage systems** **P**



## 5.8.3

## For PGUs Type 2 and storage systems

P






5.8.3		For PGUs Type 2 and storage systems				P	
5.5							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	5.5	
	1	Date	--	--	yyyy.mm.dd	2022.12.12	
	2	Time (start of test)	--	--	hh:mm:ss.f	20:48:04	
	3	Fault type (phase)	--	--	--	D2	
	4	Setting voltage depth	Line to line	--	--	p.u.	1,25
	5	Setting dip duration	--	--	--	--	100
		Point of fault entry	Total	--	--	ms	10586
	7	Point of fault clearance	Total	--	--	ms	10686
	8	Fault duration in empty load test	Total	--	--	ms	100
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	1,087	
	10		Phase 2			1,235	
	11		Phase 3			1,067	
12	Total		1,002				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,001	
	14		Phase 2			1,001	
	15		Phase 3			1,002	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	1,001	
	17	Active power	Total	t1-10s to t1	p.u.	0,986	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,003	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	0,992		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	1,087	
	23		Phase 2			1,263	
	24		Phase 3			1,065	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			0,015	
	27		Phase 3			--	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			0,014	
	30		Phase 3			--	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,001	
32	Pos.		--				
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,001	
	34		Phase 2			1,001	
	35		Phase 3			1,002	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,985	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,377	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,004	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems


P



**5.8.3**
**For PGUs Type 2 and storage systems**
**P**


5.8.3		For PGUs Type 2 and storage systems				P	
6.1							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	6.1	
	1	Date	--	--	yyyy.mm.dd	2022.12.4	
	2	Time (start of test)	--	--	hh:mm:ss.f	17:56:22	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	1,2
	5	Setting dip duration	--	--	--	--	5000
		Point of fault entry	Total	--	--	ms	10861
	7	Point of fault clearance	Total	--	--	ms	15861
	8	Fault duration in empty load test	Total	--	--	ms	5000
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	1,201	
	10		Phase 2			1,202	
	11		Phase 3			1,201	
12	Total		1,001				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,002	
	14		Phase 2			1,000	
	15		Phase 3			1,001	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,995	
	17	Active power	Total	t1-10s to t1	p.u.	0,991	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,039	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	0,993		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	1,201	
	23		Phase 2			1,200	
	24		Phase 3			1,201	
	25	Line current	Phase 1	t1+60ms	p.u.	0,013	
	26		Phase 2			--	
	27		Phase 3			--	
	28	Line current	Phase 1	t1+100ms	p.u.	0,012	
	29		Phase 2			--	
	30		Phase 3			--	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,002	
	32		Pos.			--	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,002	
	34		Phase 2			1,000	
	35		Phase 3			1,001	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,993	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,567	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,038	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

**5.8.3 For PGUs Type 2 and storage systems P**






## 5.8.3

## For PGUs Type 2 and storage systems

P





5.8.3		For PGUs Type 2 and storage systems				P	
6.2							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	6.2	
	1	Date	--	--	yyyy.mm.dd	2022.12.12	
	2	Time (start of test)	--	--	hh:mm:ss.f	13:32:30	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	1,2
	5	Setting dip duration		--	--	--	5000
			Point of fault entry	Total	--	ms	10861
	7		Point of fault clearance	Total	--	ms	15861
	8		Fault duration in empty load test	Total	--	ms	5000
	9	Voltage depth/height in empty load test		Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	1,201
	10			Phase 2			1,202
	11			Phase 3			1,201
12			Total	1,001			
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,001	
	14		Phase 2			1,000	
	15		Phase 3			1,002	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,216	
	17	Active power	Total	t1-10s to t1	p.u.	0,208	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,032	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	0,988		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	1,201	
	23		Phase 2			1,200	
	24		Phase 3			1,202	
	25	Line current	Phase 1	t1+60ms	p.u.	0,060	
	26		Phase 2			--	
	27		Phase 3			--	
	28	Line current	Phase 1	t1+100ms	p.u.	0,021	
	29		Phase 2			--	
	30		Phase 3			--	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,002	
	32		Pos.			--	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,001	
	34		Phase 2			1,000	
	35		Phase 3			1,002	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,209	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,551	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,033	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3

For PGUs Type 2 and storage systems


P




**5.8.3**
**For PGUs Type 2 and storage systems**
**P**


5.8.3		For PGUs Type 2 and storage systems				P	
6.3							
Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	6.3	
	1	Date	--	--	yyyy.mm.dd	2022.12.12	
	2	Time (start of test)	--	--	hh:mm:ss.f	19:26:55	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	1,2
	5	Setting dip duration	--	--	--	--	5000
		Point of fault entry	Total	--	--	ms	10599
	7	Point of fault clearance	Total	--	--	ms	15590
	8	Fault duration in empty load test	Total	--	--	ms	4991
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	1,061	
	10		Phase 2			1,202	
	11		Phase 3			1,052	
12	Total		1,001				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,001	
	14		Phase 2			1,001	
	15		Phase 3			1,002	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,992	
	17	Active power	Total	t1-10s to t1	p.u.	0,986	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,002	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	0,999		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	1,061	
	23		Phase 2			1,201	
	24		Phase 3			1,053	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,948	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,950	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,991	
	32		Pos.			--	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,001	
	34		Phase 2			1,001	
	35		Phase 3			1,002	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,985	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,346	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,002	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

**5.8.3 For PGUs Type 2 and storage systems** **P**



**5.8.3**
**For PGUs Type 2 and storage systems**
**P**


<b>5.8.3</b>	<b>For PGUs Type 2 and storage systems</b>	<b>P</b>
--------------	--	----------

<b>6.4</b>
------------


Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	6.4	
	1	Date	--	--	yyyy.mm.dd	2022.12.12	
	2	Time (start of test)	--	--	hh:mm:ss.f	19:24:00	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	1,2
	5	Setting dip duration		--	--	--	5000
		Point of fault entry	Total	--	--	ms	10599
	7	Point of fault clearance	Total	--	--	ms	15590
	8	Fault duration in empty load test	Total	--	--	ms	4991
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	1,061	
	10		Phase 2			1,202	
	11		Phase 3			1,052	
12	Total		1,001				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,001	
	14		Phase 2			1,001	
	15		Phase 3			1,002	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,219	
	17	Active power	Total	t1-10s to t1	p.u.	0,207	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,048	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	0,991		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	1,061	
	23		Phase 2			1,201	
	24		Phase 3			1,053	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,948	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,950	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,045	
32	Pos.		--				
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,001	
	34		Phase 2			1,001	
	35		Phase 3			1,002	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,206	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,222	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,046	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	



5.8.3

For PGUs Type 2 and storage systems


P



5.8.3

For PGUs Type 2 and storage systems

P








**5.8.3 For PGUs Type 2 and storage systems P**
**7.1**

Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	7.1	
	1	Date	--	--	yyyy.mm.dd	2022.12.4	
	2	Time (start of test)	--	--	hh:mm:ss.f	18:06:47	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	1,15
	5	Setting dip duration	--	--	--	--	60000
		Point of fault entry	Total	--	--	ms	10639
	7	Point of fault clearance	Total	--	--	ms	70639
	8	Fault duration in empty load test	Total	--	--	ms	60000
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	1,151	
	10		Phase 2			1,151	
	11		Phase 3			1,152	
12	Total		1,001				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,002	
	14		Phase 2			1,000	
	15		Phase 3			1,001	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,998	
	17	Active power	Total	t1-10s to t1	p.u.	0,993	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,040	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	0,993		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	1,151	
	23		Phase 2			1,150	
	24		Phase 3			1,151	
	25	Line current	Phase 1	t1+60ms	p.u.	0,012	
	26		Phase 2			--	
	27		Phase 3			--	
	28	Line current	Phase 1	t1+100ms	p.u.	0,010	
	29		Phase 2			--	
	30		Phase 3			--	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,002	
	32		Pos.			--	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,002	
	34		Phase 2			1,000	
	35		Phase 3			1,001	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,999	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,438	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,043	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

5.8.3 For PGUs Type 2 and storage systems

P






Time [s]	A	B	Delta	RMS
113.4466	230.0075	230.3767	0.36902	230.3289
229.3442	229.3442	229.9950	0.650787	229.8740
229.8372	229.8372	230.3093	0.472122	230.2218
799.2163	799.2163	803.2870	4.070762	802.4816
-37.32528	-37.32528	-42.14626	-4.820972	41.95984

**5.8.3 For PGUs Type 2 and storage systems P**
**7.2**

Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	7.2	
	1	Date	--	--	yyyy.mm.dd	2022.12.12	
	2	Time (start of test)	--	--	hh:mm:ss.f	13:38:53	
	3	Fault type (phase)	--	--	--	A	
	4	Setting voltage depth	Line to line	--	--	p.u.	1,15
	5	Setting dip duration	--	--	--	--	60000
		Point of fault entry	Total	--	--	ms	10639
	7	Point of fault clearance	Total	--	--	ms	70639
	8	Fault duration in empty load test	Total	--	--	ms	60000
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	1,151	
	10		Phase 2			1,151	
	11		Phase 3			1,152	
12	Total		1,001				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,003	
	14		Phase 2			1,000	
	15		Phase 3			1,002	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,215	
	17	Active power	Total	t1-10s to t1	p.u.	0,209	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,032	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	0,988		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	1,151	
	23		Phase 2			1,150	
	24		Phase 3			1,152	
	25	Line current	Phase 1	t1+60ms	p.u.	0,061	
	26		Phase 2			--	
	27		Phase 3			--	
	28	Line current	Phase 1	t1+100ms	p.u.	0,020	
	29		Phase 2			--	
	30		Phase 3			--	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,002	
	32		Pos.			--	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,001	
	34		Phase 2			1,001	
	35		Phase 3			1,002	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,210	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,421	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,033	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

**5.8.3 For PGUs Type 2 and storage systems P**




**5.8.3**
**For PGUs Type 2 and storage systems**
**P**



**5.8.3 For PGUs Type 2 and storage systems P**
**7.3**

Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	7.3	
	1	Date	--	--	yyyy.mm.dd	2022.12.12	
	2	Time (start of test)	--	--	hh:mm:ss.f	19:12:45	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	1,15
	5	Setting dip duration	--	--	--	--	60000
		Point of fault entry	Total	--	--	ms	10617
	7	Point of fault clearance	Total	--	--	ms	70645
	8	Fault duration in empty load test	Total	--	--	ms	60028
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	1,041	
	10		Phase 2			1,152	
	11		Phase 3			1,042	
12	Total		1,001				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,001	
	14		Phase 2			1,001	
	15		Phase 3			1,002	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,995	
	17	Active power	Total	t1-10s to t1	p.u.	0,989	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,009	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	1,000		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	1,041	
	23		Phase 2			1,151	
	24		Phase 3			1,040	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,961	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,961	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,994	
	32		Pos.			--	
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,001	
	34		Phase 2			1,001	
	35		Phase 3			1,002	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,989	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,800	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,008	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	



**5.8.3 For PGUs Type 2 and storage systems P**




**5.8.3**
**For PGUs Type 2 and storage systems**
**P**



<b>5.8.3</b>	<b>For PGUs Type 2 and storage systems</b>	<b>P</b>
--------------	--	----------

**7.4**

Condition						Measured value	
Item	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	7.4	
	1	Date	--	--	yyyy.mm.dd	2022.12.12	
	2	Time (start of test)	--	--	hh:mm:ss.f	19:20:17	
	3	Fault type (phase)	--	--	--	D1	
	4	Setting voltage depth	Line to line	--	--	p.u.	1,15
	5	Setting dip duration	--	--	--	--	60000
		Point of fault entry	Total	--	--	ms	10617
	7	Point of fault clearance	Total	--	--	ms	70645
	8	Fault duration in empty load test	Total	--	--	ms	60028
	9	Voltage depth/height in empty load test	Phase 1	t1+100ms to t2 and t1-10s to t1	p.u.	1,041	
	10		Phase 2			1,152	
	11		Phase 3			1,042	
12	Total		1,001				
Before dip <t1	13	Voltage	Phase 1	t1-10s to t1	p.u.	1,001	
	14		Phase 2			1,001	
	15		Phase 3			1,002	
	16	Current	Pos.	t1-500ms to t1-100ms	p.u.	0,217	
	17	Active power	Total	t1-10s to t1	p.u.	0,206	
	18		Pos.			--	
	19	Reactive power	Total	t1-10s to t1	p.u.	0,047	
	20		Pos.			--	
21	Cosφ	Total	t1-10s to t1	--	0,976		
During dip t1 to t2	22	Voltage	Phase 1	t1+100ms to t2-20ms	p.u.	1,041	
	23		Phase 2			1,151	
	24		Phase 3			1,043	
	25	Line current	Phase 1	t1+60ms	p.u.	--	
	26		Phase 2			--	
	27		Phase 3			0,210	
	28	Line current	Phase 1	t1+100ms	p.u.	--	
	29		Phase 2			--	
	30		Phase 3			0,210	
	31	Active power	Total	t1+100ms to t2-20ms	p.u.	0,206	
32	Pos.		--				
After dip > t2	33	Voltage	Phase 1	t2+3s to t2+10s	p.u.	1,001	
	34		Phase 2			1,001	
	35		Phase 3			1,002	
	36	Active power	Total	t2+3s to t2+10s	p.u.	0,206	
	37		Pos.			--	
	38	Active power rising time	Total	--	s	0,385	
	39	Reactive power	Total	t2+3s to t2+10s	p.u.	0,047	
	40		Pos.			--	
	41	Reactive power rising time	total	--	s	--	
	42	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	

**5.8.3** For PGUs Type 2 and storage systems **P**



**5.8.3**
**For PGUs Type 2 and storage systems**
**P**


Time [s]	A	B	Delta	RMS
● U1_rms_rc@POWER/0 [V]	229.6046	230.2711	0.666595	230.1188
● U2_rms_rc@POWER/0 [V]	233.7156	230.0913	-3.624283	229.6523
● U3_rms_rc@POWER/0 [V]	233.0523	230.4447	-2.607590	230.4192
● P3_fund_rc@POWER/0 [W]	166.4579	164.5475	-1.910385	164.3962
● Q3_fund_rc@POWER/0 [var]	41.29215	37.39046	-3.901688	36.94846




## Annex 2 – Pictures of the unit

Photos of EUT

General view -1



General view -2



Photos of EUT

General view -3



General view -4






Photos of EUT

Internal view -1



Internal view -2





## Annex 3 – Test equipment list

Date(s) of performance of tests: 2022-09-07 to 2022-12-19

Equipment	Internal No.	Manufacturer	Type	Serial No.	Due date Calibration
DC source	HC-ENG-011	Chroma	62150H-1000S	62150EF00314	Monitored by Power Analyzer
	HC-ENG-010	Chroma	62150H-1000S	62150EF01653	
AC source	HC-ENG-012	Chroma	61830	//	
Load	HC-ENG-005	Qunling	ACLT-3803H	93H006289	
Data acquisition instrument	HC-ENG-003	DEWESOFT	SIRIUSi-HS-4xHV-4xLV	DB20123915	2023-09-05
	HC-ENG-029	DEWETRON	TRION-1820-POWER	A1228623	2023-06-23
Current sensor	HC-ENG-019	LEM	IT 400-S	82021060080	2023-09-05
	HC-ENG-020	LEM	IT 400-S	82021060081	2023-09-05
	HC-ENG-021	LEM	IT 400-S	82021060082	2023-09-05
	HC-ENG-022	LEM	IT 400-S	82021060084	2023-09-05

---End of test report--