



Product Service

Attestation of Compliance

No. N5A 004865 0011 Rev. 00

Holder of Attestation: SURGEFREE CORPORATION

904 Wooree Venture Town
466, Gangseo-ro, Gangseo-gu
Seoul 07573
REPUBLIC OF KOREA

**Product: Surge protection equipment
(Surge Protective Device)****Model(s): SHD-RJ45-8(POE)**

Parameters:	Rated input voltage:	48 V d.c.
	Type C2 test (Voltage 1.2/50 μ s, Current 8/20 μ s):	4 kV / 2 kA
	Maximum continuous operating voltage Uc:	50 V d.c.
	Voltage protection level Up:	150 V

Tested according to: EN 61643-21:2001/A2:2013

This Attestation of Compliance is issued on a voluntary basis and confirms the compliance with the listed electrical safety standards for electrical equipment below 50 V AC or 75 V DC, which is below the voltage limits of the Low Voltage Directive 2014/35/EU. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: MAEB01599822**Date,** 2023-01-31

(Harry Kwon)

Page 1 of 1

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. Other relevant European directives have to be observed. If they require CE marking, it may be affixed on the product after preparation of the necessary technical documentation as well as the EU declaration of conformity.



TUV®