

## **Declaration Of Performance**

WaterCare Ø600 Lifting Plant for faecal-free wastewater - 223190601 No.: DoP\_EN\_223190601\_RS Valid from: 2013.06.01

| Identification                           |  |  |
|--|--|--|
| 1. Product                               | WaterCare Ø600 Lifting Plant for fae-<br>cal-free wastewater   |  |
| 2. Item number                           | 223190601  |  |
| 3. Intended use                          | Lifting plant for faecal-free wastewater   |  |
| 4. Manufacturer                          | WaterCare ApS<br>Stejlebjergvej 14<br>DK - 5610 Assens<br>Denmark<br>Tel: +45 70 25 65 37<br>Web: www.watercare.dk |  |
| 5. Authorized representative             | -  |  |
| 6. System of assessment and verification | (EU) No. 305/2011 cf. Appendix V.  |  |
| 7. Harmonized standard                   | DS/EN 12050-2:2001   |  |
| 8. Technical Assessment                  | Not relevant   |  |



Item number: 223190601

| 9. Declared performance   |  |  |
|---------------------------|--|--|
| Essential characteristics | Performance  | Harmonized technical specification             |
| Dimensions                | Ø600 x 2000 mm   | -  |
| Material                  | PE   | DS/EN 12050-2:2001 pt. 6 (Annex B)             |
| Weight                    | < 80 kg  | -  |
| Water tightness           | No leakage   | DS/EN 12050-2:2001 pt. 4.4 jf. 8.5             |
| Odourtightness            | Require qualified cover/solution                         | -  |
| Noise level               | NPD  | Noise level below limit values<br>cf. 98/37/EF |
| Lifting effectiveness     |  |  |
| Pump                      | Grundfos AP35B.50.06.A1                                  | -  |
| Pipe connections          | DN50 (see installation instructions for venting & inlet) | DS/EN 12050-2:2001 pt. 5.2                     |
| Ventilation               | Must be drilled  | DS/EN 12050-2:2001 pt. 5.4                     |
| Minimum flow velocity     | 3,74 m/s at 40 kPa                                       | DS/EN 12050-2:2001 pt. 5.5                     |
| Minimum solids passage    | 10 mm  | DS/EN 12050-2:2001 pt. 5.6                     |
| Minimum useful volume     | 20   | DS/EN 12050-2:2001 pt. 3.3                     |

The Declaration Of Performance continues on page 2.



| 9. Declared performance - continued |   |                                    |  |  |
|-------------------------------------|---|------------------------------------|--|--|
| Essential characteristics           | Performance   | Harmonized technical specification |  |  |
| Mechanical resistance               |   |                                    |  |  |
| Crushing resistance                 | 26,6 kN/m²  | DS/EN 12566-3:2009 Annex C         |  |  |
| Durability                          |   |                                    |  |  |
| Fixing devices                      | Passed  | DS/EN 12050-2:2001 pt. 5.3         |  |  |
| 10. Conformity                      | The performance of the product identified in point 1 and 2 (page 1) is in conformity with the declared performance in point 9 (page 1 & 2). This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4 (page 1). |                                    |  |  |

Signed for and on behalf of the manufacturer by:

Assens, date 01.06.2020

Jacob L. Kristensen, Engineer