

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing  
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031  
P.O Box 240, North Melbourne, Victoria 3051  
Phone (03) 9371 2400

## TEST REPORT

**Client :** Sitca Pty Ltd (Primo Walk)  
20/8 Victoria Avenue  
Castle Hill NSW 2154

**Test Number :** 23-004496  
**Issue Date :** 30/11/2023  
**Print Date :** 30/11/2023

**Sample Description** Clients Ref : "Signature Primo Walk"  
SPC Hybrid flooring planks with integrated underlay  
Colour : Timber Look  
End Use : Flooring  
Nominal Composition : Wear layer, SPC core, 1XPE Pad  
Nominal Mass per Unit Area/Density : 2200g/m2  
Nominal Thickness : 6.5mm



310538

67622

Page 1 of 2

© Australian Wool Testing Authority Ltd  
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing  
Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



Fiona McDonald

APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc.(Hons)  
MANAGING DIRECTOR

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing  
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031  
P.O Box 240, North Melbourne, Victoria 3051  
Phone (03) 9371 2400

## TEST REPORT

**Client :** Sitca Pty Ltd (Primo Walk)  
20/8 Victoria Avenue  
Castle Hill NSW 2154

**Test Number :** 23-004496  
**Issue Date :** 30/11/2023  
**Print Date :** 30/11/2023

### AS 4586-2013 Appendix A

### Slip Resistance Classification of new Pedestrian Surface Materials Wet Pendulum Test Method

Date of Testing 30-11-2023  
Operator AWTA Test Operator 4  
Test Temperature (20±5degC) 22 °C  
Sample washed with pH neutral detergent and dried  
Test Direction Length  
Fixed/Unfixed Unfixed

Slider No 96 Batch No					23	
Length	1	2	3	4	5	SRV
British Pendulum number	37	37	36	39	38	37

Classification P3

Equipment: Cooper Pendulum Skid Tester Serial No: 1433-01 Calibrated 11/10/2023  
Slider prepared using P400 and 3µm lapping film.

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance and wear on their slip resistance be checked.

310538

67622

Page 2 of 2

© Australian Wool Testing Authority Ltd  
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing  
Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

