



# TEST REPORT



**Test Report No :URS/CH/RID/22/11/222**  
**Dated : 23/11/2022**

Issued To : Wisewell Technologies Ltd		Office No.102 Incubayt investments Burj Daman Building Dubai International Financial Center (DIFC) Dubai, United Arab Emirates	
Attention	Mr. Sebastien Wakim		
Sample Condition (Receipt Temperature)	4.2°C	Sample Condition (On Site)	21.4°C
Customer Ref.No.	39572/ Dated 16/11/2022 <b>TRF No:URS/SR/CH/3208 /</b> <b>Sample ID: URS/F/CH /SID/22/11/126</b>	Sample Package & Quantity	1 Litre
Sample Name	Water: Filtered Drinking Water (Unbottle)	Source of Sample	Filter Water
Sample Description	Colorless Liquid	Sampled by	Atif Muhammad
Batch No. /Lot No.	NA	Delivered by	Lab Representative
Manufacturing Date	NA	Sampling Protocol	URS-SOP-16
Best before date	NA	Date of Sample Receipt	16/11/2022
Other Details	NA	Date of Analysis	16/11/2022
Date of Completion	23/11/2022		

**Note:** NA

**Note:** For any queries, please contact lab manager at [info@urslabs.com](mailto:info@urslabs.com).

S.NO	Test Parameters	Test Methods	Unit	Result	Acceptable Limits	MU(±)	LOQ
1	pH@25°C	APHA 4500H+ B	--	7.29	6.5 - 8.5^	0.04	--
2	Conductivity@25°C	APHA 2510 B	µS/cm	65	2500	5.40	3.0
3	Turbidity	APHA 2130 B	NTU	<0.1	<0.4	NA	0.1
4	Total Dissolved Solids	APHA 2540 C	mg/l	34	500^	9.58	5.0
5	Total Hardness(CaCO3)	APHA 2340 C	mg/l	6.06	300	3.86	2.0
6	Calcium (Ca)	APHA 3500 Ca B	mg/l	<2.0	80	1.37	2.0
7	Magnesium (Mg)	APHA 3500 Mg B	mg/l	<2.0	30	1.12	2.0
8	Chloride(Cl)	APHA 4500 Cl- B	mg/l	12.42	250	1.88	2.0
9	Sulphate(SO4)	APHA 4500 SO42- E	mg/l	<2.0	250	2.0	2.0
10	Sodium (Na)	APHA 3500 Na	mg/l	7.5	150	3.0	2.0
11	Potassium (K)	APHA 3500 K	mg/l	<2.0	12	NA	2.0
12	Iron(Fe)	APHA 3500 Fe	mg/l	<0.1	0.3	NA	0.1

R. Bui vy

Technical Manager- Chemical

**Laboratory :**  
**URS Testing Laboratory LLC**  
Ware house No:64  
Industrial area 1, Jebel Ali Dubai UAE



Phone : +971 48837115  
E-Mail : [info@urslabs.com](mailto:info@urslabs.com)  
Web site : [www.urslabs.com](http://www.urslabs.com)  
PO Box 377913



# TEST REPORT



**Test Report No :URS/CH/RID/22/11/222**  
**Dated : 23/11/2022**

S.NO	Test Parameters	Test Methods	Unit	Result	Acceptable Limits	MU(±)	LOQ
13	Nitrate(NO3)	APHA 4500 NO3- B	mg/l	<0.1	50	NA	0.1
14	Nitrite(NO2)	EPA -354-1 NO2	mg/l	<0.1	3.0	NA	0.1

**Remarks: The sample analysed is of satisfactory quality with respect to above tested parameter.**

Test method Variation: None, ND: Not Detected, NA: Not Applicable, LOQ : Limit of Quantitation, MU: Measurement of Uncertainty

\* Parameter not accredited,

# Subcontract Parameter accredited. Measurement of Uncertainty provided is expanded uncertainty using coverage factor of 2 at 95% confidence level

Decision Rule:- Statements of conformity (e.g. Satisfactory/ Not Satisfactory) to specifications are made in this report without taking measurement uncertainty into account. Where statements of conformity are made in this report, the following decision rules are applied: Satisfactory – Results within limits/specifications, Not Satisfactory – Results exceed limits/specifications.

Limit:- Water Quality Regulation 5th Edition & US EPA National Primary Drinking water regulation.

**Note:** (1) The results relate only to the items tested,

(2) The test report shall not be reproduced except in full without the written approval of the URS laboratory,

R. Binay

Technical Manager- Chemical

**Laboratory :**  
**URS Testing Laboratory LLC**  
Ware house No:64  
Industrial area 1, Jebel Ali Dubai UAE



Phone : +971 48837115  
E-Mail : info@urslabs.com  
Web site : www.urslabs.com  
PO Box 377913

-----END OF THE TEST REPORT-----