



EC CERTIFICATE OF CONFORMITY

Number: 1121 – CPD – KA0045

In compliance with Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it is confirmed that the following products are subject to factory production control procedures and are submitted by the manufacturer to further testing of samples taken at the factory in accordance with a prescribed test plan. The stated Notified Certification Body has performed the initial type-testing for the relevant characteristics of the product, has conducted the initial inspection of the factory and the factory production control, and is responsible for the continuous surveillance, assessment and approval of the factory production control.

construction product: **Decorative PVC based self adhesive wallcoverings, described as follows:**

"Belbien", Types "PR, A, C, CY, F, K, S, W, SW, WA, BC, NC, SA, BR, CO, DA, MA" having a thickness of between 0.19mm and 0.26mm and a total weight of between 264g/m² and 285g/m², with or without embossed surface finish.

placed on the market by: **C.I. Kasei**

company Address: **18-1 Kyobashi 1-Chome, Chuo-Ku, Tokyo, 104-8321, Japan**

intended use: **Applying to internal walls or partitions, for the primary purpose of decoration.**

This document certifies that all the provisions concerning the attestation of conformity and product performance described in Annex ZA of the product standard.

EN 15102: 2007+ A1 : 2011

was applied and that the product fulfils all the prescribed requirements.

Notified Certification Body: **Warrington Certification Ltd**

EC Reference Number: **1121**

This certificate was first issued on **02/05/12** and revised on **15/05/12** and remains valid as long as the conditions laid down in the harmonised technical specification above, or the product design, or the manufacturing conditions in the factory, or the FPC itself are not modified.



Manager – Warrington Certification Ltd.

References:

Classification reports: WF 316521 (Exova Warringtonfire)

Extended application report WF 316520

Factory references: AC/004

Reaction to Fire Classification: B – s1, d0

Other test evidence: Heavy Metals / VCM report reference 1011-0058 (Butterworth Laboratories), all results within prescribed limits of EN 15102:2007+A1: 2011