


# MERV 13 Interior Cover

Replacement filter for inner screen type 9/IBK and 9/IBG-H



(A) Inner Screen  
(B) Cover Frame  
(C) Filter



Check the filter every 3 months for contamination and replace it if necessary. The supply air opening must not be blocked or covered.

## Snap on the inner screen

Insert the filter (note direction of the arrow) and snap the inner screen into the open position (G).

