



NOZZLE SCHEDULE							
ITEM	SIZE	RATING	TYPE	MATL	PROJ IN	PROJ OUT	REMARKS
A	2"	N.P.T.	W.F.	C.S.	STD.	STD.	
B	4"	N.P.T.	W.F.	C.S.	STD.	STD.	EMERGENCY VENT OPENING
C	3/4"	N.P.T.	W.F.	C.S.	STD.	STD.	DRAIN

- NOTES:
- A. QUANTITY:
  - B. MATERIAL: H.R. CARBON STEEL
  - C. TANK: 12 GA. W/10 GA. TOP
  - D. DESIGN & OPERATING PRESSURE: ATOMOSPHERIC.
  - E. DESIGN & OPERATING TEMPERATURE: AMBIENT.
  - F. TANK TO BE BUILT & LABELED PER U.L. SPEC. #142.
  - G. TANK TO BEAR MANUFACTURERS & U.L. LABELS ONLY.
  - H. TANK TO BE AIR TESTED WITH WATER & SOAP SUDS SOLUTION.
  - I. INTERIOR: REMOVE WELD SLAG (SHIP CLEAN & DRY).
  - J. EXTERIOR: GRAY PRIMER INCLUDED; SEE SALES ORDER FOR TOP COAT.
  - K. ALL FITINGS TO BE PROTECTED FOR SHIPMENT.
  - L. CUSTOMER HAS THE RESPONSIBILITY TO VERIFY ALL DIMENSIONS.

APPROVAL FOR CONSTRUCTION  
 SCHEDULE A - MASTER TERMS &  
 CONDITION OF SALE\*

APPROVED AS DRAWN.

APPROVED WITH NOTED CHANGES,  
 CONSTRUCTION WILL BE SCHEDULED  
 WHEN SIGNED DRAWING AND  
 CONFIRMED ORDER ARE RECEIVED.

SIGNATURE: \_\_\_\_\_

DATE: \_\_\_\_\_

\*All pages of this Schedule A are incorporated by  
 reference and are a part of the additional terms of  
 the Master Terms & Conditions of Sale.  
 www.newberrytanks.com/masterterms.pdf

**SALES ORDER: -**

**Newberry Tanks**  
 New Thinking

Phone: 870-735-4473 Fax: 870-735-3982

WEIGHT (LBS): **458**

All units inches unless stated otherwise

DESCRIPTION:  
 350 GALLON RECTANGULAR UL 142 SINGLE WALL TANK

CUSTOMER: \_\_\_\_\_ P.O.# \_\_\_\_\_

DATE: 9/8/2020 SCALE: \_\_\_\_\_ DWG.#: FTSBS-0350

DRAWN BY: AJC  
 SHEET 1 OF 1